

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2020年11月1日 (日)

項 目 時 刻	1号炉				
	塩 化 水 素	窒 素 酸 化 物	硫 黄 酸 化 物	ば い じ ん	水 銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	7	1	0	1
2	6	9	1	0	1
3	6	10	1	0	1
4	6	6	0	0	1
5	6	7	0	0	1
6	6	9	1	0	1
7	6	13	2	0	1
8	6	7	0	0	1
9	6	8	0	0	1
10	6	12	2	0	1
11	5	10	1	0	1
12	6	8	0	0	1
13	6	12	1	0	1
14	6	11	2	0	0
15	6	8	0	0	0
16	6	8	1	0	0
17	6	12	1	0	0
18	6	10	2	0	0
19	6	7	1	0	0
20	6	9	1	0	0
21	6	12	2	0	0
22	6	8	1	0	0
23	6	9	1	0	0
24	6	11	2	0	0

自主規制値
法規制値

項 目 時 刻	2号炉				
	塩 化 水 素	窒 素 酸 化 物	硫 黄 酸 化 物	ば い じ ん	水 銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	8	0	0	0
2	6	8	0	0	0
3	6	12	0	0	0
4	6	8	0	0	0
5	6	7	0	0	0
6	6	8	0	0	0
7	6	12	0	0	0
8	6	10	0	0	0
9	6	8	0	0	0
10	6	12	0	0	0
11	6	9	0	0	0
12	6	7	0	0	0
13	5	11	0	0	0
14	6	11	0	0	0
15	5	7	0	0	0
16	6	9	0	0	0
17	6	11	1	0	0
18	6	10	0	0	0
19	6	7	0	0	0
20	6	8	1	0	0
21	6	13	1	0	0
22	6	9	0	0	0
23	6	12	0	0	0
24	6	12	0	0	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2020年11月2日 (月)

項 目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	10	2	0	0
2	6	8	0	0	0
3	6	12	2	0	0
4	6	10	1	0	0
5	6	8	0	0	0
6	6	11	2	0	0
7	6	11	2	0	0
8	6	7	0	0	0
9	6	12	1	0	0
10	6	11	1	0	1
11	6	9	0	0	0
12	6	12	2	0	0
13	5	11	1	0	0
14	6	13	2	0	0
15	6	8	0	0	0
16	6	9	0	0	1
17	6	11	2	0	0
18	6	9	0	0	0
19	6	10	0	0	0
20	6	13	1	0	0
21	6	9	0	0	0
22	6	8	0	0	0
23	6	13	2	0	0
24	6	9	1	0	0

自主規制値
法規制値

項 目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	10	0	0	0
2	6	10	0	0	0
3	6	11	0	0	0
4	6	9	0	0	0
5	6	12	0	0	0
6	6	11	0	0	0
7	6	9	0	0	0
8	6	9	0	0	0
9	6	13	0	0	0
10	6	10	0	0	0
11	6	10	0	0	0
12	6	8	0	0	0
13	6	10	0	0	0
14	6	11	0	0	0
15	6	10	0	0	0
16	6	11	0	0	0
17	6	11	0	0	0
18	6	12	0	0	0
19	6	11	0	0	0
20	6	12	0	0	0
21	6	12	0	0	0
22	6	10	0	0	0
23	6	10	0	0	0
24	6	13	0	0	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2020年11月3日 (火)

項 目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	9	1	0	0
2	6	13	2	0	0
3	6	10	1	0	0
4	6	9	0	0	0
5	6	12	1	0	0
6	6	10	0	0	0
7	6	8	0	0	1
8	6	11	1	0	1
9	6	11	1	0	0
10	6	9	0	0	0
11	6	10	0	0	0
12	6	13	1	0	0
13	6	8	0	0	0
14	6	8	0	0	0
15	6	12	1	0	0
16	6	11	1	0	0
17	6	8	0	0	0
18	6	9	0	0	0
19	6	13	1	0	0
20	6	9	0	0	0
21	6	8	0	0	0
22	6	10	1	0	0
23	6	13	2	0	0
24	6	10	1	0	0

自主規制値
法規制値

項 目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	11	0	0	0
2	6	11	0	0	0
3	6	12	0	0	0
4	6	10	0	0	0
5	6	11	0	0	0
6	6	10	0	0	0
7	6	13	0	0	0
8	6	12	0	0	0
9	6	12	0	0	0
10	6	12	0	0	0
11	6	10	0	0	0
12	6	8	0	0	0
13	6	13	0	0	0
14	6	10	0	0	0
15	6	11	0	0	0
16	6	11	0	0	0
17	6	10	0	0	0
18	6	12	0	0	0
19	6	12	0	0	0
20	6	11	0	0	0
21	6	10	0	0	0
22	6	11	0	0	0
23	6	9	0	0	0
24	6	9	0	0	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2020年11月4日 (水)

項 目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	7	0	0	0
2	6	11	0	0	1
3	6	11	1	0	1
4	6	8	0	0	1
5	6	11	1	0	1
6	6	11	1	0	1
7	6	8	0	0	1
8	6	10	1	0	1
9	6	12	1	0	1
10	4	9	0	0	1
11	4	8	0	0	1
12	4	9	0	0	1
13	4	6	0	0	1
14	4	7	0	0	1
15	4	10	0	0	1
16	4	7	0	0	0
17	4	8	0	0	0
18	4	8	0	0	0
19	4	7	1	0	0
20	4	9	1	0	0
21	4	10	1	0	0
22	4	9	0	0	1
23	4	8	0	0	0
24	6	9	0	0	1

自主規制値
法規制値

項 目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	12	0	0	0
2	6	11	0	0	0
3	6	10	0	0	0
4	6	12	0	0	0
5	6	12	0	0	0
6	6	11	0	0	0
7	6	10	0	0	0
8	6	10	0	0	0
9	6	11	0	0	0
10	4	9	0	0	0
11	4	10	0	0	0
12	5	9	0	0	1
13	4	9	0	0	0
14	4	9	0	0	0
15	4	8	0	0	0
16	4	7	0	0	0
17	4	7	0	0	0
18	4	9	0	0	0
19	4	10	0	0	0
20	4	10	0	0	0
21	4	9	0	0	0
22	4	6	0	0	0
23	4	12	0	0	0
24	6	12	0	0	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2020年11月5日 (木)

項 目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	11	1	0	0
2	6	10	1	0	0
3	6	6	0	0	0
4	6	11	1	0	0
5	6	7	1	0	0
6	6	8	1	0	0
7	6	11	2	0	0
8	6	8	1	0	0
9	6	8	1	0	0
10	6	11	2	0	0
11	6	9	1	0	1
12	6	7	0	0	1
13	6	8	0	0	0
14	6	12	2	0	0
15	6	8	0	0	0
16	6	9	0	0	0
17	6	12	2	0	0
18	6	10	1	0	0
19	6	8	0	0	0
20	6	11	1	0	0
21	6	12	2	0	0
22	6	8	0	0	0
23	6	10	1	0	0
24	6	12	2	0	0

自主規制値
法規制値

項 目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	12	0	0	0
2	6	9	0	0	0
3	6	12	0	0	0
4	6	13	0	0	0
5	6	9	0	0	0
6	6	6	0	0	0
7	6	9	0	0	0
8	6	12	0	0	0
9	6	10	0	0	0
10	6	11	0	0	0
11	6	11	0	0	0
12	6	11	0	0	0
13	6	11	0	0	0
14	6	12	0	0	0
15	6	10	0	0	0
16	6	11	0	0	0
17	6	11	0	0	0
18	6	10	0	0	0
19	6	12	0	0	1
20	6	10	0	0	1
21	6	12	0	0	1
22	6	12	0	0	1
23	6	11	0	0	1
24	6	11	0	0	1

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2020年11月6日 (金)

項 目 時 刻	1号炉				
	塩 化 水 素	窒 素 酸 化 物	硫 黄 酸 化 物	ば い じ ん	水 銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	9	1	0	0
2	6	11	0	0	0
3	6	10	1	0	0
4	6	9	0	0	0
5	6	12	2	0	0
6	6	8	0	0	0
7	6	7	0	0	0
8	6	12	2	0	0
9	6	8	1	0	0
10	6	9	0	0	0
11	6	10	2	0	0
12	6	11	2	0	0
13	6	10	1	0	0
14	6	8	0	0	0
15	6	11	2	0	0
16	6	11	2	0	0
17	6	8	1	0	0
18	6	10	1	0	0
19	6	12	1	0	0
20	6	9	0	0	0
21	6	9	0	0	0
22	6	12	1	0	0
23	6	10	1	0	0
24	6	8	0	0	0

自主規制値
法規制値

項 目 時 刻	2号炉				
	塩 化 水 素	窒 素 酸 化 物	硫 黄 酸 化 物	ば い じ ん	水 銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	9	0	0	1
2	6	13	0	0	0
3	6	12	0	0	0
4	6	11	0	0	0
5	6	11	0	0	0
6	6	12	0	0	0
7	6	12	0	0	0
8	6	11	0	0	0
9	6	11	0	0	0
10	6	11	0	0	0
11	6	10	0	0	0
12	6	10	0	0	0
13	6	10	0	0	0
14	6	12	0	0	0
15	6	10	0	0	0
16	6	11	0	0	0
17	6	11	0	0	0
18	6	11	0	0	0
19	6	12	0	0	0
20	6	11	0	0	0
21	6	11	0	0	1
22	6	13	0	0	1
23	6	12	0	0	1
24	6	10	0	0	1

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2020年11月7日 (土)

項 目 時 刻	1号炉				
	塩 化 水 素	窒 素 酸 化 物	硫 黄 酸 化 物	ば い じ ん	水 銀
	ppm	ppm	ppm	g/mN	μg/mN
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	9	1	0	0
2	6	12	2	0	0
3	6	11	1	0	0
4	6	7	0	0	0
5	6	10	0	0	0
6	6	12	1	0	0
7	6	9	0	0	0
8	6	9	0	0	0
9	6	9	1	0	0
10	6	10	2	0	0
11	6	11	1	0	0
12	6	7	0	0	0
13	6	8	0	0	0
14	6	10	2	0	0
15	6	9	1	0	0
16	6	7	0	0	0
17	6	9	0	0	0
18	6	11	2	0	0
19	6	9	1	0	0
20	6	10	1	0	0
21	6	12	2	0	0
22	6	10	1	0	0
23	6	9	0	0	0
24	6	11	1	0	0

自主規制値
法規制値

項 目 時 刻	2号炉				
	塩 化 水 素	窒 素 酸 化 物	硫 黄 酸 化 物	ば い じ ん	水 銀
	ppm	ppm	ppm	g/mN	μg/mN
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	11	0	0	1
2	6	11	0	0	1
3	6	12	0	0	1
4	6	11	0	0	2
5	6	10	0	0	2
6	6	10	0	0	1
7	6	9	0	0	1
8	6	12	0	0	1
9	6	10	0	0	1
10	6	9	0	0	1
11	6	13	0	0	1
12	6	10	0	0	1
13	----	----	----	----	----
14	----	----	----	----	----
15	----	----	----	----	----
16	----	----	----	----	----
17	----	----	----	----	----
18	----	----	----	----	----
19	----	----	----	----	----
20	----	----	----	----	----
21	----	----	----	----	----
22	----	----	----	----	----
23	----	----	----	----	----
24	----	----	----	----	----

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2020年11月8日 (日)

項 目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	11	1	0	0
2	6	9	0	0	0
3	6	10	0	0	0
4	6	10	1	0	0
5	6	10	2	0	0
6	6	13	2	0	0
7	6	9	0	0	0
8	6	11	1	0	0
9	6	12	1	0	0
10	6	10	0	0	0
11	6	8	0	0	0
12	6	12	0	0	0
13	6	12	1	0	0
14	6	10	0	0	0
15	6	9	0	0	0
16	6	11	0	0	0
17	6	10	0	0	0
18	6	10	0	0	0
19	6	10	0	0	0
20	6	10	0	0	0
21	6	9	0	0	0
22	6	9	0	0	0
23	6	9	0	0	0
24	6	10	0	0	0

自主規制値
法規制値

項 目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	----	----	----	----	----
2	----	----	----	----	----
3	----	----	----	----	----
4	----	----	----	----	----
5	----	----	----	----	----
6	----	----	----	----	----
7	----	----	----	----	----
8	----	----	----	----	----
9	----	----	----	----	----
10	----	----	----	----	----
11	----	----	----	----	----
12	----	----	----	----	----
13	----	----	----	----	----
14	----	----	----	----	----
15	----	----	----	----	----
16	----	----	----	----	----
17	----	----	----	----	----
18	----	----	----	----	----
19	----	----	----	----	----
20	----	----	----	----	----
21	----	----	----	----	----
22	----	----	----	----	----
23	----	----	----	----	----
24	----	----	----	----	----

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2020年11月9日 (月)

項 目 時 刻	1号炉				
	塩 化 水 素	窒 素 酸 化 物	硫 黄 酸 化 物	ば い じ ん	水 銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	8	0	0	0
2	6	9	0	0	0
3	6	9	1	0	0
4	5	8	1	0	0
5	6	9	1	0	0
6	6	12	2	0	0
7	6	10	0	0	0
8	6	8	0	0	0
9	6	10	0	0	0
10	6	12	1	0	0
11	6	10	0	0	0
12	6	9	0	0	0
13	6	10	0	0	0
14	6	9	0	0	0
15	6	10	0	0	0
16	6	10	1	0	0
17	6	12	1	0	0
18	6	9	0	0	0
19	6	9	0	0	0
20	6	12	1	0	1
21	6	10	1	0	0
22	6	10	0	0	0
23	6	10	0	0	0
24	6	11	1	0	0

自主規制値
法規制値

項 目 時 刻	2号炉				
	塩 化 水 素	窒 素 酸 化 物	硫 黄 酸 化 物	ば い じ ん	水 銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	----	----	----	----	----
2	----	----	----	----	----
3	----	----	----	----	----
4	----	----	----	----	----
5	----	----	----	----	----
6	----	----	----	----	----
7	----	----	----	----	----
8	----	----	----	----	----
9	----	----	----	----	----
10	----	----	----	----	----
11	----	----	----	----	----
12	----	----	----	----	----
13	----	----	----	----	----
14	----	----	----	----	----
15	----	----	----	----	----
16	----	----	----	----	----
17	----	----	----	----	----
18	----	----	----	----	----
19	----	----	----	----	----
20	----	----	----	----	----
21	----	----	----	----	----
22	----	----	----	----	----
23	----	----	----	----	----
24	----	----	----	----	----

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2020年11月10日 (火)

項 目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	10	0	0	1
2	6	9	0	0	1
3	6	8	0	0	1
4	6	11	1	0	1
5	6	10	1	0	1
6	6	9	0	0	1
7	6	9	0	0	1
8	6	10	1	0	1
9	6	12	1	0	1
10	6	10	0	0	1
11	6	10	0	0	1
12	6	10	0	0	1
13	6	11	0	0	1
14	6	10	0	0	0
15	6	9	0	0	1
16	6	10	0	0	0
17	6	9	1	0	1
18	6	14	2	0	0
19	6	8	0	0	0
20	6	9	0	0	0
21	6	11	1	0	0
22	6	12	1	0	0
23	6	9	0	0	1
24	6	11	0	0	3

自主規制値
法規制値

項 目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	----	----	----	----	----
2	----	----	----	----	----
3	----	----	----	----	----
4	----	----	----	----	----
5	----	----	----	----	----
6	----	----	----	----	----
7	----	----	----	----	----
8	----	----	----	----	----
9	----	----	----	----	----
10	----	----	----	----	----
11	----	----	----	----	----
12	----	----	----	----	----
13	----	----	----	----	----
14	----	----	----	----	----
15	----	----	----	----	----
16	----	----	----	----	----
17	----	----	----	----	----
18	----	----	----	----	----
19	----	----	----	----	----
20	----	----	----	----	----
21	----	----	----	----	----
22	----	----	----	----	----
23	----	----	----	----	----
24	----	----	----	----	----

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2020年11月11日 (水)

項 目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	9	0	0	3
2	6	10	1	0	2
3	6	12	1	0	1
4	6	10	0	0	1
5	7	8	0	0	1
6	5	11	1	0	1
7	2	10	0	0	1
8	3	8	0	0	1
9	4	11	0	0	0
10	5	10	0	0	1
11	5	10	0	0	1
12	4	9	0	0	0
13	6	12	1	0	0
14	6	8	0	0	0
15	6	8	0	0	0
16	5	11	0	0	0
17	6	11	1	0	0
18	6	10	0	0	0
19	6	11	0	0	0
20	6	10	0	0	0
21	6	10	0	0	0
22	6	8	0	0	0
23	6	11	0	0	0
24	6	11	1	0	0

自主規制値
法規制値

項 目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	----	----	----	----	----
2	----	----	----	----	----
3	----	----	----	----	----
4	----	----	----	----	----
5	----	----	----	----	----
6	----	----	----	----	----
7	----	----	----	----	----
8	----	----	----	----	----
9	----	----	----	----	----
10	----	----	----	----	----
11	----	----	----	----	----
12	----	----	----	----	----
13	----	----	----	----	----
14	----	----	----	----	----
15	----	----	----	----	----
16	----	----	----	----	----
17	----	----	----	----	----
18	----	----	----	----	----
19	----	----	----	----	----
20	----	----	----	----	----
21	----	----	----	----	----
22	----	----	----	----	----
23	----	----	----	----	----
24	----	----	----	----	----

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2020年11月12日 (木)

項 目 時 刻	1号炉				
	塩 化 水 素	窒 素 酸 化 物	硫 黄 酸 化 物	ば い じ ん	水 銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	8	0	0	0
2	6	8	1	0	0
3	6	11	2	0	0
4	6	10	2	0	0
5	6	7	1	0	0
6	6	9	1	0	0
7	6	13	1	0	0
8	6	10	1	0	0
9	6	8	0	0	0
10	6	11	1	0	0
11	6	12	2	0	0
12	6	9	0	0	0
13	6	8	0	0	0
14	6	10	1	0	1
15	6	12	2	0	1
16	6	9	1	0	0
17	6	10	1	0	0
18	6	12	2	0	0
19	6	9	0	0	0
20	6	10	0	0	0
21	6	10	1	0	0
22	6	8	0	0	0
23	6	10	1	0	0
24	6	7	0	0	0

自主規制値
法規制値

項 目 時 刻	2号炉				
	塩 化 水 素	窒 素 酸 化 物	硫 黄 酸 化 物	ば い じ ん	水 銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	----	----	----	----	----
2	----	----	----	----	----
3	----	----	----	----	----
4	----	----	----	----	----
5	----	----	----	----	----
6	----	----	----	----	----
7	----	----	----	----	----
8	----	----	----	----	----
9	----	----	----	----	----
10	----	----	----	----	----
11	----	----	----	----	----
12	----	----	----	----	----
13	----	----	----	----	----
14	----	----	----	----	----
15	----	----	----	----	----
16	----	----	----	----	----
17	----	----	----	----	----
18	----	----	----	----	----
19	----	----	----	----	----
20	----	----	----	----	----
21	----	----	----	----	----
22	----	----	----	----	----
23	----	----	----	----	----
24	----	----	----	----	----

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2020年11月13日 (金)

項 目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	10	0	0	0
2	6	9	1	0	0
3	6	8	0	0	0
4	5	11	1	0	0
5	6	10	1	0	0
6	6	8	0	0	0
7	5	8	0	0	0
8	5	10	0	0	0
9	5	12	1	0	0
10	6	8	0	0	0
11	6	7	0	0	0
12	6	9	0	0	0
13	6	11	1	0	0
14	6	9	1	0	0
15	6	7	1	0	0
16	6	10	1	0	0
17	6	12	1	0	0
18	6	9	1	0	0
19	6	8	0	0	0
20	6	10	0	0	0
21	6	10	1	0	0
22	6	9	0	0	0
23	6	10	0	0	0
24	6	12	1	0	0

自主規制値
法規制値

項 目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	----	----	----	----	----
2	----	----	----	----	----
3	----	----	----	----	----
4	----	----	----	----	----
5	----	----	----	----	----
6	----	----	----	----	----
7	----	----	----	----	----
8	----	----	----	----	----
9	----	----	----	----	----
10	----	----	----	----	----
11	----	----	----	----	----
12	----	----	----	----	----
13	----	----	----	----	----
14	----	----	----	----	----
15	----	----	----	----	----
16	----	----	----	----	----
17	----	----	----	----	----
18	----	----	----	----	----
19	----	----	----	----	----
20	----	----	----	----	----
21	----	----	----	----	----
22	----	----	----	----	----
23	----	----	----	----	----
24	----	----	----	----	----

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2020年11月14日 (土)

項 目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	9	0	0	0
2	6	8	0	0	0
3	6	13	1	0	0
4	6	11	1	0	0
5	6	8	0	0	0
6	6	10	1	0	0
7	6	11	1	0	0
8	6	9	0	0	0
9	6	9	0	0	0
10	6	12	1	0	0
11	6	10	0	0	0
12	6	10	0	0	0
13	6	10	0	0	0
14	6	13	1	0	0
15	6	10	0	0	0
16	6	8	0	0	0
17	6	14	0	0	0
18	5	8	0	0	0
19	6	9	0	0	0
20	5	10	0	0	0
21	6	10	0	0	0
22	5	11	0	0	0
23	5	9	0	0	0
24	5	10	0	0	0

自主規制値
法規制値

項 目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	----	----	----	----	----
2	----	----	----	----	----
3	----	----	----	----	----
4	----	----	----	----	----
5	----	----	----	----	----
6	----	----	----	----	----
7	----	----	----	----	----
8	----	----	----	----	----
9	----	----	----	----	----
10	----	----	----	----	----
11	----	----	----	----	----
12	----	----	----	----	----
13	----	----	----	----	----
14	----	----	----	----	----
15	----	----	----	----	----
16	----	----	----	----	----
17	----	----	----	----	----
18	----	----	----	----	----
19	----	----	----	----	----
20	----	----	----	----	----
21	----	----	----	----	----
22	----	----	----	----	----
23	----	----	----	----	----
24	----	----	----	----	----

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2020年11月15日 (日)

項 目 時 刻	1号炉				
	塩 化 水 素	窒 素 酸 化 物	硫 黄 酸 化 物	ば い じ ん	水 銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	4	12	1	0	0
2	4	8	0	0	0
3	5	9	0	0	0
4	5	9	0	0	0
5	5	10	0	0	0
6	5	13	1	0	0
7	5	10	0	0	0
8	6	9	0	0	0
9	6	10	2	0	0
10	5	12	1	0	0
11	6	8	0	0	0
12	6	9	0	0	0
13	6	12	1	0	0
14	6	10	1	0	0
15	6	8	0	0	0
16	6	10	0	0	0
17	6	10	0	0	0
18	6	11	0	0	0
19	5	10	0	0	0
20	6	11	0	0	0
21	6	11	0	0	0
22	6	10	0	0	0
23	6	10	0	0	0
24	6	9	0	0	0

自主規制値
法規制値

項 目 時 刻	2号炉				
	塩 化 水 素	窒 素 酸 化 物	硫 黄 酸 化 物	ば い じ ん	水 銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	----	----	----	----	----
2	----	----	----	----	----
3	----	----	----	----	----
4	----	----	----	----	----
5	----	----	----	----	----
6	----	----	----	----	----
7	----	----	----	----	----
8	----	----	----	----	----
9	----	----	----	----	----
10	----	----	----	----	----
11	----	----	----	----	----
12	----	----	----	----	----
13	----	----	----	----	----
14	----	----	----	----	----
15	----	----	----	----	----
16	----	----	----	----	----
17	----	----	----	----	----
18	----	----	----	----	----
19	----	----	----	----	----
20	----	----	----	----	----
21	----	----	----	----	----
22	----	----	----	----	----
23	----	----	----	----	----
24	----	----	----	----	----

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2020年11月16日 (月)

項 目 時 刻	1号炉				
	塩 化 水 素	窒 素 酸 化 物	硫 黄 酸 化 物	ば い じ ん	水 銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	11	0	0	0
2	6	11	0	0	0
3	6	10	0	0	0
4	6	10	0	0	0
5	6	11	0	0	0
6	6	10	0	0	0
7	6	8	0	0	0
8	6	12	1	0	0
9	6	11	2	0	0
10	6	9	0	0	0
11	6	9	0	0	0
12	6	11	2	0	0
13	6	10	1	0	0
14	6	10	0	0	0
15	6	10	0	0	0
16	6	10	1	0	0
17	6	10	0	0	0
18	6	10	0	0	0
19	6	9	0	0	0
20	6	12	1	0	0
21	6	9	0	0	0
22	6	8	0	0	0
23	6	10	1	0	0
24	6	13	1	0	0

自主規制値
法規制値

項 目 時 刻	2号炉				
	塩 化 水 素	窒 素 酸 化 物	硫 黄 酸 化 物	ば い じ ん	水 銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	----	----	----	----	----
2	----	----	----	----	----
3	----	----	----	----	----
4	----	----	----	----	----
5	----	----	----	----	----
6	----	----	----	----	----
7	----	----	----	----	----
8	----	----	----	----	----
9	----	----	----	----	----
10	----	----	----	----	----
11	----	----	----	----	----
12	----	----	----	----	----
13	----	----	----	----	----
14	----	----	----	----	----
15	----	----	----	----	----
16	----	----	----	----	----
17	----	----	----	----	----
18	----	----	----	----	----
19	----	----	----	----	----
20	----	----	----	----	----
21	----	----	----	----	----
22	----	----	----	----	----
23	----	----	----	----	----
24	----	----	----	----	----

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2020年11月17日 (火)

項 目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	9	0	0	0
2	6	10	0	0	0
3	6	10	0	0	0
4	6	9	0	0	0
5	6	11	0	0	0
6	6	11	1	0	0
7	6	8	0	0	0
8	6	9	0	0	0
9	6	10	0	0	0
10	6	9	0	0	0
11	6	10	0	0	0
12	6	11	0	0	0
13	6	11	0	0	0
14	6	9	0	0	0
15	6	10	0	0	0
16	6	9	0	0	0
17	6	10	1	0	0
18	6	13	2	0	0
19	6	10	0	0	0
20	6	8	0	0	0
21	6	10	0	0	0
22	6	12	2	0	0
23	6	9	0	0	0
24	6	10	0	0	0

自主規制値
法規制値

項 目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	----	----	----	----	----
2	----	----	----	----	----
3	----	----	----	----	----
4	----	----	----	----	----
5	----	----	----	----	----
6	----	----	----	----	----
7	----	----	----	----	----
8	----	----	----	----	----
9	----	----	----	----	----
10	----	----	----	----	----
11	----	----	----	----	----
12	----	----	----	----	----
13	----	----	----	----	----
14	----	----	----	----	----
15	----	----	----	----	----
16	----	----	----	----	----
17	----	----	----	----	----
18	----	----	----	----	----
19	----	----	----	----	----
20	----	----	----	----	----
21	----	----	----	----	----
22	----	----	----	----	----
23	----	----	----	----	----
24	----	----	----	----	----

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2020年11月18日 (水)

項 目 時 刻	1号炉				
	塩 化 水 素	窒 素 酸 化 物	硫 黄 酸 化 物	ば い じ ん	水 銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	12	1	0	0
2	5	10	0	0	0
3	5	10	0	0	0
4	4	10	0	0	0
5	4	12	0	0	0
6	4	10	0	0	0
7	4	11	0	0	0
8	4	10	0	0	0
9	4	10	0	0	0
10	4	11	0	0	0
11	4	11	0	0	0
12	5	11	0	0	0
13	4	9	0	0	0
14	5	10	0	0	0
15	5	11	0	0	0
16	6	8	0	0	0
17	5	10	0	0	0
18	5	10	0	0	0
19	5	13	0	0	0
20	5	10	0	0	0
21	6	10	0	0	0
22	6	11	0	0	0
23	6	10	0	0	0
24	6	11	0	0	0

自主規制値
法規制値

項 目 時 刻	2号炉				
	塩 化 水 素	窒 素 酸 化 物	硫 黄 酸 化 物	ば い じ ん	水 銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	----	----	----	----	----
2	----	----	----	----	----
3	----	----	----	----	----
4	----	----	----	----	----
5	----	----	----	----	----
6	----	----	----	----	----
7	----	----	----	----	----
8	----	----	----	----	----
9	----	----	----	----	----
10	----	----	----	----	----
11	----	----	----	----	----
12	----	----	----	----	----
13	----	----	----	----	----
14	----	----	----	----	----
15	----	----	----	----	----
16	----	----	----	----	----
17	----	----	----	----	----
18	----	----	----	----	----
19	----	----	----	----	----
20	----	----	----	----	----
21	----	----	----	----	----
22	----	----	----	----	----
23	----	----	----	----	----
24	----	----	----	----	----

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2020年11月19日 (木)

項 目 時 刻	1号炉				
	塩 化 水 素	窒 素 酸 化 物	硫 黄 酸 化 物	ば い じ ん	水 銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	9	0	0	0
2	6	9	0	0	0
3	6	10	0	0	0
4	6	10	0	0	0
5	6	11	0	0	0
6	6	9	0	0	0
7	6	11	0	0	0
8	6	10	0	0	0
9	6	9	0	0	0
10	6	9	0	0	0
11	6	12	0	0	0
12	6	10	0	0	0
13	6	11	0	0	0
14	6	10	0	0	0
15	6	10	0	0	0
16	6	10	0	0	0
17	6	11	0	0	0
18	6	10	0	0	0
19	4	9	0	0	0
20	3	8	0	0	0
21	5	14	0	0	0
22	5	11	0	0	0
23	6	11	0	0	0
24	6	9	0	0	0

自主規制値
法規制値

項 目 時 刻	2号炉				
	塩 化 水 素	窒 素 酸 化 物	硫 黄 酸 化 物	ば い じ ん	水 銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	----	----	----	----	----
2	----	----	----	----	----
3	----	----	----	----	----
4	----	----	----	----	----
5	----	----	----	----	----
6	----	----	----	----	----
7	----	----	----	----	----
8	----	----	----	----	----
9	----	----	----	----	----
10	----	----	----	----	----
11	----	----	----	----	----
12	----	----	----	----	----
13	----	----	----	----	----
14	----	----	----	----	----
15	----	----	----	----	----
16	----	----	----	----	----
17	----	----	----	----	----
18	----	----	----	----	----
19	----	----	----	----	----
20	----	----	----	----	----
21	----	----	----	----	----
22	----	----	----	----	----
23	----	----	----	----	----
24	----	----	----	----	----

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2020年11月20日（金）

項 目 時 刻	1号炉				
	塩 化 水 素	窒 素 酸 化 物	硫 黄 酸 化 物	ば い じ ん	水 銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	11	0	0	0
2	6	12	0	0	0
3	5	11	0	0	0
4	6	10	0	0	0
5	5	11	0	0	0
6	4	10	0	0	0
7	4	9	0	0	0
8	4	9	0	0	0
9	4	10	0	0	0
10	6	10	0	0	0
11	6	9	0	0	0
12	6	12	1	0	0
13	6	11	0	0	0
14	6	9	0	0	0
15	6	8	0	0	0
16	6	8	0	0	0
17	6	11	1	0	0
18	6	11	1	0	0
19	6	6	0	0	0
20	6	12	1	0	0
21	6	11	0	0	0
22	6	8	0	0	0
23	6	9	0	0	0
24	6	9	0	0	0

自主規制値
法規制値

項 目 時 刻	2号炉				
	塩 化 水 素	窒 素 酸 化 物	硫 黄 酸 化 物	ば い じ ん	水 銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	----	----	----	----	----
2	----	----	----	----	----
3	----	----	----	----	----
4	----	----	----	----	----
5	----	----	----	----	----
6	----	----	----	----	----
7	----	----	----	----	----
8	----	----	----	----	----
9	----	----	----	----	----
10	----	----	----	----	----
11	----	----	----	----	----
12	----	----	----	----	----
13	----	----	----	----	----
14	----	----	----	----	----
15	----	----	----	----	----
16	----	----	----	----	----
17	----	----	----	----	----
18	----	----	----	----	----
19	----	----	----	----	----
20	----	----	----	----	----
21	----	----	----	----	----
22	----	----	----	----	----
23	----	----	----	----	----
24	----	----	----	----	----

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2020年11月21日 (土)

項 目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	10	0	0	0
2	6	11	0	0	0
3	6	10	0	0	0
4	6	10	0	0	0
5	6	11	0	0	0
6	6	10	0	0	0
7	6	10	0	0	0
8	6	11	0	0	0
9	6	11	0	0	0
10	6	11	0	0	1
11	6	10	0	0	1
12	6	10	0	0	1
13	6	11	0	0	1
14	6	11	0	0	1
15	6	11	0	0	1
16	6	11	0	0	1
17	6	10	0	0	1
18	6	8	0	0	1
19	6	12	0	0	1
20	6	11	0	0	1
21	6	10	0	0	1
22	6	12	0	0	1
23	6	11	0	0	1
24	6	10	0	0	1

自主規制値
法規制値

項 目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	----	----	----	----	----
2	----	----	----	----	----
3	----	----	----	----	----
4	----	----	----	----	----
5	----	----	----	----	----
6	----	----	----	----	----
7	----	----	----	----	----
8	----	----	----	----	----
9	----	----	----	----	----
10	----	----	----	----	----
11	----	----	----	----	----
12	----	----	----	----	----
13	----	----	----	----	----
14	----	----	----	----	----
15	----	----	----	----	----
16	----	----	----	----	----
17	----	----	----	----	----
18	----	----	----	----	----
19	----	----	----	----	----
20	----	----	----	----	----
21	----	----	----	----	----
22	----	----	----	----	----
23	----	----	----	----	----
24	----	----	----	----	----

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2020年11月22日 (日)

項 目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	8	0	0	0
2	6	10	0	0	1
3	6	13	2	0	0
4	6	11	0	0	1
5	6	10	0	0	1
6	6	10	0	0	1
7	6	10	0	0	1
8	6	9	0	0	1
9	6	11	0	0	0
10	6	11	1	0	1
11	6	10	0	0	0
12	6	10	0	0	0
13	6	11	0	0	0
14	6	11	0	0	0
15	6	11	0	0	0
16	6	11	0	0	0
17	6	10	0	0	0
18	6	10	0	0	0
19	6	11	0	0	0
20	6	13	0	0	0
21	6	11	0	0	0
22	6	11	0	0	0
23	6	11	0	0	0
24	6	10	0	0	0

自主規制値
法規制値

項 目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	----	----	----	----	----
2	----	----	----	----	----
3	----	----	----	----	----
4	----	----	----	----	----
5	----	----	----	----	----
6	----	----	----	----	----
7	----	----	----	----	----
8	----	----	----	----	----
9	----	----	----	----	----
10	----	----	----	----	----
11	----	----	----	----	----
12	----	----	----	----	----
13	----	----	----	----	----
14	----	----	----	----	----
15	----	----	----	----	----
16	----	----	----	----	----
17	----	----	----	----	----
18	----	----	----	----	----
19	----	----	----	----	----
20	----	----	----	----	----
21	----	----	----	----	----
22	----	----	----	----	----
23	----	----	----	----	----
24	----	----	----	----	----

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2020年11月23日 (月)

項 目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	10	0	0	0
2	6	10	0	0	0
3	6	10	0	0	0
4	6	11	0	0	0
5	6	11	0	0	0
6	6	10	0	0	0
7	6	10	0	0	0
8	6	10	0	0	0
9	6	10	0	0	1
10	6	12	0	0	1
11	6	11	0	0	1
12	6	11	0	0	1
13	6	12	0	0	1
14	6	12	0	0	1
15	6	11	0	0	1
16	6	11	0	0	1
17	6	10	0	0	1
18	6	10	0	0	1
19	6	10	0	0	1
20	6	12	0	0	1
21	6	11	0	0	1
22	6	13	0	0	1
23	6	12	0	0	1
24	6	10	0	0	1

自主規制値
法規制値

項 目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	----	----	----	----	----
2	----	----	----	----	----
3	----	----	----	----	----
4	----	----	----	----	----
5	----	----	----	----	----
6	----	----	----	----	----
7	----	----	----	----	----
8	----	----	----	----	----
9	----	----	----	----	----
10	----	----	----	----	----
11	----	----	----	----	----
12	----	----	----	----	----
13	----	----	----	----	----
14	----	----	----	----	----
15	----	----	----	----	----
16	----	----	----	----	----
17	----	----	----	----	----
18	----	----	----	----	----
19	----	----	----	----	----
20	----	----	----	----	----
21	----	----	----	----	----
22	----	----	----	----	----
23	----	----	----	----	----
24	----	----	----	----	----

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2020年11月24日 (火)

項 目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	14	0	0	1
2	6	13	0	0	1
3	6	13	0	0	1
4	6	13	0	0	1
5	6	12	0	0	1
6	6	12	0	0	1
7	6	12	0	0	1
8	6	12	0	0	1
9	6	13	0	0	1
10	6	13	0	0	1
11	6	13	0	0	1
12	6	12	0	0	1
13	6	12	0	0	1
14	6	11	0	0	1
15	6	9	0	0	1
16	6	8	0	0	0
17	5	11	0	0	0
18	6	11	0	0	0
19	6	6	0	0	0
20	6	8	0	0	0
21	6	8	0	0	0
22	6	8	0	0	0
23	6	8	0	0	0
24	5	7	0	0	0

自主規制値
法規制値

項 目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	----	----	----	----	----
2	----	----	----	----	----
3	----	----	----	----	----
4	----	----	----	----	----
5	----	----	----	----	----
6	----	----	----	----	----
7	----	----	----	----	----
8	----	----	----	----	----
9	----	----	----	----	----
10	----	----	----	----	----
11	----	----	----	----	----
12	----	----	----	----	----
13	----	----	----	----	----
14	----	----	----	----	----
15	----	----	----	----	----
16	6	6	2	0	2
17	6	9	3	0	2
18	6	14	4	0	3
19	6	6	1	0	2
20	6	5	0	0	2
21	6	6	3	0	2
22	6	8	3	0	2
23	6	7	3	0	1
24	6	11	5	0	1

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2020年11月25日 (水)

項 目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	9	0	0	0
2	6	11	0	0	0
3	6	10	0	0	0
4	6	11	0	0	1
5	6	9	0	0	1
6	6	9	0	0	1
7	6	11	0	0	1
8	6	10	0	0	1
9	6	11	0	0	0
10	6	11	0	0	1
11	6	11	0	0	0
12	6	12	0	0	0
13	6	11	0	0	1
14	6	10	0	0	1
15	6	11	0	0	0
16	6	12	0	0	0
17	6	9	0	0	0
18	6	10	0	0	0
19	6	11	0	0	0
20	6	11	0	0	0
21	6	12	0	0	1
22	6	11	0	0	1
23	6	11	0	0	1
24	6	11	0	0	1

自主規制値
法規制値

項 目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	9	2	0	1
2	6	7	0	0	1
3	6	8	2	0	9
4	6	9	4	0	7
5	6	9	3	0	3
6	6	11	3	0	3
7	6	7	0	0	2
8	6	6	0	0	2
9	6	7	2	0	1
10	6	9	4	0	1
11	6	10	4	0	1
12	6	11	3	0	1
13	6	7	0	0	1
14	6	7	1	0	1
15	6	9	4	0	1
16	6	11	4	0	0
17	6	9	1	0	1
18	6	8	0	0	1
19	6	8	0	0	1
20	6	10	1	0	1
21	6	14	2	0	1
22	6	10	0	0	1
23	6	9	0	0	1
24	6	8	0	0	1

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2020年11月26日 (木)

項 目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	11	0	0	1
2	6	11	0	0	1
3	6	11	0	0	1
4	6	10	0	0	0
5	6	10	0	0	1
6	6	11	0	0	1
7	6	10	0	0	1
8	6	11	0	0	0
9	6	9	0	0	0
10	6	10	0	0	0
11	6	10	0	0	0
12	6	9	0	0	0
13	6	9	0	0	1
14	6	12	0	0	1
15	5	9	0	0	1
16	6	9	0	0	1
17	6	10	0	0	0
18	6	10	0	0	0
19	6	9	1	0	0
20	6	11	2	0	0
21	5	11	1	0	0
22	6	11	0	0	0
23	6	10	0	0	0
24	6	9	0	0	0

自主規制値
法規制値

項 目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	10	1	0	1
2	6	14	2	0	1
3	6	9	0	0	1
4	6	7	0	0	0
5	6	9	1	0	0
6	6	12	3	0	0
7	6	10	2	0	0
8	6	9	0	0	0
9	6	7	0	0	0
10	6	9	1	0	0
11	6	12	3	0	0
12	6	8	0	0	0
13	6	6	0	0	1
14	6	11	1	0	0
15	6	11	2	0	0
16	6	8	0	0	0
17	6	5	0	0	0
18	6	7	1	0	0
19	6	8	2	0	0
20	6	11	2	0	0
21	6	12	1	0	0
22	6	8	0	0	0
23	6	7	0	0	0
24	6	9	1	0	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2020年11月27日（金）

項 目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	11	0	0	0
2	6	14	0	0	0
3	6	10	0	0	0
4	6	11	0	0	0
5	6	10	0	0	0
6	6	10	0	0	0
7	6	10	0	0	0
8	6	9	0	0	0
9	6	10	0	0	0
10	6	11	0	0	0
11	6	9	0	0	0
12	6	11	0	0	0
13	6	12	0	0	1
14	6	11	0	0	0
15	6	10	0	0	1
16	6	11	0	0	0
17	6	11	0	0	1
18	6	10	0	0	0
19	6	11	0	0	0
20	6	11	0	0	0
21	6	11	0	0	0
22	6	11	0	0	0
23	6	10	0	0	0
24	6	10	0	0	0

自主規制値
法規制値

項 目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	12	2	0	1
2	6	9	0	0	0
3	6	6	0	0	0
4	6	7	0	0	0
5	6	12	1	0	0
6	6	10	1	0	0
7	6	10	0	0	0
8	6	10	0	0	0
9	6	6	0	0	0
10	6	7	0	0	0
11	6	9	0	0	0
12	6	10	2	0	0
13	6	11	1	0	0
14	6	5	0	0	1
15	6	6	3	0	1
16	6	7	0	0	1
17	6	8	0	0	0
18	6	9	0	0	1
19	6	9	0	0	0
20	6	11	2	0	0
21	6	10	1	0	0
22	6	8	0	0	0
23	6	8	1	0	0
24	6	11	2	0	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2020年11月28日 (土)

項 目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	11	0	0	0
2	6	12	0	0	0
3	6	10	0	0	0
4	6	10	0	0	0
5	6	10	0	0	0
6	5	10	0	0	1
7	5	10	0	0	1
8	6	10	0	0	1
9	6	10	0	0	1
10	5	11	0	0	1
11	6	12	1	0	1
12	6	10	0	0	1
13	6	11	0	0	1
14	6	10	0	0	1
15	6	9	0	0	1
16	6	12	0	0	1
17	6	10	0	0	1
18	6	9	0	0	1
19	6	11	0	0	1
20	6	10	0	0	1
21	6	8	0	0	1
22	6	9	0	0	1
23	6	9	0	0	1
24	6	11	0	0	1

自主規制値
法規制値

項 目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	10	2	0	1
2	6	8	0	0	1
3	6	9	0	0	1
4	6	11	4	0	1
5	6	9	2	0	0
6	6	8	0	0	0
7	6	10	2	0	0
8	6	13	2	0	1
9	6	9	0	0	1
10	6	8	0	0	0
11	6	10	1	0	0
12	6	11	2	0	1
13	6	8	0	0	1
14	6	10	0	0	1
15	6	13	2	0	1
16	6	9	1	0	1
17	6	11	0	0	1
18	6	10	1	0	0
19	6	8	0	0	1
20	6	7	0	0	0
21	6	9	0	0	1
22	6	10	2	0	0
23	6	8	1	0	1
24	6	6	0	0	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2020年11月29日 (日)

項 目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	8	0	0	1
2	6	8	0	0	1
3	5	11	0	0	1
4	5	10	0	0	1
5	6	8	0	0	1
6	6	9	0	0	1
7	6	12	1	0	1
8	5	8	1	0	1
9	5	9	0	0	1
10	6	9	0	0	1
11	6	8	0	0	1
12	6	8	0	0	1
13	6	8	0	0	1
14	5	8	0	0	1
15	6	9	0	0	1
16	6	12	0	0	1
17	6	11	1	0	1
18	5	9	0	0	1
19	6	10	0	0	1
20	6	11	1	0	1
21	6	10	0	0	1
22	6	10	0	0	1
23	6	10	0	0	1
24	6	12	1	0	1

自主規制値
法規制値

項 目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	8	2	0	0
2	6	10	3	0	0
3	6	7	0	0	1
4	6	11	0	0	1
5	6	9	1	0	0
6	6	6	0	0	1
7	6	8	0	0	0
8	6	6	0	0	1
9	6	7	0	0	1
10	6	9	1	0	0
11	6	13	2	0	0
12	6	8	0	0	0
13	6	7	0	0	0
14	6	6	0	0	0
15	6	8	0	0	0
16	6	10	0	0	0
17	6	11	1	0	0
18	6	8	0	0	0
19	6	7	0	0	0
20	6	9	3	0	0
21	6	11	3	0	0
22	6	10	2	0	0
23	6	7	0	0	0
24	6	9	1	0	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2020年11月30日 (月)

項 目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	10	1	0	1
2	6	9	0	0	1
3	6	10	0	0	1
4	6	11	0	0	1
5	6	10	0	0	1
6	6	10	0	0	1
7	6	10	0	0	1
8	6	8	0	0	1
9	6	10	0	0	1
10	6	13	1	0	1
11	6	9	0	0	1
12	6	11	0	0	1
13	6	11	0	0	1
14	6	11	0	0	1
15	6	11	0	0	1
16	6	10	0	0	1
17	6	10	0	0	1
18	6	10	0	0	1
19	6	9	0	0	1
20	6	11	0	0	1
21	6	10	0	0	1
22	6	10	0	0	1
23	6	10	0	0	1
24	6	10	0	0	1

自主規制値
法規制値

項 目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	12	4	0	0
2	6	8	1	0	0
3	6	11	1	0	0
4	6	13	2	0	0
5	6	9	0	0	0
6	6	8	0	0	0
7	6	9	2	0	0
8	6	12	4	0	0
9	6	10	1	0	0
10	6	8	0	0	0
11	6	7	0	0	0
12	6	9	2	0	0
13	6	12	2	0	0
14	6	13	1	0	0
15	6	6	0	0	0
16	6	6	0	0	0
17	6	9	0	0	0
18	6	10	1	0	0
19	6	5	0	0	0
20	6	6	1	0	0
21	6	13	3	0	0
22	6	12	1	0	0
23	6	8	0	0	0
24	6	10	0	0	0