

浅川清流環境組合可燃ごみ処理施設

**環境監視日報**

2022年3月1日 (火)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	4	10	1	0	0
2	4	12	1	0	0
3	4	11	1	0	0
4	5	13	1	0	0
5	4	12	1	0	0
6	5	11	1	0	0
7	5	11	1	0	0
8	5	11	1	0	0
9	5	10	1	0	0
10	5	13	1	0	0
11	6	11	1	0	0
12	4	11	1	0	0
13	6	11	1	0	0
14	6	10	1	0	0
15	6	11	1	0	0
16	6	11	1	0	0
17	6	12	1	0	0
18	6	12	1	0	0
19	6	9	1	0	0
20	5	12	1	0	0
21	5	13	1	0	0
22	4	13	0	0	0
23	4	11	1	0	0
24	4	12	1	0	0

自主規制値  
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	6	12	0	0	0
2	6	11	0	0	0
3	6	12	0	0	0
4	6	11	0	0	0
5	6	11	0	0	0
6	6	11	0	0	0
7	6	13	0	0	0
8	6	13	0	0	0
9	6	10	0	0	0
10	6	10	0	0	0
11	6	11	0	0	0
12	6	12	0	0	0
13	6	10	0	0	0
14	6	11	0	0	0
15	6	11	0	0	0
16	6	11	0	0	0
17	6	13	0	0	0
18	6	12	0	0	0
19	6	13	0	0	0
20	6	12	0	0	0
21	6	13	0	0	0
22	6	11	0	0	0
23	6	14	0	0	0
24	6	13	0	0	0

浅川清流環境組合可燃ごみ処理施設

**環境監視日報**

2022年3月2日 (水)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	5	10	1	0	0
2	5	11	1	0	0
3	4	12	0	0	0
4	4	12	1	0	0
5	4	12	1	0	0
6	5	11	1	0	0
7	4	11	1	0	0
8	4	13	1	0	0
9	3	11	1	0	0
10	4	13	1	0	0
11	3	14	1	0	0
12	4	13	1	0	0
13	5	14	1	0	0
14	4	12	1	0	0
15	4	12	1	0	0
16	5	12	1	0	0
17	4	13	1	0	0
18	5	12	1	0	0
19	5	11	0	0	0
20	5	13	1	0	0
21	5	12	1	0	0
22	4	13	1	0	0
23	4	12	0	0	0
24	4	13	1	0	0

自主規制値  
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	6	13	0	0	0
2	6	11	0	0	0
3	6	13	0	0	0
4	6	11	0	0	0
5	6	10	0	0	0
6	6	13	0	0	0
7	6	11	0	0	0
8	6	13	0	0	0
9	6	12	0	0	0
10	6	14	0	0	0
11	6	14	0	0	0
12	6	13	0	0	0
13	6	12	0	0	0
14	5	11	0	0	0
15	5	12	0	0	0
16	6	14	0	0	0
17	6	14	0	0	0
18	6	13	0	0	0
19	6	12	0	0	0
20	6	14	0	0	0
21	6	14	0	0	0
22	6	13	0	0	0
23	6	14	0	0	0
24	6	13	0	0	0

浅川清流環境組合可燃ごみ処理施設

**環境監視日報**

2022年3月3日 (木)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	4	13	1	0	0
2	4	12	1	0	0
3	5	13	1	0	0
4	3	12	1	0	0
5	3	12	1	0	0
6	4	12	1	0	0
7	3	14	1	0	0
8	3	13	1	0	0
9	3	13	1	0	0
10	4	13	1	0	0
11	4	11	1	0	0
12	3	12	1	0	0
13	4	13	1	0	0
14	4	12	1	0	0
15	4	12	1	0	0
16	4	12	1	0	0
17	4	14	1	0	0
18	4	13	1	0	0
19	4	15	1	0	0
20	4	12	1	0	0
21	4	11	1	0	0
22	4	13	1	0	0
23	4	14	1	0	0
24	5	13	1	0	0

自主規制値  
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	6	13	0	0	0
2	6	13	0	0	0
3	6	14	0	0	0
4	6	14	0	0	0
5	6	13	0	0	0
6	6	11	0	0	0
7	6	15	0	0	0
8	6	12	0	0	0
9	6	12	0	0	0
10	6	10	0	0	0
11	6	12	0	0	0
12	6	11	0	0	0
13	6	10	0	0	0
14	6	11	0	0	0
15	6	13	0	0	0
16	6	13	0	0	0
17	6	11	0	0	0
18	6	14	0	0	0
19	6	12	0	0	0
20	6	14	0	0	0
21	6	13	0	0	0
22	6	13	0	0	0
23	6	14	0	0	0
24	6	12	0	0	0

浅川清流環境組合可燃ごみ処理施設

**環境監視日報**

2022年3月4日 (金)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	5	11	1	0	0
2	5	13	1	0	0
3	5	13	1	0	0
4	6	13	1	0	0
5	5	13	1	0	0
6	5	13	1	0	0
7	5	12	1	0	0
8	5	13	1	0	0
9	4	14	1	0	0
10	4	14	0	0	0
11	4	13	1	0	0
12	5	12	1	0	0
13	5	11	1	0	0
14	4	12	1	0	0
15	4	13	1	0	0
16	4	12	1	0	0
17	3	11	1	0	0
18	3	13	1	0	0
19	3	12	1	0	0
20	3	13	1	0	0
21	3	15	1	0	0
22	4	13	1	0	0
23	4	14	1	0	0
24	4	12	1	0	0

自主規制値  
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	6	11	0	0	0
2	6	12	0	0	0
3	6	13	0	0	0
4	6	10	0	0	0
5	6	13	0	0	0
6	6	14	0	0	2
7	6	12	0	0	1
8	6	13	0	0	0
9	6	14	0	0	0
10	6	13	0	0	0
11	6	14	0	0	0
12	6	13	0	0	0
13	6	12	0	0	0
14	6	12	0	0	0
15	6	10	0	0	0
16	5	11	0	0	0
17	6	12	0	0	0
18	5	11	0	0	0
19	6	13	0	0	0
20	6	14	0	0	0
21	6	14	0	0	0
22	6	15	0	0	0
23	6	13	0	0	0
24	6	13	0	0	0

浅川清流環境組合可燃ごみ処理施設

**環境監視日報**

2022年3月5日 (土)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	5	13	1	0	0
2	4	14	1	0	0
3	4	12	1	0	0
4	4	13	1	0	0
5	4	13	1	0	0
6	4	11	1	0	0
7	3	14	1	0	0
8	4	11	1	0	0
9	4	15	1	0	0
10	5	14	1	0	0
11	5	14	0	0	0
12	4	13	1	0	0
13	5	12	1	0	0
14	5	13	1	0	0
15	5	11	1	0	0
16	6	13	1	0	0
17	5	13	1	0	0
18	4	13	1	0	0
19	5	13	1	0	0
20	5	13	1	0	0
21	4	12	1	0	0
22	3	14	1	0	0
23	4	13	1	0	0
24	3	13	1	0	0

自主規制値  
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	6	13	0	0	0
2	6	15	0	0	0
3	6	13	0	0	0
4	6	14	0	0	0
5	6	13	0	0	0
6	6	15	0	0	0
7	6	13	0	0	0
8	6	13	0	0	0
9	6	14	0	0	0
10	6	13	0	0	0
11	6	14	0	0	0
12	5	13	0	0	0
13	5	13	0	0	0
14	6	12	0	0	0
15	6	15	0	0	0
16	5	12	0	0	0
17	6	12	0	0	0
18	6	15	0	0	0
19	6	12	0	0	0
20	5	13	0	0	0
21	4	13	0	0	0
22	5	12	0	0	0
23	6	12	0	0	0
24	6	13	0	0	0

浅川清流環境組合可燃ごみ処理施設

**環境監視日報**

2022年3月6日 (日)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	3	11	1	0	0
2	3	12	1	0	0
3	3	13	1	0	0
4	3	13	1	0	0
5	3	11	1	0	0
6	4	13	0	0	0
7	3	12	1	0	0
8	4	11	1	0	0
9	4	11	1	0	0
10	4	10	1	0	0
11	4	13	1	0	0
12	4	12	1	0	0
13	5	13	1	0	0
14	4	11	1	0	0
15	5	13	1	0	0
16	4	12	1	0	0
17	4	14	1	0	0
18	4	13	1	0	0
19	4	14	0	0	0
20	4	13	1	0	0
21	4	12	1	0	0
22	4	10	1	0	0
23	4	11	1	0	0
24	4	12	1	0	0

自主規制値  
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	5	12	0	0	0
2	6	12	0	0	0
3	6	16	0	0	0
4	6	11	0	0	0
5	6	15	0	0	0
6	6	13	0	0	0
7	6	13	0	0	0
8	6	13	0	0	0
9	6	13	0	0	0
10	6	14	0	0	0
11	6	13	0	0	0
12	6	12	0	0	0
13	6	12	0	0	0
14	6	10	0	0	0
15	6	14	0	0	0
16	6	14	0	0	0
17	6	12	0	0	0
18	6	13	0	0	0
19	6	14	0	0	0
20	6	12	0	0	0
21	6	14	0	0	0
22	6	11	0	0	0
23	6	14	0	0	0
24	6	11	0	0	0

浅川清流環境組合可燃ごみ処理施設

**環境監視日報**

2022年3月7日 (月)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
10	20	10	0.005	50	
430	250	約2700	0.040	50	
1	3	13	0	0	0
2	3	11	1	0	0
3	3	11	0	0	0
4	3	12	1	0	0
5	2	11	1	0	0
6	2	12	1	0	0
7	2	12	1	0	0
8	3	11	1	0	0
9	3	13	1	0	1
10	3	13	1	0	0
11	3	11	1	0	0
12	5	12	1	0	0
13	6	14	0	0	0
14	6	12	1	0	0
15	6	12	1	0	0
16	6	12	1	0	0
17	6	13	1	0	0
18	6	11	1	0	0
19	6	11	1	0	0
20	6	13	1	0	0
21	6	12	1	0	0
22	6	12	1	0	0
23	6	13	1	0	0
24	6	14	1	0	0

自主規制値  
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
10	20	10	0.005	50	
430	250	約2700	0.040	50	
1	6	12	0	0	0
2	6	14	0	0	0
3	6	13	0	0	0
4	5	12	0	0	0
5	5	11	0	0	0
6	5	12	0	0	0
7	6	13	0	0	0
8	6	14	0	0	0
9	6	13	0	0	0
10	6	14	0	0	0
11	6	13	0	0	0
12	6	14	0	0	0
13	6	12	0	0	0
14	6	13	0	0	0
15	6	13	0	0	0
16	6	11	0	0	0
17	6	14	0	0	0
18	6	11	0	0	0
19	6	13	0	0	0
20	6	----※	----※	0	0
21	6	12	0	0	0
22	6	13	0	0	0
23	6	13	0	0	0
24	6	13	0	0	0

※測定器の整備のため---表示しています。

浅川清流環境組合可燃ごみ処理施設

**環境監視日報**

2022年3月8日 (火)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	5	13	1	0	0
2	4	11	1	0	0
3	5	14	1	0	0
4	5	13	1	0	0
5	4	12	1	0	0
6	6	12	1	0	0
7	6	12	1	0	0
8	6	14	1	0	0
9	6	12	1	0	0
10	6	12	1	0	0
11	6	14	1	0	0
12	6	13	1	0	0
13	6	12	1	0	0
14	6	11	1	0	0
15	6	12	1	0	0
16	6	11	1	0	0
17	6	12	1	0	0
18	6	14	1	0	0
19	6	14	1	0	0
20	6	15	1	0	0
21	6	12	1	0	0
22	6	13	1	0	0
23	6	11	1	0	0
24	6	13	1	0	0

自主規制値  
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	6	11	0	0	0
2	6	12	0	0	0
3	6	13	0	0	0
4	6	12	0	0	0
5	6	14	0	0	0
6	6	14	0	0	0
7	6	13	0	0	0
8	6	14	0	0	0
9	6	12	0	0	0
10	6	14	0	0	0
11	6	13	0	0	0
12	6	14	0	0	0
13	6	13	0	0	0
14	6	14	0	0	0
15	6	13	0	0	0
16	6	15	0	0	0
17	6	14	0	0	0
18	6	14	0	0	0
19	6	12	0	0	0
20	6	15	0	0	0
21	6	12	0	0	0
22	6	14	0	0	0
23	6	14	0	0	0
24	6	15	0	0	0

浅川清流環境組合可燃ごみ処理施設

**環境監視日報**

2022年3月9日 (水)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	6	13	1	0	0
2	6	12	1	0	0
3	6	14	1	0	0
4	5	11	0	0	0
5	5	11	1	0	0
6	6	12	1	0	0
7	6	11	1	0	0
8	6	12	1	0	0
9	6	12	1	0	0
10	6	12	1	0	0
11	6	12	1	0	0
12	6	13	1	0	0
13	6	13	1	0	0
14	6	12	1	0	0
15	6	11	1	0	0
16	6	12	1	0	0
17	5	12	1	0	0
18	5	12	1	0	0
19	6	13	1	0	0
20	6	11	1	0	0
21	6	12	1	0	0
22	6	11	1	0	0
23	5	11	1	0	0
24	6	12	1	0	0

自主規制値  
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	6	11	0	0	0
2	6	15	0	0	0
3	6	13	0	0	0
4	6	16	0	0	0
5	6	11	0	0	0
6	6	15	0	0	0
7	6	11	0	0	0
8	6	12	0	0	0
9	6	15	0	0	0
10	6	12	0	0	0
11	6	14	0	0	0
12	6	13	0	0	0
13	6	10	0	0	0
14	6	11	0	0	0
15	6	13	0	0	0
16	6	13	0	0	0
17	6	13	0	0	0
18	6	11	0	0	0
19	6	13	0	0	0
20	6	12	0	0	0
21	6	12	0	0	0
22	6	14	0	0	0
23	6	15	0	0	0
24	6	11	0	0	0

浅川清流環境組合可燃ごみ処理施設

**環境監視日報**

2022年3月10日 (木)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	6	12	1	0	0
2	6	11	1	0	0
3	6	12	1	0	0
4	6	13	1	0	0
5	6	12	1	0	0
6	6	14	1	0	0
7	6	14	1	0	0
8	6	13	1	0	0
9	6	12	1	0	0
10	6	12	0	0	0
11	6	12	0	0	0
12	5	14	1	0	0
13	5	13	1	0	0
14	6	14	1	0	0
15	6	14	1	0	0
16	6	12	1	0	0
17	6	14	1	0	0
18	6	13	1	0	0
19	6	13	1	0	0
20	6	14	1	0	0
21	6	13	0	0	0
22	6	13	1	0	0
23	6	12	1	0	0
24	6	14	1	0	0

自主規制値  
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	6	15	0	0	0
2	6	12	0	0	0
3	6	13	0	0	0
4	6	12	0	0	0
5	6	15	0	0	0
6	6	12	0	0	0
7	6	15	0	0	0
8	6	14	0	0	0
9	6	13	0	0	0
10	6	13	0	0	0
11	6	14	0	0	0
12	5	14	0	0	0
13	5	14	0	0	0
14	6	13	0	0	0
15	6	11	0	0	0
16	6	11	0	0	0
17	6	14	0	0	0
18	6	13	0	0	0
19	6	13	0	0	0
20	6	14	0	0	0
21	6	13	0	0	0
22	6	11	0	0	0
23	6	13	0	0	0
24	6	15	0	0	0

浅川清流環境組合可燃ごみ処理施設

**環境監視日報**

2022年3月11日 (金)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	6	12	1	0	0
2	6	14	1	0	0
3	6	12	1	0	0
4	6	13	1	0	0
5	6	12	1	0	0
6	6	11	1	0	0
7	6	13	1	0	0
8	6	12	1	0	0
9	6	13	1	0	0
10	6	13	1	0	0
11	6	13	1	0	0
12	6	13	0	0	0
13	6	12	1	0	0
14	6	14	1	0	0
15	6	13	1	0	0
16	6	12	0	0	0
17	6	12	1	0	0
18	6	12	1	0	0
19	6	12	1	0	0
20	6	14	1	0	0
21	6	13	0	0	0
22	6	13	1	0	0
23	6	14	1	0	0
24	6	14	0	0	0

自主規制値  
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	6	12	0	0	0
2	6	13	0	0	0
3	6	13	0	0	0
4	6	13	0	0	0
5	6	13	0	0	0
6	6	13	0	0	0
7	6	14	0	0	0
8	6	14	0	0	0
9	6	13	0	0	0
10	6	14	0	0	0
11	6	12	0	0	0
12	6	12	0	0	0
13	6	12	0	0	0
14	6	11	0	0	0
15	6	14	0	0	0
16	6	13	0	0	0
17	6	13	0	0	0
18	6	14	0	0	0
19	6	14	0	0	0
20	6	12	0	0	0
21	6	12	0	0	0
22	6	15	0	0	0
23	6	14	0	0	0
24	6	15	0	0	0

## 浅川清流環境組合可燃ごみ処理施設

## 環境監視日報

2022年3月12日 (土)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	6	14	1	0	0
2	6	13	1	0	0
3	6	13	1	0	0
4	6	12	1	0	0
5	6	14	1	0	0
6	6	11	1	0	0
7	6	15	0	0	0
8	6	12	0	0	0
9	6	14	1	0	0
10	6	13	1	0	0
11	6	14	1	0	0
12	6	12	1	0	0
13	6	11	1	0	0
14	6	13	1	0	0
15	6	11	1	0	0
16	6	11	1	0	0
17	6	12	1	0	0
18	6	13	1	0	0
19	6	13	1	0	0
20	6	12	1	0	0
21	6	13	1	0	0
22	6	12	1	0	0
23	6	13	1	0	0
24	6	12	1	0	0

自主規制値  
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	6	12	0	0	0
2	6	15	0	0	0
3	6	14	0	0	0
4	6	14	0	0	0
5	6	14	0	0	0
6	6	14	0	0	0
7	6	13	0	0	0
8	6	15	0	0	0
9	6	12	0	0	0
10	6	----※	----※	0	0
11	6	14	0	0	0
12	6	12	0	0	0
13	6	14	0	0	0
14	6	14	0	0	0
15	6	12	0	0	0
16	6	14	0	0	0
17	6	12	0	0	0
18	6	13	0	0	0
19	6	15	0	0	0
20	6	11	0	0	0
21	6	14	0	0	0
22	6	13	0	0	0
23	6	13	0	0	0
24	6	13	0	0	0

※メーカーによる測定器の整備のため---表示しています。

浅川清流環境組合可燃ごみ処理施設

**環境監視日報**

2022年3月13日 (日)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	6	11	1	0	0
2	6	13	1	0	0
3	6	13	1	0	0
4	6	13	1	0	0
5	6	13	1	0	0
6	6	12	1	0	0
7	6	14	1	0	0
8	6	13	1	0	0
9	6	11	1	0	0
10	6	11	1	0	0
11	6	13	1	0	0
12	6	12	1	0	0
13	6	11	1	0	0
14	6	11	1	0	0
15	6	12	1	0	0
16	6	12	1	0	0
17	6	12	1	0	0
18	6	11	1	0	0
19	6	12	1	0	0
20	6	14	1	0	0
21	6	12	1	0	0
22	5	13	1	0	0
23	5	12	1	0	0
24	6	12	1	0	0

自主規制値  
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	6	13	0	0	0
2	6	11	0	0	0
3	6	14	0	0	0
4	6	12	0	0	0
5	6	12	0	0	0
6	6	15	0	0	0
7	6	13	0	0	0
8	6	14	0	0	0
9	6	12	0	0	0
10	6	14	0	0	0
11	6	13	0	0	0
12	6	14	0	0	0
13	6	13	0	0	0
14	6	13	0	0	0
15	6	12	0	0	0
16	6	11	0	0	0
17	6	12	0	0	0
18	6	14	0	0	0
19	6	14	0	0	0
20	6	13	0	0	0
21	6	15	0	0	0
22	5	13	0	0	0
23	6	14	0	0	0
24	6	14	0	0	0

浅川清流環境組合可燃ごみ処理施設

**環境監視日報**

2022年3月14日 (月)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	6	12	1	0	0
2	6	11	1	0	0
3	6	10	1	0	0
4	6	11	1	0	0
5	6	11	1	0	0
6	6	13	1	0	0
7	5	11	1	0	0
8	6	11	1	0	0
9	6	12	1	0	0
10	6	12	1	0	0
11	6	12	1	0	0
12	6	12	1	0	0
13	6	11	1	0	0
14	6	12	1	0	0
15	6	13	1	0	0
16	6	13	1	0	0
17	6	13	1	0	0
18	6	11	1	0	0
19	6	12	1	0	0
20	6	11	1	0	0
21	6	13	1	0	0
22	6	11	1	0	0
23	6	11	0	0	0
24	6	12	1	0	0

自主規制値  
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	6	14	0	0	0
2	6	14	0	0	0
3	6	13	0	0	0
4	6	14	0	0	0
5	6	13	0	0	0
6	6	13	0	0	0
7	6	13	0	0	0
8	6	11	0	0	0
9	6	12	0	0	0
10	6	14	0	0	0
11	6	14	0	0	0
12	6	12	0	0	0
13	6	12	0	0	0
14	6	14	0	0	0
15	6	14	0	0	0
16	6	15	0	0	0
17	6	12	0	0	0
18	6	14	0	0	0
19	6	11	0	0	0
20	6	14	0	0	0
21	6	11	0	0	0
22	6	12	0	0	0
23	6	12	0	0	0
24	6	13	0	0	0

浅川清流環境組合可燃ごみ処理施設

**環境監視日報**

2022年3月15日 (火)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	6	12	1	0	0
2	6	11	1	0	0
3	6	12	1	0	0
4	6	11	1	0	0
5	6	11	1	0	0
6	6	12	1	0	0
7	6	13	1	0	0
8	6	14	1	0	0
9	6	14	1	0	0
10	6	14	1	0	0
11	6	12	1	0	0
12	6	15	0	0	0
13	6	11	1	0	0
14	6	13	1	0	0
15	6	14	1	0	0
16	6	14	1	0	0
17	6	13	1	0	0
18	6	14	1	0	0
19	6	12	1	0	0
20	6	11	1	0	0
21	6	11	1	0	0
22	6	14	1	0	0
23	6	11	1	0	0
24	6	12	1	0	0

自主規制値  
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	6	14	0	0	0
2	6	14	0	0	0
3	6	14	0	0	0
4	6	13	0	0	0
5	6	13	0	0	0
6	6	14	0	0	0
7	6	14	0	0	0
8	6	15	0	0	0
9	6	15	0	0	0
10	6	13	0	0	0
11	6	13	0	0	0
12	6	15	0	0	0
13	6	14	0	0	0
14	6	13	0	0	0
15	6	15	0	0	0
16	6	13	0	0	0
17	6	13	0	0	0
18	6	15	0	0	0
19	6	13	0	0	0
20	6	14	0	0	0
21	6	13	0	0	0
22	6	13	0	0	0
23	6	13	0	0	0
24	6	14	0	0	0

浅川清流環境組合可燃ごみ処理施設

**環境監視日報**

2022年3月16日 (水)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	6	13	0	0	0
2	6	11	0	0	0
3	6	11	1	0	0
4	6	12	1	0	0
5	6	13	0	0	0
6	6	12	1	0	0
7	6	14	1	0	0
8	6	13	1	0	0
9	6	11	1	0	0
10	6	12	1	0	0
11	6	12	1	0	0
12	6	13	0	0	0
13	6	13	1	0	0
14	5	12	1	0	0
15	5	12	1	0	0
16	6	15	1	0	0※
17	6	11	1	0	0※
18	5	13	1	0	0※
19	6	13	1	0	0※
20	6	12	1	0	0※
21	5	12	1	0	0※
22	6	14	1	0	0※
23	6	13	1	0	0※
24	6	11	1	0	0※

※この期間、公害防止表示盤メンテナンスのため、“調整中”的表示。

自主規制値  
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	6	14	0	0	0
2	6	14	0	0	0
3	6	14	0	0	0
4	6	12	0	0	0
5	6	14	0	0	0
6	6	13	0	0	0
7	6	13	0	0	0
8	6	13	0	0	0
9	6	14	0	0	0
10	6	12	0	0	0
11	6	15	0	0	0
12	6	10	0	0	0
13	6	13	0	0	0
14	6	13	0	0	0
15	6	12	0	0	0
16	6	15	0	0	0
17	6	14	0	0	0
18	6	12	0	0	0
19	6	14	0	0	0
20	6	14	0	0	0
21	6	14	0	0	0
22	6	16	0	0	0
23	6	13	0	0	0
24	6	14	0	0	0

浅川清流環境組合可燃ごみ処理施設

**環境監視日報**

2022年3月17日 (木)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	5	12	1	0	0 ※
2	6	13	1	0	0 ※
3	5	9	1	0	0 ※
4	4	7	1	0	0 ※
5	3	5	1	0	0 ※
6	3	8	1	0	0 ※
7	5	12	1	0	0 ※
8	6	10	1	0	0 ※
9	6	14	1	0	0
10	6	12	1	0	0
11	6	14	1	0	0
12	6	13	1	0	0
13	6	12	1	0	0
14	6	13	1	0	0
15	6	13	1	0	0
16	6	13	1	0	0
17	6	13	1	0	0
18	6	13	1	0	0
19	6	11	1	0	0
20	6	11	1	0	0
21	6	12	1	0	0
22	6	13	1	0	0
23	6	12	1	0	0
24	6	11	1	0	0

※この期間、公害防止表示盤メンテナンスのため、“調整中”的表示。

自主規制値  
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	6	14	0	0	0
2	6	13	0	0	0
3	6	8	0	0	0
4	6	6	0	0	0
5	5	6	0	0	0
6	6	10	0	0	0
7	6	15	0	0	0
8	6	13	0	0	0
9	6	16	0	0	0
10	6	12	0	0	0
11	6	11	0	0	0
12	6	16	0	0	0
13	6	11	0	0	0
14	6	13	0	0	0
15	6	12	0	0	0
16	6	11	0	0	0
17	6	14	0	0	0
18	6	16	0	0	0
19	6	11	0	0	0
20	6	14	0	0	0
21	6	14	0	0	0
22	6	14	0	0	0
23	6	13	0	0	0
24	6	15	0	0	0

浅川清流環境組合可燃ごみ処理施設

**環境監視日報**

2022年3月18日 (金)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	13	1	0	0
2	6	13	1	0	0
3	6	13	1	0	0
4	6	13	0	0	0
5	6	11	1	0	0
6	6	13	1	0	0
7	6	13	1	0	0
8	6	13	1	0	0
9	5	11	1	0	0
10	4	11	1	0	0
11	4	12	1	0	0
12	5	13	1	0	0
13	5	12	1	0	0
14	5	12	1	0	0
15	4	11	1	0	0
16	4	11	1	0	0
17	4	11	1	0	0
18	4	13	1	0	0
19	5	13	1	0	0
20	6	12	0	0	0
21	6	12	1	0	0
22	5	11	1	0	0
23	5	13	0	0	0
24	5	13	1	0	0

自主規制値  
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	13	0	0	0
2	6	13	0	0	0
3	6	14	0	0	0
4	6	13	0	0	0
5	6	13	0	0	0
6	6	14	0	0	0
7	6	14	0	0	0
8	6	12	0	0	0
9	6	15	0	0	0
10	6	10	0	0	0
11	6	12	0	0	0
12	6	15	0	0	0
13	6	13	0	0	0
14	6	12	0	0	0
15	6	14	0	0	0
16	6	12	0	0	0
17	6	13	0	0	0
18	6	14	0	0	0
19	6	11	0	0	0
20	6	12	0	0	0
21	6	13	0	0	0
22	6	13	0	0	0
23	6	14	0	0	0
24	6	12	0	0	0

浅川清流環境組合可燃ごみ処理施設

**環境監視日報**

2022年3月19日 (土)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	5	12	0	0	0
2	4	12	0	0	0
3	5	13	1	0	0
4	4	11	1	0	0
5	4	12	1	0	0
6	4	14	0	0	0
7	4	13	0	0	0
8	4	12	0	0	0
9	4	12	0	0	0
10	5	14	0	0	0
11	5	13	0	0	0
12	5	13	1	0	0
13	4	13	0	0	0
14	5	14	0	0	0
15	5	13	0	0	0
16	4	12	0	0	0
17	5	12	0	0	0
18	5	14	0	0	0
19	5	13	1	0	0
20	5	12	1	0	0
21	5	13	0	0	0
22	5	12	0	0	0
23	6	13	1	0	0
24	5	13	0	0	0

自主規制値  
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	6	13	0	0	0
2	6	14	0	0	0
3	6	13	0	0	0
4	6	14	0	0	0
5	6	14	0	0	0
6	6	14	0	0	0
7	6	15	0	0	0
8	6	12	0	0	0
9	6	15	0	0	0
10	6	13	0	0	0
11	6	15	0	0	0
12	5	13	0	0	0
13	5	14	0	0	0
14	6	14	0	0	0
15	6	13	0	0	0
16	5	14	0	0	0
17	6	14	0	0	0
18	6	14	0	0	0
19	6	14	0	0	0
20	6	12	0	0	0
21	6	14	0	0	0
22	6	13	0	0	0
23	6	12	0	0	0
24	6	13	0	0	0

浅川清流環境組合可燃ごみ処理施設

**環境監視日報**

2022年3月20日 (日)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	5	11	1	0	0
2	4	10	0	0	0
3	4	12	1	0	0
4	4	12	1	0	0
5	4	12	1	0	0
6	4	12	1	0	0
7	4	12	1	0	0
8	4	12	1	0	0
9	3	12	1	0	0
10	4	12	1	0	0
11	3	13	1	0	0
12	3	12	1	0	0
13	3	12	1	0	0
14	3	12	0	0	0
15	3	12	0	0	0
16	3	11	0	0	0
17	3	12	0	0	0
18	3	11	1	0	0
19	3	11	1	0	0
20	3	14	1	0	0
21	3	13	1	0	0
22	3	12	1	0	0
23	3	13	0	0	0
24	3	13	1	0	0

自主規制値  
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	6	12	0	0	0
2	6	12	0	0	0
3	6	14	0	0	0
4	6	14	0	0	0
5	6	15	0	0	0
6	6	12	0	0	0
7	5	13	0	0	0
8	6	14	0	0	0
9	6	14	0	0	0
10	6	15	0	0	0
11	6	14	0	0	0
12	6	12	0	0	0
13	6	14	0	0	0
14	6	13	0	0	0
15	6	13	0	0	0
16	4	13	0	0	0
17	5	14	0	0	0
18	5	14	0	0	0
19	6	14	0	0	0
20	5	14	0	0	0
21	5	14	0	0	0
22	4	15	0	0	0
23	5	12	0	0	0
24	5	15	0	0	0

浅川清流環境組合可燃ごみ処理施設

**環境監視日報**

2022年3月21日 (月)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	3	13	1	0	0
2	3	11	1	0	0
3	3	13	1	0	0
4	3	12	1	0	0
5	3	13	0	0	0
6	3	12	1	0	0
7	3	10	1	0	0
8	3	10	1	0	0
9	3	12	1	0	0
10	2	12	1	0	0
11	3	13	1	0	0
12	3	12	1	0	0
13	3	12	1	0	0
14	3	13	1	0	0
15	3	12	1	0	0
16	3	11	1	0	0
17	3	12	1	0	0
18	3	12	1	0	0
19	3	11	0	0	0
20	3	14	0	0	0
21	3	11	0	0	0
22	3	13	1	0	0
23	3	13	1	0	0
24	3	12	0	0	0

自主規制値  
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	5	12	0	0	0
2	4	14	0	0	0
3	6	13	0	0	0
4	4	16	0	0	0
5	4	13	0	0	0
6	4	13	0	0	0
7	4	13	0	0	0
8	3	16	0	0	0
9	3	12	0	0	0
10	4	15	0	0	0
11	4	11	0	0	0
12	4	14	0	0	0
13	4	14	0	0	0
14	4	14	0	0	0
15	6	13	0	0	0
16	6	12	0	0	0
17	5	14	0	0	0
18	5	14	0	0	0
19	5	13	0	0	0
20	5	14	0	0	0
21	5	14	0	0	0
22	6	12	0	0	0
23	6	14	0	0	0
24	6	14	0	0	0

浅川清流環境組合可燃ごみ処理施設

**環境監視日報**

2022年3月22日 (火)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	3	11	1	0	0
2	3	14	1	0	0
3	3	12	0	0	0
4	3	13	1	0	0
5	3	12	1	0	0
6	3	12	0	0	0
7	3	11	1	0	0
8	3	11	1	0	0
9	3	11	1	0	0
10	4	12	1	0	0
11	4	12	1	0	0
12	3	12	1	0	0
13	4	12	1	0	0
14	4	12	1	0	0
15	4	13	1	0	0
16	5	12	1	0	0
17	5	14	1	0	0
18	5	12	1	0	0
19	5	14	1	0	0
20	4	12	1	0	0
21	5	12	0	0	0
22	4	12	1	0	0
23	4	11	1	0	0
24	5	11	1	0	0

自主規制値  
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	6	14	0	0	0
2	6	14	0	0	0
3	5	15	0	0	0
4	5	14	0	0	0
5	5	12	0	0	0
6	5	12	0	0	0
7	6	14	0	0	0
8	5	12	0	0	0
9	6	12	0	0	0
10	6	13	0	0	0
11	6	13	0	0	0
12	6	13	0	0	0
13	6	12	0	0	0
14	6	13	0	0	0
15	6	13	0	0	0
16	6	13	0	0	0
17	6	12	0	0	0
18	6	15	0	0	0
19	6	13	0	0	0
20	6	15	0	0	0
21	6	12	0	0	0
22	6	14	0	0	0
23	6	14	0	0	0
24	6	11	0	0	0

浅川清流環境組合可燃ごみ処理施設

**環境監視日報**

2022年3月23日 (水)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
10	20	10	0.005	50	
430	250	約2700	0.040	50	
1	5	12	1	0	0
2	5	12	1	0	0
3	5	13	1	0	0
4	5	12	1	0	0
5	5	12	1	0	0
6	4	13	1	0	0
7	4	12	1	0	0
8	4	12	1	0	0
9	4	12	1	0	0
10	4	14	1	0	0
11	4	12	1	0	0
12	5	11	1	0	0
13	5	13	0	0	0
14	6	13	0	0	0
15	6	13	0	0	0
16	6	13	0	0	0
17	6	12	0	0	0
18	6	13	0	0	0
19	6	12	0	0	0
20	6	12	0	0	0
21	6	11	0	0	0
22	6	11	0	0	0
23	6	12	0	0	0
24	6	12	1	0	0

自主規制値  
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
10	20	10	0.005	50	
430	250	約2700	0.040	50	
1	6	14	0	0	0
2	6	13	0	0	0
3	6	13	0	0	0
4	6	13	0	0	0
5	6	14	0	0	0
6	6	12	1	0	0
7	6	16	0	0	0
8	6	12	1	0	0
9	6	14	0	0	0
10	6	14	0	0	0
11	6	10	0	0	0
12	6	13	0	0	0
13	6	14	0	0	0
14	6	14	0	0	0
15	6	14	0	0	0
16	6	13	0	0	0
17	6	14	0	0	0
18	6	12	0	0	0
19	6	14	0	0	0
20	6	14	0	0	0
21	6	14	0	0	0
22	6	11	0	0	0
23	6	15	0	0	0
24	6	11	0	0	0

浅川清流環境組合可燃ごみ処理施設

**環境監視日報**

2022年3月24日 (木)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	6	12	0	0	0
2	6	14	0	0	0
3	6	12	0	0	0
4	6	12	0	0	0
5	6	13	0	0	0
6	6	12	1	0	0
7	6	11	1	0	0
8	6	13	0	0	0
9	6	13	0	0	0
10	6	11	0	0	0
11	6	12	0	0	0
12	6	13	0	0	0
13	6	12	0	0	0
14	6	11	0	0	0
15	6	11	0	0	0
16	6	12	0	0	0
17	6	12	0	0	0
18	6	12	0	0	0
19	6	10	0	0	0
20	6	12	0	0	0
21	6	13	0	0	0
22	6	14	0	0	0
23	6	12	0	0	0
24	6	12	0	0	0

自主規制値  
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	6	15	0	0	0
2	6	12	0	0	0
3	6	14	0	0	0
4	6	13	0	0	0
5	6	14	0	0	0
6	6	11	0	0	0
7	6	14	0	0	0
8	6	13	0	0	0
9	6	15	0	0	0
10	6	11	0	0	0
11	6	15	0	0	0
12	6	13	0	0	0
13	6	11	0	0	0
14	6	16	0	0	0
15	6	13	0	0	0
16	6	13	0	0	0
17	6	15	0	0	0
18	6	13	0	0	0
19	6	10	0	0	0
20	6	11	0	0	0
21	6	13	0	0	0
22	6	14	0	0	0
23	6	14	0	0	0
24	6	12	0	0	0

浅川清流環境組合可燃ごみ処理施設

**環境監視日報**

2022年3月25日 (金)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
10	20	10	0.005	50	
430	250	約2700	0.040	50	
1	6	13	0	0	0
2	6	12	0	0	0
3	6	10	0	0	2
4	6	12	0	0	1
5	6	11	0	0	1
6	6	13	0	0	1
7	6	14	1	0	1
8	6	12	1	0	1
9	6	13	0	0	1
10	6	12	0	0	1
11	6	12	0	0	1
12	6	12	0	0	1
13	6	12	0	0	1
14	6	13	0	0	1
15	6	13	0	0	1
16	6	13	0	0	0
17	6	14	0	0	0
18	6	13	0	0	0
19	6	12	0	0	0
20	6	13	0	0	0
21	6	13	1	0	0
22	6	15	1	0	0
23	6	12	1	0	0
24	6	13	0	0	0

自主規制値  
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
10	20	10	0.005	50	
430	250	約2700	0.040	50	
1	6	14	1	0	0
2	6	15	0	0	0
3	6	12	0	0	0
4	6	12	0	0	0
5	6	14	0	0	0
6	6	13	0	0	0
7	6	14	0	0	0
8	6	12	0	0	0
9	6	15	0	0	0
10	6	10	0	0	0
11	6	14	0	0	0
12	---	---	---	---	---
13	---	---	---	---	---
14	---	---	---	---	---
15	---	---	---	---	---
16	---	---	---	---	---
17	---	---	---	---	---
18	---	---	---	---	---
19	---	---	---	---	---
20	---	---	---	---	---
21	---	---	---	---	---
22	---	---	---	---	---
23	---	---	---	---	---
24	---	---	---	---	---

浅川清流環境組合可燃ごみ処理施設

**環境監視日報**

2022年3月26日 (土)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	6	12	0	0	0
2	6	13	1	0	0
3	6	14	0	0	0
4	6	12	0	0	0
5	6	13	0	0	0
6	6	14	1	0	0
7	6	15	1	0	0
8	6	12	1	0	0
9	6	13	0	0	0
10	6	13	0	0	0
11	6	13	0	0	0
12	6	13	0	0	0
13	6	13	0	0	0
14	6	14	0	0	0
15	6	12	0	0	0
16	6	12	1	0	0
17	6	14	0	0	0
18	6	13	0	0	0
19	6	15	0	0	0
20	6	13	1	0	0
21	6	13	1	0	0
22	6	14	1	0	0
23	6	13	1	0	0
24	6	15	1	0	0

自主規制値  
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	---	---	---	---	---
2	---	---	---	---	---
3	---	---	---	---	---
4	---	---	---	---	---
5	---	---	---	---	---
6	---	---	---	---	---
7	---	---	---	---	---
8	---	---	---	---	---
9	---	---	---	---	---
10	---	---	---	---	---
11	---	---	---	---	---
12	---	---	---	---	---
13	---	---	---	---	---
14	---	---	---	---	---
15	---	---	---	---	---
16	---	---	---	---	---
17	---	---	---	---	---
18	---	---	---	---	---
19	---	---	---	---	---
20	---	---	---	---	---
21	---	---	---	---	---
22	---	---	---	---	---
23	---	---	---	---	---
24	---	---	---	---	---

浅川清流環境組合可燃ごみ処理施設

**環境監視日報**

2022年3月27日 (日)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	6	13	0	0	0
2	6	14	1	0	0
3	6	13	0	0	0
4	6	13	0	0	0
5	6	15	1	0	0
6	6	13	1	0	0
7	6	14	1	0	0
8	6	13	0	0	0
9	6	14	1	0	0
10	6	14	1	0	0
11	6	12	0	0	0
12	6	15	1	0	0
13	6	12	1	0	0
14	6	14	0	0	0
15	6	14	1	0	0
16	6	14	1	0	0
17	6	15	1	0	0
18	6	13	1	0	0
19	6	12	1	0	0
20	6	14	1	0	0
21	6	13	1	0	0
22	6	13	1	0	0
23	6	14	1	0	0
24	6	12	1	0	0

自主規制値  
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	---	---	---	---	---
2	---	---	---	---	---
3	---	---	---	---	---
4	---	---	---	---	---
5	---	---	---	---	---
6	---	---	---	---	---
7	---	---	---	---	---
8	---	---	---	---	---
9	---	---	---	---	---
10	---	---	---	---	---
11	---	---	---	---	---
12	---	---	---	---	---
13	---	---	---	---	---
14	---	---	---	---	---
15	---	---	---	---	---
16	---	---	---	---	---
17	---	---	---	---	---
18	---	---	---	---	---
19	---	---	---	---	---
20	---	---	---	---	---
21	---	---	---	---	---
22	---	---	---	---	---
23	---	---	---	---	---
24	---	---	---	---	---

浅川清流環境組合可燃ごみ処理施設

**環境監視日報**

2022年3月28日 (月)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	6	11	1	0	0
2	6	14	1	0	0
3	6	12	1	0	0
4	6	13	1	0	0
5	6	12	1	0	0
6	6	15	0	0	0
7	6	13	1	0	0
8	6	14	0	0	0
9	6	13	0	0	0
10	6	14	0	0	0
11	6	12	1	0	0
12	6	14	1	0	0
13	6	14	1	0	0
14	6	13	1	0	0
15	6	14	1	0	0
16	6	14	1	0	0
17	6	13	1	0	0
18	6	12	1	0	0
19	6	13	1	0	0
20	6	12	1	0	0
21	6	13	0	0	0
22	6	12	0	0	0
23	6	12	1	0	0
24	6	11	1	0	0

自主規制値  
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	---	---	---	---	---
2	---	---	---	---	---
3	---	---	---	---	---
4	---	---	---	---	---
5	---	---	---	---	---
6	---	---	---	---	---
7	---	---	---	---	---
8	---	---	---	---	---
9	---	---	---	---	---
10	---	---	---	---	---
11	---	---	---	---	---
12	---	---	---	---	---
13	---	---	---	---	---
14	---	---	---	---	---
15	---	---	---	---	---
16	---	---	---	---	---
17	---	---	---	---	---
18	---	---	---	---	---
19	---	---	---	---	---
20	---	---	---	---	---
21	---	---	---	---	---
22	---	---	---	---	---
23	---	---	---	---	---
24	---	---	---	---	---

浅川清流環境組合可燃ごみ処理施設

**環境監視日報**

2022年3月29日 (火)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	6	12	1	0	0
2	6	14	1	0	0
3	6	12	1	0	0
4	6	12	1	0	0
5	6	12	1	0	0
6	6	12	1	0	0
7	6	12	0	0	0
8	6	13	1	0	0
9	6	12	0	0	0
10	6	13	0	0	0
11	6	13	1	0	0
12	6	12	1	0	0
13	6	13	1	0	0
14	6	13	0	0	0
15	6	13	1	0	1
16	6	14	1	0	0
17	6	13	1	0	0
18	6	12	1	0	0
19	6	12	0	0	0
20	6	13	1	0	0
21	6	13	1	0	0
22	6	13	1	0	0
23	6	13	1	0	0
24	6	13	0	0	0

自主規制値  
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	---	---	---	---	---
2	---	---	---	---	---
3	---	---	---	---	---
4	---	---	---	---	---
5	---	---	---	---	---
6	---	---	---	---	---
7	---	---	---	---	---
8	---	---	---	---	---
9	---	---	---	---	---
10	---	---	---	---	---
11	---	---	---	---	---
12	---	---	---	---	---
13	---	---	---	---	---
14	---	---	---	---	---
15	---	---	---	---	---
16	---	---	---	---	---
17	---	---	---	---	---
18	---	---	---	---	---
19	---	---	---	---	---
20	---	---	---	---	---
21	---	---	---	---	---
22	---	---	---	---	---
23	---	---	---	---	---
24	---	---	---	---	---

浅川清流環境組合可燃ごみ処理施設

**環境監視日報**

2022年3月30日 (水)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	6	14	1	0	0
2	6	13	1	0	0
3	6	12	1	0	0
4	6	13	1	0	0
5	6	13	1	0	0
6	6	15	1	0	0
7	6	12	0	0	0
8	6	13	1	0	0
9	6	13	1	0	0
10	6	13	0	0	0
11	6	13	1	0	0
12	6	14	0	0	0
13	6	12	1	0	0
14	6	13	0	0	0
15	6	14	1	0	0
16	6	14	1	0	0
17	6	12	1	0	0
18	6	13	1	0	0
19	6	14	1	0	0
20	6	13	1	0	0
21	6	14	1	0	0
22	6	13	1	0	0
23	6	13	1	0	0
24	6	13	1	0	0

自主規制値  
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	---	---	---	---	---
2	---	---	---	---	---
3	---	---	---	---	---
4	---	---	---	---	---
5	---	---	---	---	---
6	---	---	---	---	---
7	---	---	---	---	---
8	---	---	---	---	---
9	---	---	---	---	---
10	---	---	---	---	---
11	---	---	---	---	---
12	---	---	---	---	---
13	---	---	---	---	---
14	---	---	---	---	---
15	---	---	---	---	---
16	---	---	---	---	---
17	---	---	---	---	---
18	---	---	---	---	---
19	---	---	---	---	---
20	---	---	---	---	---
21	---	---	---	---	---
22	---	---	---	---	---
23	---	---	---	---	---
24	---	---	---	---	---

浅川清流環境組合可燃ごみ処理施設

**環境監視日報**

2022年3月31日 (木)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
10	20	10	0.005	50	
430	250	約2700	0.040	50	
1	6	14	1	0	0
2	6	14	0	0	0
3	6	13	0	0	0
4	6	13	1	0	0
5	6	13	0	0	0
6	6	12	0	0	0
7	6	13	1	0	0
8	6	13	1	0	0
9	6	14	1	0	0
10	6	14	1	0	0
11	6	12	1	0	0
12	6	11	1	0	0
13	6	10	1	0	0
14	6	11	1	0	0
15	6	13	1	0	0
16	6	13	1	0	0
17	6	12	1	0	0
18	6	13	1	0	0
19	6	12	0	0	0
20	6	14	1	0	0
21	6	13	1	0	0
22	6	14	1	0	0
23	6	11	1	0	0
24	6	14	1	0	0

自主規制値  
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
10	20	10	0.005	50	
430	250	約2700	0.040	50	
1	---	---	---	---	---
2	---	---	---	---	---
3	---	---	---	---	---
4	---	---	---	---	---
5	---	---	---	---	---
6	---	---	---	---	---
7	---	---	---	---	---
8	---	---	---	---	---
9	---	---	---	---	---
10	---	---	---	---	---
11	---	---	---	---	---
12	---	---	---	---	---
13	---	---	---	---	---
14	---	---	---	---	---
15	---	---	---	---	---
16	---	---	---	---	---
17	---	---	---	---	---
18	---	---	---	---	---
19	---	---	---	---	---
20	---	---	---	---	---
21	---	---	---	---	---
22	---	---	---	---	---
23	---	---	---	---	---
24	---	---	---	---	---