

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年4月1日 (金)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	13	1	0	0
2	6	13	1	0	0
3	6	15	0	0	0
4	6	12	1	0	0
5	6	11	1	0	0
6	6	13	1	0	0
7	6	15	1	0	0
8	6	12	1	0	0
9	6	13	1	0	0
10	6	13	1	0	0
11	6	15	1	0	0
12	6	14	1	0	0
13	6	13	1	0	0
14	6	14	1	0	0
15	6	14	1	0	0
16	6	14	0	0	0
17	6	13	1	0	0
18	6	13	1	0	0
19	6	15	1	0	0
20	6	13	1	0	0
21	6	16	1	0	0
22	6	13	0	0	1
23	6	12	1	0	1
24	6	15	0	0	1

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	----	----	----	----	----
2	----	----	----	----	----
3	----	----	----	----	----
4	----	----	----	----	----
5	----	----	----	----	----
6	----	----	----	----	----
7	----	----	----	----	----
8	----	----	----	----	----
9	----	----	----	----	----
10	----	----	----	----	----
11	----	----	----	----	----
12	----	----	----	----	----
13	----	----	----	----	----
14	----	----	----	----	----
15	----	----	----	----	----
16	----	----	----	----	----
17	----	----	----	----	----
18	----	----	----	----	----
19	----	----	----	----	----
20	----	----	----	----	----
21	----	----	----	----	----
22	----	----	----	----	----
23	----	----	----	----	----
24	----	----	----	----	----

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年4月2日 (土)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	14	0	0	0
2	6	13	0	0	0
3	6	15	1	0	0
4	6	12	0	0	0
5	6	14	1	0	45
6	6	12	1	0	25
7	6	14	0	0	8
8	6	14	1	0	5
9	6	13	1	0	3
10	6	14	0	0	2
11	6	12	1	0	3
12	6	14	1	0	1
13	6	12	1	0	1
14	6	14	0	0	1
15	6	14	0	0	1
16	6	12	0	0	1
17	6	14	0	0	1
18	6	14	1	0	0
19	6	14	1	0	0
20	6	14	0	0	0
21	6	14	1	0	0
22	6	13	0	0	0
23	6	15	1	0	0
24	6	13	0	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	----	----	----	----	----
2	----	----	----	----	----
3	----	----	----	----	----
4	----	----	----	----	----
5	----	----	----	----	----
6	----	----	----	----	----
7	----	----	----	----	----
8	----	----	----	----	----
9	----	----	----	----	----
10	----	----	----	----	----
11	----	----	----	----	----
12	----	----	----	----	----
13	----	----	----	----	----
14	----	----	----	----	----
15	----	----	----	----	----
16	----	----	----	----	----
17	----	----	----	----	----
18	----	----	----	----	----
19	----	----	----	----	----
20	----	----	----	----	----
21	----	----	----	----	----
22	----	----	----	----	----
23	----	----	----	----	----
24	----	----	----	----	----

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年4月3日 (日)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	13	0	0	0
2	6	14	1	0	0
3	6	13	0	0	0
4	6	12	1	0	0
5	6	14	0	0	0
6	6	12	0	0	0
7	6	13	0	0	0
8	6	12	0	0	0
9	6	13	1	0	0
10	6	14	0	0	0
11	6	13	1	0	0
12	6	14	1	0	0
13	6	14	0	0	0
14	6	14	1	0	0
15	6	14	0	0	0
16	6	13	0	0	0
17	6	14	0	0	0
18	6	13	1	0	0
19	6	14	1	0	0
20	6	14	1	0	0
21	6	14	1	0	0
22	6	12	0	0	0
23	6	14	0	0	0
24	6	14	1	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	----	----	----	----	----
2	----	----	----	----	----
3	----	----	----	----	----
4	----	----	----	----	----
5	----	----	----	----	----
6	----	----	----	----	----
7	----	----	----	----	----
8	----	----	----	----	----
9	----	----	----	----	----
10	----	----	----	----	----
11	----	----	----	----	----
12	----	----	----	----	----
13	----	----	----	----	----
14	----	----	----	----	----
15	----	----	----	----	----
16	----	----	----	----	----
17	----	----	----	----	----
18	----	----	----	----	----
19	----	----	----	----	----
20	----	----	----	----	----
21	----	----	----	----	----
22	----	----	----	----	----
23	----	----	----	----	----
24	----	----	----	----	----

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年4月4日 (月)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	14	1	0	0
2	6	14	0	0	0
3	6	13	1	0	0
4	6	15	1	0	0
5	6	14	1	0	0
6	6	14	1	0	0
7	6	14	1	0	0
8	6	14	1	0	0
9	6	12	1	0	0
10	6	14	1	0	0
11	6	14	1	0	0
12	6	13	0	0	0
13	6	14	1	0	0
14	6	15	0	0	0
15	6	14	0	0	0
16	6	14	1	0	0
17	6	14	0	0	0
18	6	15	1	0	0
19	6	10	1	0	0
20	6	11	1	0	0
21	6	11	0	0	0
22	6	13	1	0	0
23	6	13	0	0	0
24	6	12	1	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	----	----	----	----	----
2	----	----	----	----	----
3	----	----	----	----	----
4	----	----	----	----	----
5	----	----	----	----	----
6	----	----	----	----	----
7	----	----	----	----	----
8	----	----	----	----	----
9	----	----	----	----	----
10	----	----	----	----	----
11	----	----	----	----	----
12	----	----	----	----	----
13	----	----	----	----	----
14	----	----	----	----	----
15	----	----	----	----	----
16	----	----	----	----	----
17	----	----	----	----	----
18	----	----	----	----	----
19	----	----	----	----	----
20	----	----	----	----	----
21	----	----	----	----	----
22	----	----	----	----	----
23	----	----	----	----	----
24	----	----	----	----	----

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年4月5日 (火)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	13	1	0	0
2	6	13	1	0	0
3	6	13	0	0	0
4	6	13	1	0	0
5	6	13	0	0	0
6	6	13	0	0	0
7	6	15	1	0	0
8	6	13	1	0	0
9	6	13	1	0	0
10	6	14	0	0	0
11	6	13	1	0	0
12	6	14	0	0	0
13	6	13	1	0	0
14	6	13	0	0	0
15	6	13	0	0	0
16	6	15	0	0	0
17	6	11	0	0	0
18	6	14	0	0	0
19	6	13	0	0	0
20	6	13	1	0	0
21	6	14	0	0	0
22	6	13	0	0	0
23	6	10	0	0	0
24	6	10	1	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	----	----	----	----	----
2	----	----	----	----	----
3	----	----	----	----	----
4	----	----	----	----	----
5	----	----	----	----	----
6	----	----	----	----	----
7	----	----	----	----	----
8	----	----	----	----	----
9	----	----	----	----	----
10	----	----	----	----	----
11	----	----	----	----	----
12	----	----	----	----	----
13	----	----	----	----	----
14	----	----	----	----	----
15	----	----	----	----	----
16	----	----	----	----	----
17	----	----	----	----	----
18	----	----	----	----	----
19	----	----	----	----	----
20	----	----	----	----	----
21	----	----	----	----	----
22	----	----	----	----	----
23	----	----	----	----	----
24	----	----	----	----	----

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年4月6日 (水)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	16	0	0	0
2	6	11	0	0	0
3	6	13	0	0	0
4	6	14	0	0	0
5	6	13	0	0	0
6	6	14	0	0	0
7	6	12	0	0	0
8	6	14	0	0	0
9	6	13	0	0	0
10	6	12	0	0	0
11	6	11	0	0	0
12	6	14	1	0	0
13	6	14	0	0	0
14	6	13	0	0	0
15	6	13	0	0	0
16	6	14	0	0	0
17	6	13	1	0	0
18	6	14	1	0	0
19	6	13	1	0	0
20	6	14	1	0	0
21	6	13	1	0	0
22	6	15	1	0	0
23	6	11	1	0	0
24	6	14	1	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	----	----	----	----	----
2	----	----	----	----	----
3	----	----	----	----	----
4	----	----	----	----	----
5	----	----	----	----	----
6	----	----	----	----	----
7	----	----	----	----	----
8	----	----	----	----	----
9	----	----	----	----	----
10	----	----	----	----	----
11	----	----	----	----	----
12	----	----	----	----	----
13	----	----	----	----	----
14	----	----	----	----	----
15	----	----	----	----	----
16	----	----	----	----	----
17	----	----	----	----	----
18	----	----	----	----	----
19	----	----	----	----	----
20	----	----	----	----	----
21	----	----	----	----	----
22	----	----	----	----	----
23	----	----	----	----	----
24	----	----	----	----	----

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年4月7日 (木)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	12	1	0	0
2	6	14	0	0	0
3	6	15	1	0	0
4	6	12	1	0	0
5	6	15	1	0	0
6	6	11	1	0	0
7	6	14	0	0	0
8	6	14	1	0	0
9	6	13	1	0	0
10	6	14	1	0	0
11	6	13	1	0	0
12	6	15	1	0	0
13	6	12	1	0	0
14	6	13	1	0	0
15	6	14	1	0	0
16	6	14	1	0	0
17	6	14	1	0	0
18	6	14	1	0	0
19	6	14	1	0	0
20	6	13	1	0	0
21	6	15	1	0	0
22	6	13	1	0	0
23	6	15	1	0	0
24	6	12	1	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	----	----	----	----	----
2	----	----	----	----	----
3	----	----	----	----	----
4	----	----	----	----	----
5	----	----	----	----	----
6	----	----	----	----	----
7	----	----	----	----	----
8	----	----	----	----	----
9	----	----	----	----	----
10	----	----	----	----	----
11	----	----	----	----	----
12	----	----	----	----	----
13	----	----	----	----	----
14	----	----	----	----	----
15	----	----	----	----	----
16	----	----	----	----	----
17	----	----	----	----	----
18	----	----	----	----	----
19	----	----	----	----	----
20	----	----	----	----	----
21	----	----	----	----	----
22	----	----	----	----	----
23	----	----	----	----	----
24	----	----	----	----	----

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年4月8日 (金)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	15	1	0	0
2	6	13	1	0	0
3	6	14	1	0	0
4	6	13	1	0	0
5	6	13	1	0	0
6	6	14	1	0	0
7	6	14	1	0	0
8	6	14	1	0	0
9	6	14	1	0	0
10	6	12	0	0	0
11	6	14	1	0	0
12	6	14	1	0	0
13	6	15	1	0	0
14	6	13	1	0	0
15	6	14	0	0	0
16	6	14	1	0	0
17	6	12	1	0	0
18	6	14	1	0	0
19	6	12	1	0	0
20	6	14	1	0	0
21	6	13	1	0	0
22	6	15	1	0	0
23	6	13	1	0	0
24	6	15	1	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	----	----	----	----	----
2	----	----	----	----	----
3	----	----	----	----	----
4	----	----	----	----	----
5	----	----	----	----	----
6	----	----	----	----	----
7	----	----	----	----	----
8	----	----	----	----	----
9	----	----	----	----	----
10	----	----	----	----	----
11	----	----	----	----	----
12	----	----	----	----	----
13	----	----	----	----	----
14	----	----	----	----	----
15	----	----	----	----	----
16	----	----	----	----	----
17	----	----	----	----	----
18	----	----	----	----	----
19	----	----	----	----	----
20	----	----	----	----	----
21	----	----	----	----	----
22	----	----	----	----	----
23	----	----	----	----	----
24	----	----	----	----	----

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年4月9日 (土)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	15	0	0	0
2	6	13	1	0	0
3	6	13	1	0	0
4	6	14	0	0	0
5	6	13	0	0	0
6	6	12	1	0	0
7	6	13	1	0	0
8	6	14	0	0	0
9	6	14	1	0	0
10	6	13	1	0	0
11	6	13	0	0	0
12	6	14	0	0	0
13	6	13	1	0	0
14	6	15	1	0	0
15	6	14	1	0	0
16	6	12	1	0	0
17	6	14	1	0	0
18	6	13	1	0	0
19	6	13	1	0	0
20	6	14	1	0	0
21	6	13	0	0	1
22	6	15	1	0	0
23	6	13	0	0	0
24	6	14	1	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	----	----	----	----	----
2	----	----	----	----	----
3	----	----	----	----	----
4	----	----	----	----	----
5	----	----	----	----	----
6	----	----	----	----	----
7	----	----	----	----	----
8	----	----	----	----	----
9	----	----	----	----	----
10	----	----	----	----	----
11	----	----	----	----	----
12	----	----	----	----	----
13	----	----	----	----	----
14	----	----	----	----	----
15	----	----	----	----	----
16	----	----	----	----	----
17	----	----	----	----	----
18	----	----	----	----	----
19	----	----	----	----	----
20	----	----	----	----	----
21	----	----	----	----	----
22	----	----	----	----	----
23	----	----	----	----	----
24	----	----	----	----	----

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年4月10日 (日)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	13	1	0	0
2	6	13	1	0	0
3	6	13	1	0	0
4	6	13	0	0	0
5	6	14	1	0	1
6	6	13	0	0	1
7	6	13	1	0	1
8	6	15	1	0	1
9	6	11	1	0	1
10	6	10	1	0	0
11	6	14	1	0	0
12	6	13	1	0	0
13	6	15	1	0	0
14	6	14	1	0	0
15	6	13	1	0	0
16	6	14	1	0	0
17	6	12	1	0	0
18	6	15	1	0	0
19	6	13	1	0	0
20	6	14	1	0	0
21	6	15	1	0	0
22	6	13	1	0	0
23	6	12	1	0	0
24	6	14	1	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	----	----	----	----	----
2	----	----	----	----	----
3	----	----	----	----	----
4	----	----	----	----	----
5	----	----	----	----	----
6	----	----	----	----	----
7	----	----	----	----	----
8	----	----	----	----	----
9	----	----	----	----	----
10	----	----	----	----	----
11	----	----	----	----	----
12	----	----	----	----	----
13	----	----	----	----	----
14	----	----	----	----	----
15	----	----	----	----	----
16	----	----	----	----	----
17	----	----	----	----	----
18	----	----	----	----	----
19	----	----	----	----	----
20	----	----	----	----	----
21	----	----	----	----	----
22	----	----	----	----	----
23	----	----	----	----	----
24	----	----	----	----	----

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年4月11日 (月)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	14	1	0	0
2	6	14	1	0	0
3	6	13	1	0	0
4	6	13	1	0	0
5	6	14	1	0	0
6	6	13	1	0	0
7	6	14	1	0	0
8	6	13	1	0	0
9	6	14	1	0	0
10	6	13	1	0	0
11	6	13	1	0	0
12	6	13	1	0	0
13	6	13	1	0	0
14	6	13	1	0	0
15	6	12	0	0	0
16	6	13	1	0	0
17	6	14	1	0	0
18	6	14	1	0	0
19	6	11	1	0	0
20	6	14	1	0	0
21	6	13	1	0	0
22	6	13	1	0	0
23	6	15	1	0	0
24	6	14	1	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	----	----	----	----	----
2	----	----	----	----	----
3	----	----	----	----	----
4	----	----	----	----	----
5	----	----	----	----	----
6	----	----	----	----	----
7	----	----	----	----	----
8	----	----	----	----	----
9	----	----	----	----	----
10	----	----	----	----	----
11	----	----	----	----	----
12	----	----	----	----	----
13	----	----	----	----	----
14	----	----	----	----	----
15	----	----	----	----	----
16	----	----	----	----	----
17	----	----	----	----	----
18	----	----	----	----	----
19	----	----	----	----	----
20	----	----	----	----	----
21	----	----	----	----	----
22	----	----	----	----	----
23	----	----	----	----	----
24	----	----	----	----	----

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年4月12日 (火)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	13	1	0	0
2	6	13	1	0	0
3	6	14	1	0	0
4	6	12	0	0	0
5	6	13	1	0	0
6	6	14	1	0	0
7	6	13	1	0	0
8	6	13	1	0	0
9	6	14	1	0	0
10	6	15	0	0	0
11	6	11	1	0	0
12	6	14	1	0	0
13	6	13	0	0	0
14	6	15	0	0	0
15	6	11	1	0	0
16	6	13	1	0	0
17	6	15	0	0	0
18	6	13	0	0	0
19	6	12	0	0	0
20	6	14	1	0	0
21	6	13	0	0	0
22	6	15	0	0	0
23	6	13	0	0	0
24	6	13	0	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	----	----	----	----	----
2	----	----	----	----	----
3	----	----	----	----	----
4	----	----	----	----	----
5	----	----	----	----	----
6	----	----	----	----	----
7	----	----	----	----	----
8	----	----	----	----	----
9	----	----	----	----	----
10	----	----	----	----	----
11	----	----	----	----	----
12	----	----	----	----	----
13	----	----	----	----	----
14	----	----	----	----	----
15	----	----	----	----	----
16	----	----	----	----	----
17	----	----	----	----	----
18	----	----	----	----	----
19	----	----	----	----	----
20	----	----	----	----	----
21	----	----	----	----	----
22	----	----	----	----	----
23	----	----	----	----	----
24	----	----	----	----	----

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年4月13日 (水)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	14	0	0	0
2	6	11	1	0	0
3	6	17	1	0	0
4	6	12	0	0	0
5	6	12	0	0	0
6	6	14	1	0	0
7	6	13	0	0	0
8	6	13	0	0	0
9	6	14	0	0	0
10	6	12	0	0	0
11	6	13	0	0	0
12	6	12	0	0	0
13	6	12	0	0	0
14	6	14	0	0	0
15	6	13	1	0	0
16	6	14	0	0	0
17	6	13	1	0	0
18	6	14	0	0	0
19	6	13	0	0	0
20	6	12	0	0	0
21	6	13	1	0	0
22	6	12	0	0	0
23	6	12	0	0	0
24	6	13	0	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	----	----	----	----	----
2	----	----	----	----	----
3	----	----	----	----	----
4	----	----	----	----	----
5	----	----	----	----	----
6	----	----	----	----	----
7	----	----	----	----	----
8	----	----	----	----	----
9	----	----	----	----	----
10	----	----	----	----	----
11	----	----	----	----	----
12	----	----	----	----	----
13	----	----	----	----	----
14	----	----	----	----	----
15	----	----	----	----	----
16	----	----	----	----	----
17	----	----	----	----	----
18	----	----	----	----	----
19	----	----	----	----	----
20	----	----	----	----	----
21	----	----	----	----	----
22	----	----	----	----	----
23	----	----	----	----	----
24	----	----	----	----	----

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年4月14日 (木)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	12	0	0	0
2	6	13	1	0	0
3	6	11	0	0	0
4	6	14	0	0	0
5	6	14	0	0	0
6	6	12	0	0	0
7	6	12	0	0	0
8	6	11	0	0	0
9	6	12	1	0	0
10	6	12	1	0	0
11	6	11	1	0	0
12	6	13	0	0	0
13	6	12	0	0	0
14	6	14	1	0	0
15	6	13	0	0	0
16	6	12	0	0	0
17	6	13	1	0	0
18	6	13	0	0	0
19	6	13	0	0	0
20	6	14	1	0	0
21	6	11	0	0	0
22	6	13	0	0	0
23	6	14	0	0	0
24	6	12	0	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	----	----	----	----	----
2	----	----	----	----	----
3	----	----	----	----	----
4	----	----	----	----	----
5	----	----	----	----	----
6	----	----	----	----	----
7	----	----	----	----	----
8	----	----	----	----	----
9	----	----	----	----	----
10	----	----	----	----	----
11	----	----	----	----	----
12	----	----	----	----	----
13	----	----	----	----	----
14	----	----	----	----	----
15	----	----	----	----	----
16	----	----	----	----	----
17	----	----	----	----	----
18	----	----	----	----	----
19	----	----	----	----	----
20	----	----	----	----	----
21	----	----	----	----	----
22	----	----	----	----	----
23	----	----	----	----	----
24	----	----	----	----	----

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年4月15日 (金)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	13	1	0	0
2	6	13	0	0	0
3	6	13	0	0	0
4	6	13	0	0	0
5	6	14	0	0	0
6	6	16	0	0	0
7	6	12	0	0	0
8	6	14	0	0	0
9	6	12	0	0	0
10	6	12	0	0	0
11	6	13	1	0	0
12	6	10	1	0	0
13	6	13	1	0	0
14	6	13	0	0	0
15	6	13	0	0	0
16	6	11	0	0	0
17	6	12	0	0	0
18	6	11	0	0	0
19	6	11	0	0	0
20	6	11	1	0	0
21	6	13	0	0	0
22	6	13	0	0	0
23	6	14	0	0	0
24	6	14	0	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	----	----	----	----	----
2	----	----	----	----	----
3	----	----	----	----	----
4	----	----	----	----	----
5	----	----	----	----	----
6	----	----	----	----	----
7	----	----	----	----	----
8	----	----	----	----	----
9	----	----	----	----	----
10	----	----	----	----	----
11	----	----	----	----	----
12	----	----	----	----	----
13	----	----	----	----	----
14	----	----	----	----	----
15	6	4	0	0	1
16	6	7	0	0	1
17	6	8	0	0	0
18	6	8	0	0	1
19	6	7	0	0	0
20	6	10	1	0	0
21	6	9	0	0	0
22	6	8	0	0	0
23	6	8	0	0	0
24	6	9	0	0	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年4月16日 (土)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	13	0	0	0
2	6	11	0	0	0
3	6	12	0	0	0
4	6	11	0	0	0
5	6	13	0	0	0
6	6	13	0	0	0
7	6	12	0	0	0
8	6	13	0	0	0
9	6	12	0	0	0
10	6	13	0	0	0
11	6	14	1	0	0
12	6	12	0	0	0
13	6	12	0	0	0
14	6	10	0	0	0
15	6	11	0	0	0
16	6	13	1	0	0
17	6	14	0	0	0
18	6	11	0	0	0
19	6	13	0	0	0
20	6	11	0	0	0
21	6	11	1	0	0
22	6	11	1	0	0
23	6	12	0	0	0
24	6	12	1	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	9	0	0	0
2	6	9	0	0	0
3	6	9	0	0	0
4	6	10	0	0	0
5	6	10	0	0	0
6	6	10	0	0	0
7	6	9	0	0	0
8	6	8	0	0	0
9	6	9	0	0	0
10	6	9	0	0	0
11	6	9	0	0	0
12	6	9	0	0	0
13	6	10	0	0	0
14	6	9	0	0	0
15	6	10	0	0	0
16	6	9	0	0	0
17	6	10	0	0	0
18	6	10	0	0	0
19	6	9	0	0	0
20	6	9	0	0	0
21	6	10	0	0	0
22	6	8	0	0	0
23	6	9	0	0	0
24	6	9	0	0	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年4月17日 (日)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	11	0	0	0
2	6	13	0	0	2
3	6	12	0	0	1
4	6	10	1	0	1
5	6	12	0	0	1
6	6	12	1	0	1
7	6	12	0	0	1
8	6	11	0	0	0
9	6	11	1	0	1
10	6	11	1	0	0
11	6	12	1	0	0
12	6	13	0	0	0
13	6	11	0	0	0
14	6	11	0	0	0
15	6	10	1	0	0
16	6	11	0	0	0
17	6	11	0	0	0
18	6	11	0	0	0
19	6	12	0	0	0
20	6	11	0	0	0
21	6	12	0	0	0
22	6	12	0	0	0
23	6	12	0	0	0
24	6	12	1	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	8	0	0	0
2	6	10	0	0	0
3	6	10	0	0	0
4	6	10	0	0	0
5	6	9	0	0	0
6	6	10	0	0	0
7	6	11	0	0	0
8	6	11	0	0	0
9	6	10	0	0	0
10	6	11	0	0	0
11	6	11	0	0	0
12	6	9	0	0	0
13	6	9	0	0	0
14	6	9	0	0	0
15	6	9	0	0	0
16	6	10	0	0	1
17	6	10	0	0	1
18	6	10	0	0	0
19	6	8	0	0	0
20	6	10	0	0	0
21	6	9	0	0	0
22	6	10	0	0	0
23	6	10	0	0	0
24	6	11	0	0	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年4月18日 (月)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	13	0	0	0
2	6	12	0	0	0
3	6	11	1	0	0
4	6	12	0	0	0
5	6	11	0	0	0
6	6	12	0	0	0
7	6	13	0	0	0
8	6	11	0	0	0
9	6	11	0	0	0
10	6	12	1	0	0
11	6	12	0	0	0
12	6	11	0	0	0
13	6	14	0	0	0
14	6	12	0	0	0
15	6	13	0	0	0
16	6	13	1	0	0
17	6	13	0	0	0
18	6	12	0	0	0
19	6	14	0	0	0
20	6	13	0	0	0
21	6	13	0	0	0
22	6	13	0	0	0
23	6	13	0	0	0
24	6	13	0	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	10	0	0	0
2	6	11	0	0	0
3	6	12	0	0	0
4	6	9	0	0	0
5	6	10	0	0	0
6	6	10	0	0	0
7	6	10	0	0	0
8	6	10	0	0	0
9	6	10	0	0	0
10	6	11	0	0	0
11	6	10	0	0	0
12	6	10	0	0	0
13	6	11	0	0	0
14	6	12	0	0	0
15	6	13	0	0	0
16	6	12	0	0	0
17	6	13	0	0	0
18	6	13	0	0	0
19	6	14	0	0	0
20	6	14	0	0	0
21	6	11	0	0	0
22	6	11	0	0	0
23	6	12	0	0	0
24	6	12	0	0	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年4月19日 (火)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	13	0	0	0
2	6	14	0	0	0
3	6	13	0	0	0
4	6	14	0	0	0
5	6	14	0	0	0
6	6	12	1	0	0
7	6	14	0	0	0
8	6	14	0	0	0
9	6	14	0	0	0
10	6	14	0	0	0
11	6	14	0	0	0
12	6	14	1	0	0
13	6	12	0	0	0
14	6	13	1	0	0
15	6	14	1	0	0
16	6	14	0	0	0
17	6	14	0	0	0
18	6	14	1	0	0
19	6	13	0	0	0
20	6	13	1	0	0
21	6	14	0	0	0
22	6	13	0	0	0
23	6	13	0	0	0
24	6	13	0	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	12	0	0	0
2	6	12	0	0	0
3	6	13	0	0	0
4	6	13	0	0	0
5	6	12	0	0	0
6	6	11	0	0	0
7	6	14	0	0	0
8	6	10	0	0	0
9	6	12	0	0	0
10	6	13	0	0	0
11	6	14	0	0	0
12	6	14	0	0	0
13	6	12	0	0	1
14	6	11	0	0	0
15	6	14	0	0	0
16	6	12	0	0	0
17	6	11	0	0	0
18	6	13	0	0	0
19	6	14	0	0	0
20	6	11	0	0	0
21	6	11	0	0	0
22	6	13	0	0	0
23	6	11	0	0	0
24	6	12	0	0	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年4月20日 (水)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	13	0	0	0
2	6	14	0	0	0
3	6	13	1	0	0
4	6	12	0	0	0
5	6	13	1	0	0
6	6	13	1	0	0
7	6	12	0	0	0
8	6	12	1	0	0
9	6	12	1	0	0
10	6	13	1	0	0
11	6	11	0	0	0
12	6	12	1	0	0
13	6	14	1	0	0
14	6	13	0	0	0
15	6	11	0	0	0
16	6	12	1	0	0
17	6	13	0	0	0
18	6	12	1	0	0
19	6	12	1	0	0
20	6	12	0	0	0
21	6	14	1	0	0
22	6	12	1	0	0
23	6	13	1	0	0
24	6	13	0	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	13	0	0	0
2	6	15	0	0	0
3	6	11	0	0	0
4	6	13	0	0	0
5	6	14	0	0	0
6	6	12	0	0	0
7	6	12	0	0	0
8	6	13	0	0	0
9	6	12	0	0	0
10	6	14	0	0	0
11	6	13	0	0	0
12	6	11	0	0	0
13	6	11	0	0	0
14	6	14	0	0	0
15	6	10	0	0	0
16	6	10	0	0	0
17	6	11	0	0	0
18	6	15	0	0	0
19	6	12	0	0	0
20	6	13	0	0	0
21	6	14	0	0	0
22	6	12	0	0	0
23	6	12	0	0	0
24	6	14	0	0	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年4月21日 (木)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	12	1	0	0
2	6	13	1	0	0
3	6	14	1	0	0
4	6	13	0	0	0
5	6	11	0	0	0
6	6	13	0	0	0
7	6	13	0	0	0
8	6	12	0	0	0
9	6	13	1	0	0
10	6	13	1	0	0
11	6	13	1	0	0
12	6	13	1	0	0
13	6	12	0	0	0
14	6	13	1	0	0
15	6	13	0	0	0
16	6	13	0	0	0
17	6	12	1	0	1
18	6	12	1	0	1
19	6	13	1	0	1
20	6	13	0	0	1
21	6	13	0	0	0
22	6	13	1	0	0
23	6	14	1	0	0
24	6	14	0	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	13	0	0	0
2	6	14	0	0	0
3	6	12	0	0	0
4	6	14	0	0	0
5	6	11	0	0	0
6	6	14	0	0	0
7	6	11	0	0	0
8	6	10	0	0	0
9	6	13	0	0	0
10	6	14	0	0	0
11	6	14	0	0	0
12	6	14	0	0	0
13	6	14	0	0	0
14	6	13	0	0	0
15	6	13	0	0	0
16	6	14	0	0	0
17	6	14	0	0	0
18	6	12	0	0	0
19	6	11	0	0	0
20	6	11	0	0	0
21	6	14	0	0	0
22	6	10	0	0	0
23	6	13	0	0	0
24	6	13	0	0	1

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年4月22日 (金)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	11	1	0	0
2	6	13	0	0	0
3	6	14	0	0	0
4	6	12	1	0	0
5	6	14	0	0	0
6	6	12	1	0	0
7	6	13	0	0	0
8	6	14	0	0	0
9	6	14	1	0	0
10	6	12	1	0	0
11	6	14	0	0	0
12	6	13	1	0	0
13	6	13	0	0	0
14	6	13	1	0	0
15	6	14	0	0	0
16	6	13	1	0	0
17	6	13	0	0	0
18	6	13	0	0	0
19	6	14	1	0	0
20	6	13	1	0	0
21	6	14	0	0	0
22	6	13	0	0	6
23	6	14	0	0	2
24	6	14	0	0	1

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	12	0	0	0
2	6	10	0	0	0
3	6	12	0	0	0
4	6	14	0	0	0
5	6	10	0	0	0
6	6	15	0	0	0
7	6	10	0	0	0
8	6	12	0	0	0
9	6	14	0	0	0
10	6	13	0	0	0
11	6	13	0	0	0
12	6	14	0	0	0
13	6	11	0	0	0
14	6	14	0	0	0
15	6	11	0	0	0
16	6	13	0	0	0
17	6	13	0	0	0
18	6	14	0	0	0
19	6	14	0	0	1
20	6	11	0	0	1
21	6	11	0	0	0
22	6	15	0	0	0
23	6	12	0	0	0
24	6	15	0	0	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年4月23日 (土)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	14	0	0	1
2	6	13	1	0	1
3	6	13	1	0	1
4	6	14	0	0	1
5	6	14	1	0	1
6	6	14	0	0	1
7	6	14	1	0	1
8	6	13	1	0	1
9	6	13	0	0	0
10	6	12	1	0	0
11	6	14	0	0	0
12	6	12	0	0	0
13	6	13	0	0	0
14	6	13	1	0	0
15	6	13	0	0	0
16	6	12	0	0	0
17	6	13	0	0	0
18	6	13	0	0	0
19	6	13	1	0	0
20	6	13	1	0	1
21	6	14	1	0	1
22	6	12	0	0	1
23	6	13	0	0	0
24	6	12	0	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	13	0	0	0
2	6	14	0	0	0
3	6	13	0	0	0
4	6	15	0	0	0
5	6	12	0	0	0
6	6	13	0	0	0
7	6	14	0	0	0
8	6	14	0	0	0
9	6	11	0	0	0
10	6	14	0	0	0
11	6	12	0	0	0
12	6	13	0	0	0
13	6	14	0	0	0
14	6	10	0	0	0
15	6	14	0	0	0
16	6	11	0	0	0
17	6	11	0	0	0
18	6	11	0	0	0
19	6	12	0	0	0
20	6	13	0	0	0
21	6	13	0	0	0
22	6	11	0	0	0
23	6	11	0	0	0
24	6	14	0	0	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年4月24日 (日)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	14	1	0	0
2	6	14	0	0	0
3	6	14	1	0	0
4	6	13	1	0	0
5	6	12	1	0	0
6	6	12	0	0	0
7	6	13	1	0	0
8	6	12	1	0	1
9	6	12	1	0	0
10	6	13	1	0	0
11	6	13	0	0	1
12	6	13	1	0	1
13	6	14	1	0	1
14	6	12	1	0	1
15	6	13	1	0	1
16	6	13	1	0	1
17	6	11	0	0	1
18	6	12	0	0	1
19	6	13	0	0	1
20	6	12	1	0	1
21	6	14	1	0	1
22	6	13	1	0	1
23	6	13	1	0	0
24	6	14	0	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	12	0	0	0
2	6	11	0	0	0
3	6	15	0	0	0
4	6	10	0	0	0
5	6	14	0	0	0
6	6	9	0	0	0
7	6	13	0	0	0
8	6	14	0	0	0
9	6	10	0	0	0
10	6	13	0	0	0
11	6	12	0	0	0
12	6	12	0	0	0
13	6	11	0	0	0
14	6	12	0	0	0
15	6	16	0	0	0
16	6	12	0	0	0
17	6	12	0	0	0
18	6	15	0	0	0
19	6	11	0	0	0
20	6	11	0	0	0
21	6	11	0	0	0
22	6	12	0	0	0
23	6	13	0	0	0
24	6	12	0	0	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年4月25日 (月)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	13	0	0	0
2	6	13	0	0	1
3	6	13	0	0	0
4	6	13	0	0	0
5	6	13	0	0	0
6	6	13	1	0	0
7	6	11	0	0	0
8	6	12	0	0	0
9	6	13	0	0	0
10	6	13	1	0	0
11	6	13	1	0	0
12	6	13	0	0	0
13	6	13	1	0	0
14	6	14	1	0	0
15	6	14	0	0	0
16	6	12	1	0	0
17	6	12	1	0	1
18	6	13	0	0	1
19	6	12	1	0	1
20	6	13	0	0	1
21	6	14	0	0	1
22	6	10	1	0	1
23	6	13	0	0	1
24	6	13	0	0	1

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	11	0	0	0
2	6	13	0	0	0
3	6	12	0	0	0
4	6	10	0	0	0
5	6	12	0	0	0
6	6	12	0	0	0
7	6	13	0	0	0
8	6	13	0	0	0
9	6	11	0	0	0
10	6	12	0	0	0
11	6	13	0	0	0
12	6	14	0	0	0
13	6	12	0	0	0
14	6	13	0	0	0
15	6	13	0	0	0
16	6	10	0	0	0
17	6	13	0	0	0
18	6	12	0	0	0
19	6	12	0	0	0
20	6	10	0	0	0
21	6	12	0	0	0
22	6	13	0	0	0
23	6	13	0	0	0
24	6	13	0	0	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年4月26日 (火)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	13	0	0	1
2	6	14	0	0	1
3	6	13	0	0	1
4	6	11	1	0	1
5	6	14	0	0	1
6	6	13	0	0	1
7	6	13	1	0	1
8	6	13	0	0	1
9	6	12	1	0	1
10	6	12	0	0	1
11	6	14	0	0	1
12	6	13	1	0	1
13	6	14	1	0	1
14	6	13	1	0	1
15	6	13	1	0	1
16	6	12	0	0	1
17	6	14	1	0	1
18	6	13	1	0	1
19	6	13	0	0	1
20	6	13	0	0	1
21	6	12	0	0	1
22	6	13	0	0	1
23	6	12	0	0	0
24	6	13	0	0	1

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	12	0	0	0
2	6	11	0	0	0
3	6	11	0	0	0
4	6	15	0	0	0
5	6	11	0	0	0
6	6	15	0	0	0
7	6	11	0	0	0
8	6	10	0	0	0
9	6	13	0	0	0
10	6	12	0	0	0
11	6	13	0	0	0
12	6	14	0	0	0
13	6	13	0	0	0
14	6	13	0	0	0
15	6	10	0	0	0
16	6	12	0	0	0
17	6	13	0	0	0
18	6	12	0	0	0
19	6	12	0	0	0
20	6	14	0	0	0
21	6	12	0	0	0
22	6	15	0	0	0
23	6	11	0	0	0
24	6	13	0	0	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年4月27日 (水)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	13	1	0	1
2	6	13	0	0	1
3	6	14	0	0	0
4	6	14	0	0	0
5	6	13	0	0	0
6	6	13	1	0	0
7	6	14	0	0	0
8	6	12	0	0	0
9	6	14	0	0	0
10	6	13	0	0	0
11	6	11	1	0	0
12	6	13	0	0	0
13	6	14	0	0	0
14	6	13	0	0	0
15	6	13	0	0	0
16	6	12	1	0	0
17	6	13	1	0	0
18	6	13	1	0	0
19	6	14	1	0	0
20	6	13	1	0	0
21	6	13	0	0	1
22	6	13	0	0	1
23	6	13	1	0	1
24	6	11	1	0	1

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	14	0	0	0
2	6	13	0	0	0
3	6	13	0	0	0
4	6	12	0	0	0
5	6	13	0	0	0
6	6	14	0	0	0
7	6	13	0	0	0
8	6	15	0	0	0
9	6	11	0	0	0
10	6	13	0	0	0
11	6	13	0	0	0
12	6	12	0	0	0
13	6	15	0	0	0
14	6	15	0	0	0
15	6	9	0	0	0
16	6	12	0	0	0
17	6	14	0	0	0
18	6	13	0	0	0
19	6	14	0	0	0
20	6	14	0	0	0
21	6	14	0	0	0
22	6	11	0	0	0
23	6	13	0	0	0
24	6	9	0	0	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年4月28日 (木)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	11	0	0	1
2	6	14	1	0	1
3	6	13	1	0	1
4	6	12	0	0	1
5	6	11	0	0	1
6	6	13	1	0	1
7	6	14	0	0	1
8	6	13	0	0	1
9	6	13	0	0	1
10	6	12	1	0	1
11	6	11	1	0	1
12	6	13	1	0	1
13	6	14	1	0	1
14	6	13	0	0	1
15	6	11	0	0	1
16	6	12	1	0	1
17	6	13	1	0	1
18	6	13	1	0	0
19	6	13	1	0	0
20	6	12	0	0	1
21	6	11	0	0	0
22	6	12	1	0	0
23	6	14	1	0	0
24	6	13	0	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	13	0	0	0
2	6	13	0	0	0
3	6	14	0	0	0
4	6	12	0	0	0
5	6	15	0	0	0
6	6	11	0	0	0
7	6	11	0	0	0
8	6	15	0	0	0
9	7	14	1	0	0
10	6	13	0	0	0
11	6	11	0	0	0
12	6	14	0	0	0
13	6	13	0	0	0
14	7	12	0	0	0
15	----	----	----	----	----
16	----	----	----	----	----
17	----	----	----	----	----
18	----	----	----	----	----
19	4	5	0	0	0
20	5	12	0	0	0
21	5	12	0	0	0
22	5	12	0	0	0
23	5	14	0	0	0
24	6	11	0	0	0

※
※
※

※ 測定器点検のため、「----」表示としています。

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年4月29日 (金)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	13	1	0	1
2	6	12	0	0	1
3	6	12	0	0	0
4	6	12	0	0	0
5	6	13	1	0	0
6	6	13	0	0	0
7	6	13	0	0	0
8	6	13	0	0	0
9	6	13	0	0	0
10	6	14	1	0	0
11	6	12	0	0	0
12	6	14	0	0	0
13	6	13	1	0	0
14	6	14	0	0	0
15	6	12	1	0	0
16	6	14	0	0	0
17	6	13	0	0	0
18	6	14	1	0	0
19	6	12	0	0	0
20	6	13	0	0	0
21	6	13	1	0	0
22	6	13	0	0	0
23	6	14	1	0	0
24	6	13	0	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	13	0	0	0
2	6	13	0	0	0
3	6	14	0	0	0
4	6	10	0	0	0
5	6	14	0	0	0
6	6	12	0	0	0
7	6	13	0	0	0
8	6	12	0	0	0
9	6	12	0	0	0
10	6	14	0	0	0
11	6	12	0	0	0
12	6	11	0	0	0
13	6	11	0	0	0
14	6	13	0	0	0
15	6	11	0	0	0
16	6	12	0	0	0
17	6	13	0	0	0
18	6	16	0	0	0
19	6	8	0	0	0
20	6	11	0	0	0
21	6	13	0	0	0
22	6	14	0	0	0
23	6	15	0	0	0
24	6	10	0	0	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年4月30日 (土)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	13	0	0	0
2	6	13	0	0	0
3	6	12	0	0	0
4	6	13	0	0	0
5	6	13	0	0	0
6	6	13	0	0	0
7	6	12	0	0	0
8	5	13	1	0	0
9	6	11	0	0	0
10	6	13	0	0	0
11	6	14	0	0	0
12	6	13	0	0	0
13	6	14	1	0	0
14	6	14	1	0	0
15	6	14	0	0	0
16	6	11	0	0	0
17	6	13	1	0	0
18	6	13	0	0	0
19	6	12	1	0	0
20	6	13	1	0	0
21	6	13	0	0	0
22	6	14	0	0	0
23	6	12	0	0	0
24	6	13	0	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	12	0	0	0
2	6	13	0	0	0
3	6	14	0	0	0
4	6	15	0	0	0
5	6	10	0	0	0
6	6	14	0	0	0
7	6	13	0	0	0
8	6	13	0	0	0
9	6	14	0	0	0
10	6	11	0	0	0
11	6	14	0	0	0
12	6	12	0	0	0
13	6	15	0	0	0
14	6	12	0	0	0
15	6	15	0	0	0
16	6	13	0	0	0
17	6	13	0	0	0
18	6	14	0	0	0
19	6	13	0	0	0
20	6	13	0	0	0
21	6	12	0	0	0
22	6	15	0	0	0
23	6	12	0	0	0
24	6	14	0	0	0