

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年6月1日 (水)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	12	0	0	0
2	6	11	1	0	0
3	6	11	0	0	0
4	6	12	0	0	0
5	6	13	0	0	0
6	6	12	0	0	0
7	6	14	0	0	0
8	6	11	0	0	0
9	6	13	0	0	0
10	6	13	0	0	0
11	6	13	0	0	0
12	6	13	0	0	0
13	6	13	0	0	0
14	6	14	0	0	0
15	6	14	1	0	0
16	6	14	1	0	0
17	6	14	0	0	0
18	6	13	0	0	1
19	6	13	0	0	0
20	6	14	0	0	0
21	6	12	0	0	0
22	6	12	0	0	0
23	6	13	0	0	0
24	6	12	0	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	11	0	0	0
2	6	12	0	0	0
3	6	14	0	0	0
4	6	13	0	0	0
5	6	13	0	0	0
6	6	14	0	0	0
7	6	13	0	0	0
8	6	10	0	0	0
9	6	12	0	0	0
10	6	13	0	0	0
11	6	13	0	0	0
12	6	14	0	0	0
13	6	13	0	0	0
14	6	14	0	0	0
15	6	14	0	0	0
16	6	14	0	0	0
17	6	11	0	0	0
18	6	11	0	0	0
19	6	13	0	0	0
20	6	15	0	0	0
21	6	13	0	0	0
22	6	11	0	0	0
23	6	14	0	0	0
24	6	11	0	0	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年6月2日 (木)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	12	0	0	0
2	6	13	0	0	0
3	6	14	0	0	0
4	6	13	0	0	0
5	6	11	0	0	0
6	6	14	0	0	0
7	6	13	0	0	0
8	6	12	0	0	0
9	6	10	0	0	0
10	6	12	0	0	0
11	6	11	0	0	0
12	6	11	0	0	0
13	6	11	0	0	0
14	6	11	0	0	0
15	6	13	0	0	0
16	6	11	1	0	0
17	6	11	1	0	0
18	6	12	0	0	0
19	6	12	0	0	0
20	6	12	0	0	0
21	6	12	0	0	0
22	6	12	0	0	0
23	6	12	0	0	0
24	6	11	0	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	14	0	0	0
2	6	12	0	0	0
3	6	16	0	0	0
4	6	11	0	0	0
5	6	11	0	0	0
6	6	12	0	0	0
7	6	12	0	0	0
8	6	13	0	0	0
9	6	14	0	0	0
10	6	13	0	0	0
11	6	13	0	0	0
12	6	11	0	0	0
13	6	13	0	0	0
14	6	13	0	0	0
15	6	15	0	0	0
16	6	13	0	0	0
17	6	12	0	0	0
18	6	10	0	0	0
19	6	13	0	0	0
20	6	13	0	0	0
21	6	13	0	0	0
22	6	13	0	0	0
23	6	15	0	0	0
24	6	13	0	0	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年6月3日 (金)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	12	0	0	0
2	6	12	0	0	0
3	6	12	1	0	0
4	6	12	0	0	0
5	6	13	0	0	0
6	6	12	0	0	0
7	6	11	0	0	0
8	6	12	0	0	0
9	6	13	0	0	0
10	6	11	0	0	0
11	6	11	0	0	0
12	6	11	0	0	0
13	6	12	0	0	0
14	6	12	0	0	0
15	6	12	0	0	0
16	6	10	0	0	0
17	6	13	0	0	0
18	6	10	0	0	0
19	6	11	0	0	0
20	6	12	1	0	0
21	6	13	1	0	0
22	6	13	1	0	0
23	6	13	1	0	0
24	6	14	0	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	13	0	0	0
2	6	13	0	0	0
3	6	13	0	0	0
4	6	14	0	0	0
5	6	12	0	0	0
6	6	9	0	0	0
7	6	10	0	0	0
8	6	13	0	0	0
9	6	13	0	0	0
10	6	13	0	0	0
11	6	13	0	0	0
12	6	14	0	0	0
13	6	12	0	0	0
14	6	12	0	0	0
15	6	13	0	0	0
16	6	12	0	0	0
17	6	13	0	0	0
18	6	13	0	0	0
19	6	14	0	0	0
20	6	13	0	0	0
21	6	14	0	0	0
22	6	12	0	0	0
23	6	13	0	0	0
24	6	12	0	0	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年6月4日 (土)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	12	0	0	1
2	6	12	0	0	1
3	6	11	0	0	1
4	6	11	0	0	0
5	6	12	0	0	0
6	6	10	0	0	0
7	6	13	0	0	0
8	6	12	0	0	0
9	6	11	0	0	0
10	6	11	0	0	0
11	6	11	0	0	0
12	6	12	0	0	0
13	6	11	0	0	0
14	6	11	0	0	0
15	6	11	0	0	0
16	6	10	1	0	0
17	6	11	0	0	0
18	6	11	1	0	4
19	6	11	0	0	9
20	6	12	0	0	3
21	6	10	0	0	2
22	6	10	0	0	1
23	6	11	0	0	1
24	6	11	0	0	1

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	14	0	0	0
2	6	14	0	0	0
3	6	12	0	0	0
4	6	11	0	0	0
5	6	10	0	0	0
6	6	13	0	0	0
7	6	12	0	0	1
8	6	11	0	0	0
9	6	12	0	0	0
10	6	13	0	0	0
11	6	13	0	0	0
12	6	13	0	0	0
13	6	13	0	0	0
14	6	13	0	0	0
15	6	13	0	0	0
16	6	12	0	0	0
17	6	14	0	0	0
18	6	12	0	0	0
19	6	12	0	0	0
20	6	13	0	0	0
21	6	14	0	0	0
22	6	14	0	0	0
23	6	14	0	0	0
24	6	10	0	0	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年6月5日 (日)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	11	0	0	1
2	6	11	0	0	1
3	6	11	0	0	1
4	6	10	0	0	0
5	6	12	0	0	0
6	6	12	0	0	0
7	6	12	0	0	0
8	6	12	0	0	0
9	6	12	0	0	0
10	6	14	0	0	0
11	6	13	0	0	0
12	6	13	0	0	0
13	6	14	0	0	0
14	6	13	0	0	0
15	6	13	0	0	0
16	6	13	0	0	0
17	6	13	0	0	0
18	6	13	0	0	0
19	6	13	0	0	0
20	6	14	0	0	0
21	6	12	0	0	0
22	6	12	0	0	0
23	6	12	0	0	0
24	6	12	0	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	13	0	0	0
2	6	12	0	0	0
3	6	13	0	0	0
4	6	12	0	0	0
5	6	13	0	0	0
6	6	12	0	0	0
7	6	13	0	0	0
8	6	12	0	0	0
9	6	13	0	0	0
10	6	13	0	0	0
11	6	14	0	0	0
12	6	14	0	0	0
13	6	13	0	0	0
14	6	12	0	0	0
15	6	11	0	0	0
16	6	14	0	0	0
17	6	14	0	0	0
18	6	12	0	0	0
19	6	13	0	0	0
20	6	14	0	0	0
21	6	13	0	0	0
22	6	13	0	0	0
23	6	13	0	0	0
24	6	15	0	0	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年6月6日 (月)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	12	0	0	0
2	6	13	1	0	0
3	6	13	0	0	0
4	6	12	0	0	0
5	6	12	0	0	0
6	6	13	0	0	0
7	6	13	1	0	0
8	6	13	0	0	0
9	6	12	0	0	0
10	6	13	0	0	0
11	6	13	0	0	0
12	6	13	0	0	0
13	6	12	0	0	0
14	6	13	0	0	0
15	6	13	0	0	0
16	6	12	0	0	0
17	6	13	0	0	0
18	6	13	0	0	0
19	6	13	0	0	0
20	6	11	1	0	0
21	6	13	0	0	0
22	6	13	0	0	0
23	6	13	0	0	0
24	6	13	0	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	14	0	0	0
2	6	13	0	0	0
3	6	13	0	0	0
4	6	15	0	0	0
5	6	14	0	0	0
6	6	12	0	0	0
7	5	14	0	0	0
8	5	13	0	0	0
9	5	14	0	0	0
10	6	13	0	0	0
11	6	13	0	0	0
12	6	13	0	0	0
13	6	14	0	0	0
14	6	13	0	0	0
15	6	14	0	0	0
16	6	13	0	0	0
17	6	14	0	0	0
18	6	13	0	0	0
19	6	14	0	0	0
20	6	15	0	0	0
21	6	12	0	0	0
22	6	13	0	0	0
23	6	13	0	0	0
24	6	13	0	0	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年6月7日 (火)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	12	0	0	0
2	6	13	0	0	0
3	6	13	0	0	0
4	6	14	0	0	0
5	6	13	0	0	0
6	6	13	0	0	0
7	6	14	0	0	0
8	6	14	0	0	0
9	6	13	0	0	0
10	6	12	0	0	0
11	6	12	0	0	0
12	6	13	0	0	0
13	6	13	0	0	0
14	6	13	0	0	0
15	6	13	0	0	0
16	6	13	0	0	0
17	6	12	0	0	0
18	6	12	0	0	0
19	6	13	0	0	0
20	6	13	0	0	0
21	6	13	0	0	0
22	6	12	0	0	0
23	6	13	0	0	0
24	6	13	0	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	13	0	0	0
2	6	15	0	0	0
3	6	14	0	0	0
4	6	13	0	0	0
5	6	12	0	0	0
6	6	14	0	0	0
7	6	13	0	0	0
8	6	14	0	0	0
9	6	13	0	0	0
10	6	15	0	0	0
11	6	13	0	0	0
12	6	15	0	0	0
13	6	14	0	0	0
14	6	15	0	0	0
15	6	12	0	0	0
16	6	12	0	0	0
17	6	16	0	0	0
18	6	12	0	0	0
19	6	9	0	0	0
20	6	13	0	0	0
21	6	13	0	0	0
22	6	13	0	0	0
23	6	13	0	0	0
24	6	11	0	0	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年6月8日 (水)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	13	0	0	0
2	6	13	0	0	0
3	6	13	0	0	0
4	6	13	0	0	0
5	6	13	0	0	0
6	6	13	0	0	0
7	6	13	0	0	0
8	6	12	0	0	0
9	6	9	1	0	0
10	6	11	0	0	0
11	6	12	0	0	0
12	6	11	0	0	0
13	6	9	0	0	0
14	6	11	1	0	0
15	6	13	0	0	0
16	6	12	1	0	0
17	6	12	0	0	0
18	6	12	0	0	0
19	6	12	0	0	0
20	6	12	1	0	3
21	6	12	0	0	1
22	6	14	1	0	1
23	6	11	1	0	0
24	6	12	0	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	13	0	0	0
2	6	12	0	0	0
3	6	12	0	0	0
4	6	14	0	0	0
5	6	13	0	0	0
6	6	14	0	0	0
7	6	11	0	0	0
8	6	10	0	0	0
9	6	11	0	0	0
10	6	13	0	0	0
11	6	12	0	0	0
12	6	12	0	0	0
13	6	12	0	0	0
14	6	13	0	0	0
15	6	11	0	0	0
16	6	12	0	0	0
17	6	14	0	0	0
18	6	12	0	0	0
19	6	12	0	0	0
20	6	10	0	0	0
21	6	13	0	0	0
22	6	12	0	0	0
23	6	12	0	0	0
24	6	12	0	0	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年6月9日 (木)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	13	0	0	0
2	6	13	0	0	0
3	6	14	0	0	0
4	6	13	0	0	0
5	6	13	0	0	0
6	6	14	0	0	0
7	6	11	0	0	1
8	6	14	0	0	1
9	6	12	0	0	0
10	6	11	0	0	0
11	6	11	0	0	0
12	6	12	0	0	0
13	6	12	0	0	0
14	6	12	0	0	0
15	6	13	0	0	0
16	6	12	0	0	0
17	6	11	0	0	0
18	6	12	0	0	0
19	6	13	0	0	0
20	6	12	0	0	0
21	6	12	0	0	0
22	6	13	0	0	0
23	6	12	1	0	0
24	6	14	0	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	13	0	0	0
2	6	13	0	0	0
3	6	11	0	0	0
4	6	13	0	0	0
5	6	13	0	0	0
6	6	12	0	0	0
7	6	13	0	0	0
8	6	15	0	0	0
9	6	10	0	0	0
10	6	10	0	0	0
11	6	13	0	0	0
12	6	12	0	0	0
13	6	13	0	0	0
14	6	13	0	0	0
15	6	14	0	0	0
16	6	13	0	0	0
17	6	13	0	0	0
18	6	14	0	0	0
19	6	13	0	0	0
20	6	12	0	0	0
21	6	11	0	0	0
22	6	14	0	0	0
23	6	14	0	0	0
24	6	11	0	0	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年6月10日 (金)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	14	0	0	0
2	6	13	0	0	0
3	6	12	0	0	0
4	6	11	1	0	0
5	6	13	1	0	0
6	6	12	0	0	0
7	6	11	0	0	0
8	6	12	0	0	0
9	6	12	0	0	0
10	6	11	0	0	0
11	6	12	0	0	0
12	6	12	1	0	0
13	6	12	0	0	0
14	6	12	0	0	0
15	6	11	0	0	0
16	6	13	0	0	0
17	6	13	0	0	0
18	6	13	0	0	0
19	6	12	0	0	0
20	6	14	0	0	0
21	6	11	0	0	0
22	6	12	0	0	0
23	6	13	0	0	0
24	6	12	0	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	11	0	0	0
2	6	12	0	0	0
3	6	13	0	0	0
4	6	13	0	0	0
5	6	12	0	0	0
6	6	13	0	0	0
7	6	13	0	0	0
8	6	12	0	0	0
9	6	13	0	0	0
10	6	12	0	0	0
11	6	13	0	0	0
12	6	14	0	0	0
13	6	13	0	0	0
14	6	12	0	0	0
15	6	13	0	0	0
16	6	13	0	0	0
17	6	11	0	0	0
18	6	15	0	0	0
19	6	13	0	0	0
20	6	11	0	0	0
21	6	13	0	0	0
22	6	13	0	0	0
23	6	13	0	0	0
24	6	11	0	0	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年6月11日 (土)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	14	0	0	0
2	6	12	1	0	0
3	6	12	0	0	0
4	6	13	0	0	0
5	6	12	0	0	0
6	6	11	0	0	0
7	6	12	0	0	0
8	6	14	0	0	0
9	6	12	0	0	0
10	6	11	0	0	0
11	6	11	1	0	0
12	6	11	0	0	0
13	6	13	0	0	0
14	6	11	0	0	0
15	6	12	0	0	0
16	6	13	0	0	0
17	6	12	0	0	0
18	6	14	1	0	0
19	6	12	0	0	0
20	6	12	0	0	0
21	6	13	0	0	0
22	6	13	0	0	0
23	6	11	0	0	0
24	6	12	0	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	14	0	0	0
2	6	14	0	0	0
3	6	14	0	0	0
4	6	12	0	0	0
5	6	12	0	0	0
6	6	12	0	0	0
7	6	10	0	0	0
8	6	12	0	0	0
9	6	12	0	0	0
10	6	12	0	0	0
11	6	12	0	0	0
12	6	11	0	0	0
13	6	12	0	0	0
14	6	11	0	0	0
15	6	12	0	0	0
16	6	10	0	0	0
17	6	11	0	0	0
18	6	10	0	0	0
19	6	12	0	0	0
20	6	11	0	0	0
21	6	12	0	0	0
22	6	11	0	0	0
23	6	11	0	0	0
24	6	13	0	0	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年6月12日 (日)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	13	0	0	0
2	6	13	0	0	0
3	6	12	0	0	0
4	6	13	0	0	0
5	6	11	0	0	0
6	6	13	0	0	1
7	6	13	0	0	0
8	6	13	0	0	0
9	6	12	0	0	0
10	6	12	0	0	0
11	6	13	1	0	0
12	6	13	0	0	0
13	6	12	0	0	0
14	6	13	0	0	0
15	6	12	0	0	0
16	6	11	0	0	0
17	6	13	0	0	0
18	6	11	0	0	0
19	6	10	0	0	0
20	6	11	0	0	0
21	6	12	0	0	0
22	6	13	0	0	0
23	6	13	0	0	0
24	6	11	0	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	11	0	0	0
2	6	12	0	0	0
3	6	11	0	0	0
4	6	13	0	0	0
5	6	12	0	0	0
6	6	12	0	0	0
7	6	12	0	0	0
8	6	12	0	0	0
9	6	12	0	0	0
10	6	13	0	0	0
11	6	12	0	0	0
12	6	13	0	0	0
13	6	10	0	0	0
14	6	12	0	0	0
15	6	9	0	0	0
16	6	10	0	0	0
17	6	12	0	0	0
18	6	12	0	0	0
19	6	10	0	0	0
20	6	10	0	0	0
21	5	10	0	0	0
22	6	12	0	0	0
23	6	11	0	0	0
24	6	10	0	0	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年6月13日 (月)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	12	0	0	0
2	6	12	0	0	0
3	6	13	0	0	0
4	6	11	0	0	0
5	6	12	0	0	0
6	6	12	0	0	1
7	6	12	0	0	0
8	6	12	0	0	0
9	6	13	0	0	0
10	6	12	0	0	0
11	6	12	0	0	0
12	6	12	0	0	0
13	6	12	0	0	0
14	6	12	0	0	0
15	6	12	0	0	0
16	6	14	0	0	0
17	6	14	0	0	0
18	6	13	0	0	0
19	5	12	0	0	0
20	6	13	0	0	0
21	5	13	0	0	0
22	6	13	0	0	0
23	6	13	0	0	0
24	6	13	0	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	12	0	0	0
2	6	13	0	0	0
3	6	12	0	0	0
4	6	11	0	0	0
5	6	11	0	0	0
6	5	12	0	0	0
7	6	13	0	0	0
8	6	12	0	0	0
9	6	12	0	0	0
10	6	12	0	0	0
11	5	13	0	0	0
12	6	13	0	0	0
13	6	12	0	0	0
14	6	12	0	0	0
15	6	13	0	0	0
16	6	13	0	0	0
17	6	11	0	0	0
18	6	11	0	0	0
19	6	12	0	0	0
20	6	11	0	0	0
21	6	12	0	0	0
22	6	12	0	0	0
23	6	13	0	0	0
24	6	12	0	0	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年6月14日 (火)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	13	0	0	0
2	6	12	0	0	0
3	6	12	0	0	0
4	6	12	0	0	0
5	6	14	1	0	0
6	6	13	0	0	0
7	6	13	0	0	0
8	6	12	0	0	0
9	6	13	0	0	0
10	6	14	0	0	0
11	6	12	0	0	0
12	6	13	0	0	0
13	6	13	0	0	0
14	6	12	0	0	0
15	6	13	0	0	0
16	6	12	0	0	0
17	6	11	0	0	0
18	6	13	0	0	0
19	6	14	0	0	0
20	6	12	0	0	0
21	6	13	0	0	0
22	6	11	0	0	0
23	6	11	0	0	0
24	5	13	0	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	12	0	0	0
2	6	11	0	0	0
3	6	12	0	0	0
4	6	11	0	0	0
5	6	9	0	0	0
6	6	12	0	0	0
7	6	11	0	0	0
8	6	12	0	0	0
9	6	13	0	0	0
10	6	11	0	0	0
11	6	11	0	0	0
12	6	12	0	0	0
13	6	13	0	0	0
14	6	11	0	0	0
15	6	11	0	0	0
16	6	12	0	0	0
17	6	12	0	0	0
18	6	12	0	0	0
19	6	13	0	0	0
20	6	13	0	0	0
21	6	13	0	0	0
22	6	12	0	0	0
23	5	12	0	0	0
24	5	14	0	0	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年6月15日 (水)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	4	13	0	0	0
2	6	13	0	0	0
3	5	13	0	0	0
4	6	13	0	0	0
5	6	13	0	0	0
6	6	13	0	0	0
7	6	13	1	0	0
8	6	13	0	0	0
9	6	14	0	0	0
10	6	11	0	0	0
11	6	13	0	0	0
12	6	13	0	0	0
13	6	12	0	0	0
14	6	12	0	0	0
15	6	12	0	0	0
16	6	12	0	0	0
17	6	12	1	0	0
18	6	13	0	0	0
19	6	11	0	0	0
20	5	13	0	0	0
21	5	10	0	0	0
22	5	13	0	0	0
23	5	12	0	0	0
24	4	13	0	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	13	0	0	0
2	5	13	0	0	0
3	5	15	0	0	0
4	6	15	0	0	0
5	6	12	0	0	0
6	6	11	0	0	0
7	6	13	0	0	0
8	6	13	0	0	0
9	6	13	0	0	0
10	6	12	0	0	0
11	6	10	0	0	0
12	6	12	0	0	0
13	6	12	0	0	0
14	6	11	0	0	0
15	6	13	0	0	0
16	6	12	0	0	0
17	6	13	0	0	0
18	6	13	0	0	0
19	6	13	0	0	0
20	5	11	0	0	0
21	5	13	0	0	0
22	5	12	0	0	0
23	5	12	0	0	0
24	5	12	0	0	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年6月16日 (木)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	4	13	0	0	0
2	4	13	0	0	0
3	4	13	0	0	0
4	4	13	0	0	0
5	4	11	0	0	0
6	4	12	0	0	0
7	5	14	0	0	0
8	6	13	1	0	0
9	6	14	0	0	0
10	6	14	0	0	0
11	6	14	0	0	0
12	6	12	0	0	0
13	6	12	0	0	0
14	6	14	0	0	0
15	6	13	0	0	0
16	6	12	0	0	0
17	6	13	0	0	0
18	6	12	0	0	0
19	6	14	0	0	0
20	6	12	0	0	0
21	6	13	0	0	0
22	6	13	0	0	0
23	6	13	0	0	0
24	4	9	0	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	13	0	0	0
2	4	13	0	0	0
3	5	13	0	0	0
4	5	11	0	0	0
5	5	13	0	0	0
6	4	13	0	0	0
7	5	13	0	0	0
8	5	13	0	0	0
9	5	11	0	0	0
10	5	14	0	0	0
11	5	13	0	0	0
12	6	13	0	0	0
13	6	12	0	0	0
14	6	12	0	0	0
15	6	12	0	0	0
16	6	12	0	0	0
17	6	14	0	0	0
18	6	13	0	0	0
19	6	10	0	0	0
20	6	12	0	0	0
21	6	12	0	0	0
22	6	13	0	0	0
23	6	12	0	0	0
24	6	12	0	0	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年6月17日 (金)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	11	0	0	0
2	4	13	0	0	0
3	4	13	0	0	0
4	5	12	0	0	0
5	4	11	0	0	0
6	4	12	0	0	0
7	4	12	0	0	0
8	4	12	0	0	0
9	4	13	0	0	0
10	6	12	0	0	0
11	6	13	0	0	0
12	6	13	0	0	0
13	6	13	0	0	0
14	6	12	0	0	0
15	6	13	0	0	0
16	6	13	0	0	0
17	6	12	0	0	0
18	6	12	0	0	0
19	6	12	0	0	0
20	6	12	0	0	0
21	6	12	1	0	0
22	6	12	0	0	0
23	6	12	0	0	0
24	6	13	0	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	13	0	0	0
2	6	13	0	0	0
3	6	9	0	0	0
4	6	12	0	0	0
5	6	12	0	0	0
6	6	11	0	0	0
7	6	11	0	0	0
8	5	12	0	0	0
9	6	13	0	0	0
10	6	14	0	0	0
11	6	10	0	0	0
12	6	12	0	0	0
13	6	11	0	0	0
14	6	12	0	0	0
15	6	12	0	0	0
16	6	10	0	0	0
17	6	11	0	0	0
18	6	11	0	0	0
19	6	12	0	0	0
20	6	12	0	0	0
21	6	13	0	0	0
22	6	12	0	0	0
23	6	11	0	0	0
24	6	11	0	0	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年6月18日 (土)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	14	0	0	0
2	6	12	1	0	0
3	6	13	0	0	0
4	6	13	1	0	0
5	6	13	0	0	0
6	6	10	0	0	0
7	6	13	0	0	0
8	6	13	0	0	0
9	6	12	0	0	0
10	6	13	0	0	0
11	6	13	0	0	0
12	6	11	0	0	0
13	6	12	1	0	0
14	6	13	0	0	0
15	6	12	0	0	0
16	6	13	0	0	0
17	6	12	0	0	0
18	6	13	0	0	0
19	6	13	0	0	0
20	6	14	0	0	0
21	6	11	0	0	0
22	6	12	0	0	0
23	6	13	0	0	0
24	6	13	0	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	13	0	0	0
2	6	16	0	0	0
3	6	11	0	0	0
4	6	12	0	0	0
5	6	11	0	0	0
6	6	12	0	0	0
7	6	13	0	0	0
8	6	12	0	0	0
9	6	11	0	0	0
10	6	13	0	0	0
11	6	13	0	0	0
12	6	13	0	0	0
13	6	12	0	0	0
14	6	13	0	0	0
15	6	12	0	0	0
16	6	12	0	0	0
17	6	13	0	0	0
18	6	12	0	0	0
19	6	11	0	0	0
20	6	13	0	0	0
21	6	14	0	0	0
22	6	13	0	0	0
23	6	13	0	0	0
24	6	12	0	0	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年6月19日 (日)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	12	0	0	0
2	6	14	0	0	1
3	6	13	0	0	0
4	6	12	0	0	0
5	6	14	0	0	0
6	6	11	0	0	0
7	6	14	1	0	0
8	6	12	0	0	0
9	6	14	0	0	0
10	6	11	0	0	0
11	6	14	0	0	0
12	6	12	0	0	0
13	6	13	0	0	0
14	6	12	0	0	0
15	6	12	0	0	0
16	6	12	0	0	0
17	6	12	0	0	0
18	6	13	0	0	0
19	6	13	0	0	0
20	6	13	0	0	0
21	6	13	0	0	0
22	6	13	0	0	0
23	6	13	1	0	0
24	6	11	0	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	13	0	0	0
2	6	12	0	0	0
3	6	13	0	0	0
4	6	14	0	0	0
5	6	11	0	0	0
6	6	10	0	0	0
7	6	12	0	0	0
8	6	13	0	0	0
9	6	11	0	0	0
10	6	10	0	0	0
11	6	13	0	0	0
12	6	11	0	0	0
13	6	11	0	0	0
14	6	13	0	0	0
15	6	11	0	0	0
16	6	12	0	0	0
17	6	12	0	0	0
18	6	14	0	0	0
19	6	13	0	0	1
20	6	11	0	0	0
21	6	13	0	0	0
22	6	12	0	0	0
23	6	12	0	0	0
24	6	14	0	0	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年6月20日 (月)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	13	0	0	0
2	6	12	0	0	0
3	6	13	0	0	0
4	6	12	0	0	0
5	6	13	0	0	0
6	6	14	0	0	0
7	6	13	0	0	0
8	6	13	0	0	0
9	6	12	0	0	0
10	6	13	0	0	0
11	6	14	1	0	0
12	6	13	0	0	0
13	6	14	1	0	0
14	6	13	0	0	0
15	6	14	0	0	0
16	6	13	0	0	0
17	6	11	0	0	0
18	6	13	0	0	0
19	6	14	0	0	0
20	6	12	1	0	0
21	6	11	0	0	0
22	6	12	0	0	0
23	6	11	0	0	0
24	6	12	0	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	13	0	0	0
2	6	12	0	0	0
3	6	14	0	0	0
4	6	14	0	0	0
5	6	13	0	0	0
6	6	15	0	0	0
7	6	11	0	0	0
8	6	11	0	0	0
9	6	12	0	0	0
10	6	12	0	0	0
11	6	14	0	0	0
12	6	13	0	0	0
13	6	11	0	0	1
14	6	12	0	0	0
15	6	13	0	0	0
16	6	12	0	0	0
17	6	12	0	0	0
18	6	13	0	0	0
19	6	12	0	0	0
20	6	12	0	0	0
21	6	13	0	0	0
22	6	11	0	0	0
23	6	13	0	0	0
24	6	13	0	0	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年6月21日 (火)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	11	0	0	0
2	6	11	0	0	0
3	6	13	1	0	0
4	6	12	0	0	0
5	6	12	0	0	0
6	6	12	0	0	0
7	6	13	0	0	0
8	6	10	0	0	0
9	6	13	0	0	0
10	6	13	1	0	0
11	6	13	0	0	0
12	6	12	0	0	0
13	6	13	0	0	0
14	6	12	0	0	0
15	6	14	0	0	0
16	6	11	0	0	0
17	6	14	0	0	0
18	6	12	0	0	0
19	6	11	0	0	0
20	6	13	0	0	0
21	6	13	0	0	0
22	6	12	0	0	0
23	6	13	0	0	0
24	6	12	0	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	14	0	0	0
2	6	13	0	0	0
3	6	11	0	0	0
4	6	13	0	0	0
5	6	13	0	0	0
6	6	14	0	0	0
7	6	10	0	0	0
8	6	11	0	0	0
9	6	15	0	0	0
10	6	15	0	0	0
11	6	11	0	0	0
12	6	12	0	0	0
13	6	14	0	0	0
14	6	13	0	0	0
15	6	13	0	0	0
16	6	12	0	0	0
17	6	13	0	0	0
18	6	11	0	0	0
19	6	11	0	0	0
20	6	13	0	0	0
21	6	12	0	0	0
22	6	12	0	0	0
23	6	13	0	0	0
24	6	13	0	0	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年6月22日 (水)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	12	0	0	0
2	6	13	0	0	0
3	6	14	0	0	0
4	6	12	0	0	0
5	6	12	0	0	0
6	6	12	0	0	0
7	6	13	0	0	0
8	6	14	0	0	0
9	6	11	0	0	0
10	6	12	0	0	0
11	6	11	0	0	0
12	6	14	0	0	0
13	6	12	0	0	0
14	6	12	0	0	0
15	6	13	0	0	0
16	6	11	0	0	0
17	6	12	1	0	0
18	6	14	0	0	0
19	6	12	0	0	1
20	6	14	0	0	0
21	6	13	0	0	0
22	6	11	0	0	0
23	6	13	0	0	0
24	6	14	0	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	13	0	0	0
2	6	12	0	0	0
3	6	12	0	0	0
4	6	12	0	0	0
5	6	11	0	0	0
6	6	12	0	0	0
7	6	12	0	0	0
8	6	12	0	0	0
9	6	12	0	0	0
10	6	12	0	0	0
11	6	12	0	0	0
12	6	11	0	0	0
13	6	12	0	0	0
14	6	11	0	0	0
15	6	10	0	0	0
16	6	10	0	0	0
17	6	14	0	0	0
18	6	14	0	0	0
19	6	13	0	0	0
20	6	13	0	0	0
21	6	12	0	0	0
22	6	12	0	0	0
23	6	13	0	0	0
24	6	12	0	0	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年6月23日 (木)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	13	0	0	0
2	6	12	0	0	0
3	6	11	0	0	0
4	6	13	0	0	0
5	6	13	0	0	0
6	6	11	0	0	0
7	6	14	0	0	0
8	6	13	0	0	0
9	6	13	1	0	0
10	6	12	0	0	0
11	6	14	0	0	0
12	6	11	1	0	0
13	6	13	0	0	0
14	6	11	1	0	0
15	6	12	0	0	0
16	6	12	1	0	0
17	6	13	1	0	0
18	6	13	1	0	0
19	6	15	0	0	0
20	6	12	1	0	0
21	6	11	0	0	0
22	6	11	0	0	0
23	6	12	0	0	0
24	6	11	1	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	11	0	0	0
2	6	13	0	0	0
3	6	13	0	0	0
4	6	12	0	0	1
5	6	13	0	0	0
6	6	15	1	0	0
7	6	11	0	0	1
8	6	12	0	0	0
9	6	12	0	0	0
10	6	13	0	0	0
11	6	12	0	0	0
12	6	12	0	0	0
13	6	12	0	0	0
14	6	12	0	0	0
15	6	12	0	0	0
16	6	11	0	0	0
17	6	11	0	0	0
18	6	13	0	0	0
19	6	13	0	0	0
20	6	13	0	0	0
21	6	12	0	0	0
22	6	13	0	0	0
23	6	13	0	0	0
24	6	13	0	0	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年6月24日 (金)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	12	0	0	0
2	6	13	0	0	0
3	6	12	0	0	0
4	6	13	0	0	0
5	6	11	0	0	0
6	6	10	0	0	0
7	6	13	0	0	0
8	6	12	0	0	0
9	6	13	0	0	0
10	6	14	0	0	0
11	6	12	1	0	0
12	6	11	0	0	0
13	6	11	0	0	0
14	6	12	0	0	0
15	6	14	1	0	0
16	6	14	1	0	0
17	6	13	1	0	0
18	6	12	1	0	0
19	6	13	1	0	0
20	6	13	1	0	0
21	6	14	1	0	0
22	6	10	1	0	0
23	6	10	1	0	0
24	6	11	0	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	13	0	0	0
2	6	10	0	0	0
3	6	14	0	0	0
4	6	14	0	0	0
5	6	13	0	0	0
6	6	12	0	0	0
7	6	11	0	0	0
8	6	13	0	0	0
9	6	12	0	0	0
10	6	12	0	0	0
11	6	11	0	0	0
12	6	12	0	0	0
13	6	10	0	0	0
14	6	12	0	0	0
15	6	13	0	0	0
16	6	10	0	0	0
17	6	13	0	0	0
18	6	10	0	0	1
19	6	13	0	0	0
20	6	12	0	0	0
21	6	11	0	0	0
22	6	13	0	0	0
23	6	11	0	0	0
24	6	11	0	0	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年6月25日 (土)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	13	1	0	0
2	6	11	1	0	0
3	6	13	0	0	0
4	6	11	0	0	0
5	6	12	1	0	0
6	6	12	0	0	0
7	6	13	1	0	0
8	6	13	1	0	0
9	6	11	1	0	0
10	6	13	0	0	0
11	6	13	0	0	0
12	6	13	1	0	0
13	6	13	1	0	0
14	6	12	1	0	0
15	6	12	1	0	0
16	6	13	0	0	0
17	6	12	1	0	0
18	6	14	1	0	0
19	6	11	0	0	0
20	6	12	1	0	0
21	6	11	1	0	0
22	6	13	0	0	0
23	6	12	0	0	0
24	6	12	1	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	13	0	0	0
2	6	11	0	0	0
3	6	12	0	0	0
4	6	12	0	0	0
5	6	11	0	0	0
6	6	12	0	0	0
7	6	11	0	0	0
8	6	12	0	0	0
9	6	13	0	0	0
10	6	11	0	0	0
11	6	11	0	0	0
12	6	12	0	0	0
13	6	14	0	0	0
14	6	11	0	0	0
15	6	11	0	0	0
16	6	12	0	0	0
17	6	13	0	0	0
18	6	13	0	0	0
19	6	11	0	0	0
20	6	11	0	0	0
21	6	12	0	0	0
22	6	12	0	0	0
23	6	11	0	0	0
24	6	12	2	0	1

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年6月26日 (日)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	11	0	0	0
2	6	12	0	0	0
3	6	12	0	0	0
4	6	12	0	0	0
5	6	12	0	0	0
6	6	11	0	0	0
7	6	14	0	0	0
8	6	12	0	0	0
9	6	12	0	0	0
10	6	12	0	0	0
11	6	11	0	0	0
12	6	13	0	0	0
13	6	12	1	0	0
14	6	12	0	0	0
15	6	12	1	0	0
16	6	13	1	0	0
17	6	12	1	0	0
18	6	14	1	0	0
19	6	12	1	0	0
20	6	14	1	0	0
21	6	11	1	0	0
22	6	13	1	0	0
23	6	13	1	0	0
24	6	11	0	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	13	0	0	0
2	6	14	0	0	0
3	6	14	0	0	0
4	6	12	0	0	0
5	6	12	0	0	0
6	6	14	1	0	0
7	6	11	0	0	0
8	6	12	0	0	0
9	6	13	0	0	0
10	6	13	0	0	0
11	6	12	0	0	0
12	6	11	0	0	0
13	6	12	0	0	0
14	6	11	0	0	0
15	6	12	0	0	0
16	6	11	0	0	0
17	6	12	0	0	0
18	6	13	0	0	0
19	6	14	0	0	0
20	6	14	0	0	0
21	6	11	0	0	0
22	6	14	0	0	0
23	6	15	0	0	0
24	6	11	0	0	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年6月27日 (月)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	14	0	0	0
2	6	10	0	0	0
3	6	15	0	0	0
4	6	12	0	0	0
5	6	9	0	0	0
6	6	12	0	0	0
7	6	14	0	0	0
8	6	11	0	0	0
9	6	13	0	0	0
10	6	12	1	0	0
11	6	11	0	0	0
12	6	12	0	0	0
13	6	12	0	0	0
14	6	11	0	0	0
15	6	13	1	0	0
16	6	13	1	0	0
17	6	10	0	0	0
18	6	15	0	0	0
19	6	13	0	0	0
20	6	12	0	0	0
21	6	11	0	0	0
22	6	11	0	0	0
23	6	14	0	0	0
24	6	13	0	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	13	0	0	0
2	6	12	0	0	0
3	6	13	0	0	0
4	6	12	0	0	0
5	6	13	0	0	0
6	6	14	0	0	0
7	6	14	0	0	0
8	6	14	0	0	0
9	6	12	0	0	0
10	6	12	0	0	22
11	6	12	0	0	18
12	6	13	0	0	10
13	6	13	0	0	9
14	6	13	0	0	7
15	6	12	0	0	7
16	6	12	0	0	4
17	6	12	0	0	4
18	6	12	0	0	3
19	6	12	0	0	3
20	6	14	0	0	2
21	6	12	0	0	2
22	6	12	0	0	1
23	6	12	0	0	2
24	6	11	0	0	1

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年6月28日 (火)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	11	0	0	0
2	6	13	0	0	0
3	6	13	0	0	0
4	6	12	0	0	0
5	6	13	0	0	0
6	6	12	0	0	0
7	6	12	0	0	0
8	6	13	0	0	0
9	6	14	0	0	0
10	6	12	0	0	0
11	6	13	0	0	0
12	6	13	0	0	0
13	6	13	0	0	0
14	6	13	1	0	0
15	6	14	0	0	0
16	6	12	0	0	0
17	6	13	0	0	0
18	6	13	0	0	0
19	6	14	0	0	0
20	6	11	1	0	0
21	6	13	0	0	0
22	6	12	0	0	0
23	6	11	0	0	0
24	6	12	0	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	14	0	0	1
2	6	12	0	0	1
3	6	10	0	0	1
4	6	13	0	0	1
5	6	13	0	0	1
6	6	13	0	0	1
7	6	13	0	0	1
8	6	12	0	0	1
9	6	12	0	0	1
10	6	12	0	0	1
11	6	13	0	0	1
12	6	12	0	0	1
13	6	12	0	0	1
14	6	13	0	0	1
15	5	12	0	0	1
16	6	13	0	0	1
17	5	13	0	0	1
18	6	13	0	0	1
19	6	12	0	0	1
20	5	12	0	0	1
21	5	13	0	0	0
22	4	12	0	0	1
23	4	13	0	0	0
24	5	13	0	0	1

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年6月29日 (水)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	13	0	0	0
2	6	11	0	0	0
3	6	12	0	0	0
4	6	11	0	0	0
5	6	12	0	0	0
6	6	11	0	0	0
7	6	12	0	0	0
8	5	12	0	0	0
9	6	12	0	0	0
10	6	14	0	0	0
11	6	10	0	0	0
12	6	13	1	0	0
13	6	11	0	0	0
14	6	13	0	0	0
15	6	13	0	0	0
16	6	15	0	0	0
17	6	12	0	0	0
18	6	12	0	0	0
19	6	12	0	0	0
20	6	13	0	0	0
21	6	12	0	0	0
22	6	13	1	0	0
23	6	13	0	0	0
24	6	12	0	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	11	0	0	0
2	6	12	0	0	0
3	5	12	0	0	0
4	5	14	0	0	0
5	4	13	0	0	0
6	5	12	0	0	0
7	5	13	0	0	0
8	4	12	0	0	0
9	5	12	0	0	0
10	5	13	0	0	1
11	4	14	0	0	1
12	5	13	0	0	1
13	6	10	0	0	0
14	6	11	0	0	0
15	4	13	0	0	0
16	4	12	0	0	0
17	5	12	0	0	0
18	5	12	0	0	0
19	4	12	0	0	0
20	5	12	0	0	0
21	6	11	0	0	0
22	6	11	0	0	0
23	5	13	0	0	0
24	5	11	0	0	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2022年6月30日 (木)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	12	0	0	0
2	6	12	0	0	0
3	6	13	0	0	0
4	6	13	0	0	0
5	6	14	0	0	0
6	6	12	0	0	0
7	6	13	0	0	0
8	6	13	0	0	0
9	6	13	1	0	0
10	6	13	0	0	0
11	6	13	1	0	0
12	6	12	0	0	1
13	6	13	0	0	1
14	6	12	0	0	1
15	6	13	0	0	0
16	6	13	0	0	0
17	6	13	0	0	0
18	6	14	1	0	0
19	6	11	0	0	0
20	6	14	1	0	0
21	6	13	0	0	0
22	6	13	0	0	0
23	6	13	0	0	0
24	6	13	0	0	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	12	0	0	0
2	4	12	0	0	0
3	5	13	0	0	0
4	5	12	0	0	0
5	6	12	0	0	0
6	6	10	0	0	0
7	4	8	0	0	0
8	5	11	0	0	0
9	5	11	0	0	0
10	5	11	0	0	0
11	6	12	0	0	0
12	6	12	0	0	0
13	6	11	0	0	0
14	5	12	0	0	0
15	5	11	0	0	0
16	6	12	0	0	0
17	5	11	0	0	0
18	4	10	0	0	0
19	4	10	0	0	0
20	4	12	0	0	0
21	4	11	0	0	0
22	4	15	0	0	0
23	6	14	0	0	0
24	5	16	0	0	0