

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年3月1日 (金)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	11	1	0.000	0
2	6	11	1	0.000	0
3	6	12	1	0.000	0
4	6	12	1	0.000	0
5	6	11	1	0.000	0
6	6	10	1	0.000	0
7	6	11	1	0.000	0
8	6	12	1	0.000	0
9	6	13	1	0.000	0
10	6	12	1	0.000	0
11	6	12	1	0.000	0
12	6	13	1	0.000	0
13	6	12	1	0.000	0
14	6	11	1	0.000	0
15	6	11	1	0.000	0
16	6	11	1	0.000	0
17	6	11	1	0.000	0
18	6	12	1	0.000	0
19	6	14	1	0.000	0
20	6	11	1	0.000	0
21	6	11	1	0.000	0
22	6	12	1	0.000	0
23	6	13	1	0.000	0
24	6	15	1	0.000	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	15	1	0.000	0
2	5	13	1	0.000	0
3	5	11	1	0.000	0
4	5	11	1	0.000	0
5	6	13	2	0.000	0
6	6	12	2	0.000	0
7	6	13	1	0.000	0
8	6	12	2	0.000	0
9	5	12	1	0.000	0
10	6	12	2	0.000	0
11	6	12	2	0.000	0
12	6	11	2	0.000	0
13	6	12	1	0.000	0
14	6	13	2	0.000	0
15	6	11	1	0.000	0
16	6	11	1	0.000	0
17	6	11	2	0.000	0
18	5	11	1	0.000	0
19	5	12	1	0.000	0
20	4	11	1	0.000	0
21	4	9	1	0.000	0
22	4	11	1	0.000	0
23	4	11	1	0.000	0
24	4	11	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年3月2日 (土)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	12	1	0.000	0
2	6	13	1	0.000	0
3	6	13	1	0.000	0
4	6	13	1	0.000	0
5	6	13	1	0.000	1
6	6	12	1	0.000	0
7	6	11	1	0.000	1
8	6	10	1	0.000	1
9	6	9	1	0.000	1
10	6	11	1	0.000	1
11	6	10	1	0.000	1
12	6	10	1	0.000	1
13	6	10	1	0.000	1
14	6	12	1	0.000	1
15	6	10	1	0.000	1
16	6	10	1	0.000	1
17	6	10	1	0.000	1
18	6	10	1	0.000	1
19	6	11	1	0.000	1
20	6	11	1	0.000	1
21	6	12	1	0.000	1
22	6	10	1	0.000	1
23	6	10	1	0.000	1
24	6	11	1	0.000	1

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	4	11	1	0.000	0
2	4	11	1	0.000	0
3	4	11	1	0.000	0
4	4	11	1	0.000	0
5	4	11	1	0.000	0
6	5	13	1	0.000	0
7	5	13	1	0.000	0
8	5	14	1	0.000	1
9	5	13	1	0.000	1
10	6	13	1	0.000	1
11	5	13	1	0.000	1
12	6	13	1	0.000	1
13	6	12	1	0.000	1
14	6	13	2	0.000	1
15	5	13	1	0.000	1
16	5	12	1	0.000	1
17	5	12	1	0.000	1
18	5	10	1	0.000	1
19	4	12	1	0.000	1
20	5	12	1	0.000	1
21	5	11	1	0.000	1
22	4	11	1	0.000	1
23	4	12	1	0.000	1
24	4	11	1	0.000	1

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年3月3日 (日)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	9	1	0.000	1
2	6	10	1	0.000	1
3	6	10	1	0.000	1
4	6	11	1	0.000	0
5	6	10	1	0.000	1
6	6	9	1	0.000	1
7	5	12	1	0.000	0
8	6	13	1	0.000	1
9	6	12	1	0.000	1
10	6	11	1	0.000	1
11	6	13	1	0.000	1
12	6	12	1	0.000	1
13	6	12	1	0.000	0
14	6	10	1	0.000	0
15	6	11	1	0.000	1
16	6	10	1	0.000	0
17	6	13	1	0.000	0
18	6	13	1	0.000	1
19	6	12	1	0.000	1
20	6	12	1	0.000	0
21	5	13	1	0.000	0
22	6	13	1	0.000	0
23	6	11	1	0.000	0
24	6	10	1	0.000	1

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	4	13	1	0.000	1
2	4	11	1	0.000	1
3	4	12	1	0.000	0
4	4	10	1	0.000	0
5	4	10	1	0.000	1
6	5	10	1	0.000	1
7	4	10	1	0.000	1
8	4	11	1	0.000	0
9	3	11	1	0.000	1
10	3	11	1	0.000	1
11	3	11	1	0.000	0
12	2	10	1	0.000	0
13	3	11	1	0.000	0
14	3	13	1	0.000	0
15	3	6	1	0.000	0
16	3	9	1	0.000	0
17	3	12	1	0.000	0
18	3	11	1	0.000	1
19	3	13	1	0.000	1
20	3	12	1	0.000	1
21	3	12	1	0.000	1
22	3	10	1	0.000	0
23	2	10	1	0.000	1
24	2	12	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年3月4日 (月)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	11	1	0.000	0
2	6	11	1	0.000	0
3	6	10	1	0.000	0
4	6	12	1	0.000	0
5	6	12	1	0.000	0
6	6	11	1	0.000	0
7	6	11	1	0.000	1
8	6	13	1	0.000	0
9	6	12	1	0.000	1
10	6	12	1	0.000	1
11	5	13	1	0.000	1
12	5	13	1	0.000	1
13	6	13	1	0.000	1
14	6	12	1	0.000	1
15	6	12	1	0.000	0
16	6	12	1	0.000	1
17	6	11	1	0.000	0
18	6	9	1	0.000	0
19	6	11	1	0.000	1
20	6	13	1	0.000	0
21	6	12	1	0.000	0
22	6	11	1	0.000	0
23	6	12	1	0.000	0
24	6	12	1	0.000	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	2	10	1	0.000	0
2	2	10	1	0.000	0
3	2	11	1	0.000	0
4	2	11	1	0.000	0
5	3	12	1	0.000	0
6	3	11	1	0.000	0
7	3	12	1	0.000	1
8	3	11	1	0.000	0
9	3	12	1	0.000	1
10	3	10	1	0.000	0
11	4	14	1	0.000	1
12	4	13	1	0.000	0
13	5	11	1	0.000	1
14	4	10	1	0.000	0
15	4	10	1	0.000	0
16	4	11	1	0.000	2
17	4	10	1	0.000	1
18	4	10	1	0.000	1
19	5	12	1	0.000	1
20	5	11	1	0.000	1
21	5	10	2	0.000	1
22	5	12	1	0.000	1
23	5	10	1	0.000	1
24	5	11	1	0.000	1

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年3月5日 (火)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	12	1	0.000	0
2	6	11	1	0.000	0
3	6	12	1	0.000	0
4	6	13	1	0.000	0
5	6	9	1	0.000	0
6	6	12	1	0.000	0
7	6	11	1	0.000	0
8	6	12	1	0.000	0
9	6	11	1	0.000	0
10	6	11	1	0.000	0
11	6	11	1	0.000	0
12	6	12	1	0.000	0
13	6	12	1	0.000	0
14	6	12	1	0.000	0
15	6	13	1	0.000	0
16	5	12	1	0.000	0
17	6	14	1	0.000	0
18	6	13	1	0.000	0
19	6	14	1	0.000	0
20	6	15	1	0.000	0
21	6	12	1	0.000	0
22	6	13	1	0.000	0
23	6	11	1	0.000	0
24	6	11	1	0.000	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	4	12	1	0.000	1
2	4	10	1	0.000	1
3	5	11	1	0.000	1
4	4	10	1	0.000	1
5	5	10	1	0.000	1
6	6	10	1	0.000	1
7	5	11	1	0.000	1
8	5	11	1	0.000	1
9	5	11	1	0.000	1
10	4	13	1	0.000	1
11	4	13	1	0.000	1
12	5	11	1	0.000	1
13	6	12	1	0.000	1
14	5	13	1	0.000	1
15	5	11	1	0.000	0
16	5	13	1	0.000	0
17	6	15	1	0.000	0
18	6	9	1	0.000	0
19	6	10	1	0.000	0
20	6	12	1	0.000	0
21	6	13	1	0.000	0
22	6	11	1	0.000	0
23	6	12	1	0.000	0
24	6	11	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年3月6日 (水)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	14	1	0.000	0
2	6	12	1	0.000	0
3	6	10	1	0.000	0
4	6	10	1	0.000	0
5	6	10	1	0.000	0
6	6	10	1	0.000	0
7	6	12	1	0.000	0
8	6	12	1	0.000	0
9	6	11	1	0.000	0
10	6	10	1	0.000	0
11	6	14	1	0.000	0
12	6	11	1	0.000	0
13	6	10	1	0.000	0
14	6	10	1	0.000	0
15	6	10	1	0.000	0
16	6	13	1	0.000	0
17	6	12	1	0.000	0
18	6	12	1	0.000	0
19	6	10	1	0.000	0
20	6	13	1	0.000	0
21	6	12	1	0.000	0
22	6	10	1	0.000	0
23	6	11	1	0.000	0
24	6	10	1	0.000	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	11	1	0.000	0
2	6	11	1	0.000	0
3	6	12	1	0.000	0
4	6	11	1	0.000	0
5	6	12	1	0.000	0
6	6	11	1	0.000	0
7	6	11	1	0.000	0
8	5	11	1	0.000	0
9	6	11	1	0.000	0
10	6	11	1	0.000	0
11	6	11	1	0.000	0
12	6	10	1	0.000	0
13	5	11	1	0.000	0
14	5	10	1	0.000	0
15	5	11	1	0.000	0
16	4	11	1	0.000	0
17	4	11	1	0.000	0
18	4	10	1	0.000	0
19	4	10	1	0.000	0
20	4	10	1	0.000	0
21	4	11	1	0.000	0
22	4	9	1	0.000	0
23	4	11	1	0.000	0
24	4	11	1	0.000	1

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年3月7日 (木)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	10	1	0.000	0
2	6	10	1	0.000	0
3	6	12	1	0.000	0
4	6	13	1	0.000	0
5	6	11	1	0.000	0
6	6	11	1	0.000	1
7	6	13	1	0.000	1
8	6	10	1	0.000	0
9	6	11	1	0.000	0
10	6	13	1	0.000	1
11	6	12	1	0.000	1
12	6	13	1	0.000	1
13	6	12	1	0.000	1
14	6	10	1	0.000	0
15	6	13	0	0.000	1
16	6	7	0	0.000	0
17	6	4	0	0.000	0
18	6	4	0	0.000	0
19	6	3	0	0.000	0
20	6	4	0	0.000	0
21	6	4	0	0.000	0
22	6	4	0	0.000	0
23	6	4	0	0.000	0
24	6	4	0	0.000	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	3	10	1	0.000	0
2	4	11	1	0.000	0
3	5	11	1	0.000	0
4	4	10	1	0.000	0
5	4	11	1	0.000	0
6	4	11	1	0.000	0
7	5	11	1	0.000	0
8	5	11	1	0.000	0
9	5	12	1	0.000	0
10	4	11	1	0.000	0
11	4	11	1	0.000	0
12	5	10	1	0.000	0
13	4	11	1	0.000	0
14	6	10	1	0.000	1
15	6	10	1	0.000	0
16	6	10	1	0.000	0
17	4	9	1	0.000	0
18	4	10	1	0.000	0
19	3	10	1	0.000	0
20	3	10	1	0.000	0
21	4	10	1	0.000	0
22	4	11	1	0.000	0
23	4	11	1	0.000	0
24	4	10	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年3月8日 (金)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	4	0	0.000	0
2	6	4	0	0.000	0
3	6	6	0	0.000	0
4	6	10	0	0.000	0
5	6	13	1	0.000	0
6	6	14	1	0.000	0
7	6	12	1	0.000	0
8	6	13	1	0.000	0
9	6	12	1	0.000	0
10	6	12	1	0.000	0
11	6	10	1	0.000	0
12	6	10	1	0.000	0
13	6	11	1	0.000	0
14	6	12	1	0.000	0
15	6	11	1	0.000	0
16	6	13	1	0.000	0
17	6	13	1	0.000	0
18	6	11	1	0.000	0
19	6	10	1	0.000	0
20	6	11	1	0.000	0
21	6	15	1	0.000	0
22	6	14	1	0.000	0
23	6	11	1	0.000	0
24	6	12	1	0.000	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	4	10	1	0.000	0
2	4	10	1	0.000	0
3	4	10	1	0.000	0
4	5	10	1	0.000	0
5	4	10	1	0.000	0
6	4	10	1	0.000	0
7	5	11	1	0.000	0
8	6	11	1	0.000	0
9	6	11	1	0.000	0
10	6	10	1	0.000	0
11	6	10	1	0.000	0
12	6	11	1	0.000	0
13	6	12	2	0.000	0
14	5	12	1	0.000	0
15	4	12	1	0.000	0
16	4	11	1	0.000	0
17	5	11	1	0.000	0
18	4	10	1	0.000	0
19	5	11	1	0.000	0
20	4	10	1	0.000	0
21	5	13	1	0.000	0
22	4	13	1	0.000	0
23	4	11	1	0.000	0
24	3	11	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年3月9日 (土)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	12	1	0.000	0
2	6	11	1	0.000	0
3	6	12	1	0.000	0
4	6	13	1	0.000	0
5	6	11	1	0.000	0
6	6	11	1	0.000	0
7	6	13	1	0.000	0
8	6	12	1	0.000	0
9	6	13	1	0.000	0
10	6	13	1	0.000	0
11	6	11	1	0.000	0
12	6	12	1	0.000	1
13	6	14	1	0.000	1
14	6	12	1	0.000	0
15	6	12	1	0.000	1
16	6	12	1	0.000	1
17	6	11	1	0.000	1
18	6	11	1	0.000	1
19	6	11	1	0.000	1
20	6	9	1	0.000	1
21	6	10	1	0.000	1
22	6	13	1	0.000	0
23	6	11	1	0.000	1
24	6	11	1	0.000	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	4	11	1	0.000	0
2	4	11	1	0.000	0
3	3	12	1	0.000	0
4	3	10	1	0.000	0
5	3	11	1	0.000	0
6	4	12	1	0.000	0
7	4	12	1	0.000	0
8	5	11	1	0.000	0
9	4	12	1	0.000	0
10	4	12	1	0.000	0
11	5	11	1	0.000	0
12	6	12	2	0.000	0
13	6	11	1	0.000	15
14	6	12	2	0.000	10
15	5	11	1	0.000	5
16	5	11	1	0.000	3
17	5	13	1	0.000	2
18	5	11	1	0.000	3
19	4	10	1	0.000	2
20	4	10	1	0.000	1
21	5	10	1	0.000	1
22	6	12	1	0.000	2
23	6	11	1	0.000	4
24	5	11	1	0.000	2

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年3月10日 (日)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	11	1	0.000	0
2	6	11	1	0.000	0
3	6	11	1	0.000	0
4	6	13	1	0.000	0
5	6	11	1	0.000	0
6	6	11	1	0.000	0
7	6	11	1	0.000	0
8	6	13	1	0.000	0
9	6	11	1	0.000	1
10	6	10	1	0.000	1
11	6	12	1	0.000	1
12	6	14	1	0.000	1
13	6	12	1	0.000	1
14	6	11	1	0.000	1
15	6	12	1	0.000	1
16	6	11	1	0.000	1
17	6	12	1	0.000	1
18	6	11	1	0.000	1
19	6	10	1	0.000	1
20	6	12	1	0.000	1
21	6	10	1	0.000	1
22	6	11	1	0.000	1
23	6	10	1	0.000	1
24	6	10	1	0.000	1

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	11	1	0.000	2
2	6	10	1	0.000	1
3	6	11	1	0.000	2
4	6	10	1	0.000	2
5	6	10	1	0.000	1
6	5	10	1	0.000	1
7	5	10	1	0.000	1
8	5	11	1	0.000	1
9	5	11	1	0.000	1
10	4	10	1	0.000	1
11	5	10	1	0.000	1
12	6	11	2	0.000	1
13	6	11	1	0.000	1
14	5	11	1	0.000	1
15	4	11	1	0.000	1
16	4	10	1	0.000	1
17	4	11	1	0.000	1
18	4	11	1	0.000	1
19	4	11	1	0.000	2
20	4	11	1	0.000	2
21	3	11	1	0.000	1
22	4	11	1	0.000	1
23	4	10	1	0.000	2
24	4	12	1	0.000	1

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年3月11日 (月)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	11	1	0.000	1
2	6	11	1	0.000	0
3	6	10	1	0.000	0
4	6	11	1	0.000	0
5	6	11	1	0.000	0
6	6	10	1	0.000	0
7	6	11	1	0.000	0
8	6	10	1	0.000	0
9	6	11	1	0.000	0
10	6	11	1	0.000	0
11	6	11	1	0.000	0
12	6	11	1	0.000	0
13	6	11	1	0.000	0
14	6	10	1	0.000	1
15	6	10	1	0.000	0
16	6	11	1	0.000	0
17	6	11	1	0.000	0
18	6	11	1	0.000	0
19	6	10	1	0.000	0
20	6	12	1	0.000	0
21	6	10	1	0.000	0
22	6	11	1	0.000	0
23	6	13	1	0.000	0
24	6	11	1	0.000	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	4	12	1	0.000	1
2	4	12	1	0.000	1
3	4	14	1	0.000	1
4	4	11	1	0.000	1
5	5	11	1	0.000	1
6	4	11	1	0.000	1
7	4	11	1	0.000	1
8	4	12	1	0.000	1
9	4	12	1	0.000	1
10	4	13	1	0.000	1
11	4	11	1	0.000	1
12	4	12	1	0.000	1
13	4	10	1	0.000	1
14	4	11	1	0.000	1
15	4	11	1	0.000	1
16	3	12	1	0.000	1
17	4	12	1	0.000	1
18	4	11	1	0.000	0
19	4	11	1	0.000	1
20	4	11	1	0.000	1
21	4	11	1	0.000	0
22	3	11	1	0.000	0
23	3	13	1	0.000	0
24	3	12	1	0.000	1

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年3月12日 (火)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	12	1	0.000	0
2	6	11	1	0.000	0
3	6	12	1	0.000	0
4	6	9	1	0.000	0
5	6	11	1	0.000	0
6	6	11	1	0.000	0
7	6	12	1	0.000	0
8	6	10	1	0.000	0
9	6	11	1	0.000	0
10	6	13	1	0.000	0
11	6	12	1	0.000	0
12	6	9	1	0.000	0
13	6	9	1	0.000	0
14	6	10	1	0.000	0
15	6	12	1	0.000	0
16	6	12	1	0.000	0
17	6	13	1	0.000	0
18	6	12	1	0.000	0
19	6	9	1	0.000	0
20	6	9	1	0.000	0
21	6	9	1	0.000	0
22	6	11	1	0.000	0
23	6	13	1	0.000	0
24	6	13	1	0.000	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	3	11	1	0.000	1
2	3	12	1	0.000	0
3	4	13	1	0.000	0
4	3	12	1	0.000	0
5	3	12	1	0.000	0
6	3	10	1	0.000	0
7	3	11	1	0.000	0
8	3	10	1	0.000	0
9	3	10	1	0.000	0
10	3	12	1	0.000	0
11	3	10	1	0.000	0
12	3	9	1	0.000	0
13	3	10	1	0.000	0
14	2	10	1	0.000	0
15	2	10	1	0.000	0
16	2	10	1	0.000	0
17	2	12	1	0.000	0
18	2	11	1	0.000	0
19	2	11	1	0.000	0
20	2	11	1	0.000	0
21	2	12	1	0.000	0
22	2	12	1	0.000	0
23	2	9	1	0.000	0
24	2	10	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年3月13日 (水)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	13	1	0.000	0
2	6	10	1	0.000	0
3	6	10	1	0.000	0
4	6	11	1	0.000	2
5	6	9	1	0.000	1
6	6	9	1	0.000	1
7	6	9	1	0.000	1
8	6	10	1	0.000	2
9	6	11	1	0.000	4
10	6	9	1	0.000	3
11	6	10	1	0.000	3
12	6	11	1	0.000	2
13	6	14	1	0.000	2
14	6	13	1	0.000	2
15	6	13	1	0.000	2
16	6	12	1	0.000	2
17	6	13	1	0.000	1
18	6	12	1	0.000	1
19	6	11	1	0.000	1
20	6	11	1	0.000	1
21	6	11	1	0.000	1
22	6	9	1	0.000	1
23	6	11	1	0.000	1
24	6	11	1	0.000	1

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	2	11	1	0.000	0
2	2	12	1	0.000	0
3	2	11	1	0.000	0
4	2	11	1	0.000	0
5	2	10	1	0.000	0
6	2	11	1	0.000	0
7	2	10	1	0.000	0
8	2	11	1	0.000	0
9	2	11	1	0.000	0
10	2	13	1	0.000	0
11	2	12	1	0.000	0
12	2	11	1	0.000	0
13	2	12	1	0.000	0
14	2	12	1	0.000	0
15	2	11	1	0.000	0
16	2	11	1	0.000	0
17	2	10	1	0.000	0
18	2	10	1	0.000	0
19	2	11	1	0.000	0
20	2	10	1	0.000	0
21	2	10	1	0.000	0
22	2	11	1	0.000	0
23	2	11	1	0.000	0
24	2	10	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年3月14日 (木)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	10	1	0.000	1
2	6	11	1	0.000	1
3	6	10	1	0.000	1
4	5	10	1	0.000	1
5	6	11	1	0.000	1
6	6	11	1	0.000	1
7	6	10	1	0.000	1
8	6	9	1	0.000	1
9	6	11	1	0.000	1
10	5	11	1	0.000	1
11	5	12	1	0.000	1
12	5	11	1	0.000	1
13	5	10	1	0.000	1
14	6	10	1	0.000	1
15	6	9	1	0.000	1
16	5	11	1	0.000	0
17	5	9	1	0.000	1
18	6	11	1	0.000	0
19	6	11	1	0.000	0
20	6	10	1	0.000	0
21	6	10	1	0.000	1
22	6	9	1	0.000	1
23	5	11	1	0.000	1
24	5	10	1	0.000	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	2	11	1	0.000	0
2	2	11	1	0.000	0
3	2	11	1	0.000	0
4	2	10	1	0.000	0
5	2	10	1	0.000	0
6	2	11	1	0.000	0
7	2	11	1	0.000	0
8	2	11	1	0.000	0
9	2	11	1	0.000	0
10	2	10	1	0.000	0
11	2	11	1	0.000	0
12	2	10	1	0.000	0
13	2	10	1	0.000	0
14	2	12	1	0.000	0
15	2	11	1	0.000	0
16	2	10	1	0.000	0
17	2	11	1	0.000	0
18	2	10	1	0.000	0
19	2	10	1	0.000	0
20	2	10	1	0.000	0
21	2	12	1	0.000	0
22	2	11	1	0.000	0
23	2	9	1	0.000	0
24	2	11	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年3月15日 (金)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	10	1	0.000	0
2	5	12	1	0.000	0
3	5	10	1	0.000	0
4	6	11	1	0.000	0
5	5	10	1	0.000	0
6	6	11	1	0.000	0
7	5	12	1	0.000	0
8	5	12	1	0.000	0
9	5	11	1	0.000	0
10	5	10	1	0.000	0
11	5	11	1	0.000	0
12	5	12	1	0.000	0
13	6	11	1	0.000	0
14	6	10	1	0.000	0
15	5	11	1	0.000	0
16	6	9	1	0.000	0
17	5	10	1	0.000	0
18	5	10	1	0.000	0
19	4	10	1	0.000	0
20	5	12	1	0.000	0
21	4	12	1	0.000	0
22	5	12	1	0.000	0
23	5	10	1	0.000	0
24	5	12	1	0.000	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	2	10	1	0.000	0
2	2	10	1	0.000	0
3	1	9	1	0.000	0
4	2	11	1	0.000	0
5	2	10	1	0.000	0
6	2	12	1	0.000	0
7	2	12	1	0.000	0
8	2	10	1	0.000	0
9	2	10	1	0.000	0
10	2	11	1	0.000	0
11	2	9	1	0.000	0
12	2	11	1	0.000	0
13	2	10	1	0.000	0
14	2	10	1	0.000	0
15	2	11	1	0.000	0
16	2	10	1	0.000	0
17	2	10	1	0.000	0
18	2	11	1	0.000	0
19	2	11	1	0.000	0
20	2	11	1	0.000	0
21	2	10	1	0.000	0
22	2	10	1	0.000	0
23	2	12	1	0.000	0
24	2	11	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年3月16日 (土)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	4	9	0	0.000	0
2	4	10	0	0.000	0
3	4	12	0	0.000	0
4	4	15	1	0.000	0
5	4	9	1	0.000	0
6	4	11	0	0.000	0
7	4	14	1	0.000	0
8	4	13	0	0.000	0
9	4	12	0	0.000	0
10	4	12	0	0.000	0
11	4	10	0	0.000	0
12	4	12	0	0.000	0
13	4	12	0	0.000	0
14	4	11	0	0.000	0
15	4	10	1	0.000	0
16	4	11	1	0.000	0
17	4	9	0	0.000	0
18	4	9	0	0.000	0
19	4	14	0	0.000	0
20	4	10	0	0.000	0
21	4	10	0	0.000	0
22	3	9	0	0.000	0
23	3	11	0	0.000	0
24	3	13	0	0.000	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	2	12	1	0.000	0
2	2	11	1	0.000	0
3	2	11	1	0.000	0
4	2	11	1	0.000	0
5	2	12	1	0.000	0
6	2	11	1	0.000	0
7	2	13	1	0.000	0
8	2	11	1	0.000	0
9	2	11	1	0.000	0
10	2	11	1	0.000	0
11	3	11	1	0.000	0
12	3	11	1	0.000	0
13	3	11	1	0.000	0
14	3	10	1	0.000	0
15	3	10	1	0.000	0
16	2	10	1	0.000	0
17	2	10	1	0.000	0
18	2	11	1	0.000	0
19	2	10	1	0.000	0
20	2	10	1	0.000	0
21	2	10	1	0.000	0
22	2	9	1	0.000	0
23	2	10	1	0.000	0
24	2	10	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年3月17日 (日)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	3	11	0	0.000	0
2	3	11	0	0.000	0
3	3	11	0	0.000	0
4	4	12	0	0.000	1
5	4	12	0	0.000	1
6	3	11	0	0.000	0
7	3	12	0	0.000	0
8	3	12	0	0.000	0
9	3	11	0	0.000	0
10	3	12	0	0.000	1
11	3	11	0	0.000	0
12	3	10	0	0.000	0
13	3	10	0	0.000	0
14	3	10	0	0.000	0
15	3	9	0	0.000	0
16	3	11	0	0.000	0
17	4	10	0	0.000	0
18	3	10	0	0.000	0
19	3	10	0	0.000	0
20	4	12	0	0.000	0
21	3	9	0	0.000	0
22	4	11	0	0.000	0
23	4	14	0	0.000	0
24	4	12	0	0.000	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	2	10	1	0.000	0
2	2	11	1	0.000	0
3	2	9	1	0.000	0
4	2	11	1	0.000	0
5	2	11	1	0.000	0
6	2	12	1	0.000	0
7	2	12	1	0.000	0
8	2	10	1	0.000	0
9	2	10	1	0.000	0
10	2	10	1	0.000	0
11	2	11	1	0.000	0
12	2	10	1	0.000	0
13	2	11	1	0.000	0
14	2	10	1	0.000	0
15	2	9	1	0.000	0
16	2	11	1	0.000	0
17	2	10	1	0.000	0
18	2	10	1	0.000	0
19	2	10	1	0.000	0
20	2	10	1	0.000	0
21	2	11	1	0.000	0
22	2	10	1	0.000	0
23	2	11	1	0.000	0
24	2	10	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年3月18日 (月)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	4	11	1	0.000	0
2	4	13	0	0.000	0
3	3	11	0	0.000	0
4	3	11	0	0.000	0
5	4	11	0	0.000	0
6	4	12	0	0.000	0
7	4	11	0	0.000	1
8	3	12	0	0.000	0
9	3	13	0	0.000	1
10	5	11	1	0.000	1
11	6	12	1	0.000	1
12	6	12	1	0.000	1
13	6	10	1	0.000	1
14	6	11	1	0.000	1
15	6	12	1	0.000	1
16	6	11	1	0.000	1
17	6	10	1	0.000	1
18	6	11	1	0.000	1
19	6	12	1	0.000	1
20	6	13	1	0.000	1
21	6	14	1	0.000	1
22	6	13	1	0.000	1
23	6	12	1	0.000	1
24	6	12	1	0.000	1

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	2	11	1	0.000	0
2	2	11	1	0.000	0
3	2	10	1	0.000	1
4	2	11	1	0.000	1
5	2	12	1	0.000	0
6	2	11	1	0.000	0
7	2	10	1	0.000	0
8	2	10	1	0.000	1
9	2	10	1	0.000	0
10	3	10	1	0.000	1
11	4	10	1	0.000	1
12	3	9	1	0.000	1
13	3	12	1	0.000	1
14	3	10	1	0.000	1
15	3	10	1	0.000	1
16	4	10	1	0.000	1
17	4	10	1	0.000	1
18	4	12	1	0.000	1
19	4	11	1	0.000	1
20	4	11	1	0.000	1
21	4	12	1	0.000	1
22	4	11	1	0.000	0
23	4	11	1	0.000	1
24	4	12	1	0.000	1

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年3月19日 (火)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	12	1	0.000	1
2	6	14	1	0.000	1
3	6	12	1	0.000	1
4	6	12	1	0.000	1
5	6	10	1	0.000	1
6	6	10	1	0.000	1
7	6	11	1	0.000	1
8	6	12	1	0.000	1
9	6	12	1	0.000	1
10	6	12	1	0.000	1
11	6	10	1	0.000	1
12	6	13	1	0.000	1
13	6	11	1	0.000	1
14	6	13	1	0.000	1
15	6	13	1	0.000	0
16	6	11	1	0.000	0
17	6	13	1	0.000	0
18	6	13	1	0.000	0
19	6	12	1	0.000	0
20	6	10	1	0.000	0
21	6	10	1	0.000	0
22	6	13	1	0.000	0
23	6	13	1	0.000	1
24	6	13	1	0.000	1

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	4	11	1	0.000	1
2	4	11	1	0.000	1
3	4	10	1	0.000	1
4	5	10	1	0.000	1
5	5	10	1	0.000	1
6	5	10	1	0.000	1
7	5	11	1	0.000	0
8	4	10	1	0.000	1
9	5	10	1	0.000	1
10	5	11	1	0.000	1
11	5	11	1	0.000	1
12	4	11	1	0.000	1
13	3	10	1	0.000	1
14	3	10	1	0.000	1
15	4	10	1	0.000	1
16	4	10	1	0.000	1
17	4	11	1	0.000	0
18	4	10	1	0.000	0
19	4	11	1	0.000	0
20	5	11	1	0.000	0
21	6	12	2	0.000	1
22	5	12	1	0.000	2
23	4	10	1	0.000	2
24	5	10	1	0.000	2

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年3月20日 (水)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	12	1	0.000	1
2	6	13	1	0.000	0
3	6	12	1	0.000	0
4	6	10	1	0.000	0
5	6	11	1	0.000	0
6	6	11	1	0.000	1
7	6	10	1	0.000	0
8	6	12	1	0.000	0
9	6	11	1	0.000	0
10	6	12	1	0.000	0
11	6	12	1	0.000	0
12	6	12	1	0.000	0
13	6	10	1	0.000	0
14	6	12	1	0.000	0
15	6	11	1	0.000	0
16	6	13	1	0.000	0
17	6	14	1	0.000	0
18	6	12	1	0.000	0
19	6	12	1	0.000	0
20	6	12	1	0.000	0
21	6	11	1	0.000	0
22	6	13	1	0.000	0
23	6	11	1	0.000	0
24	6	11	1	0.000	1

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	10	1	0.000	2
2	4	10	1	0.000	2
3	5	11	1	0.000	2
4	6	10	1	0.000	2
5	5	11	1	0.000	1
6	5	11	1	0.000	1
7	5	10	1	0.000	1
8	5	10	1	0.000	1
9	5	11	1	0.000	1
10	4	11	1	0.000	1
11	4	12	1	0.000	1
12	4	12	1	0.000	1
13	3	11	1	0.000	1
14	3	10	1	0.000	1
15	3	10	1	0.000	1
16	3	11	1	0.000	1
17	3	12	1	0.000	1
18	3	11	1	0.000	1
19	3	12	1	0.000	1
20	2	10	1	0.000	1
21	2	11	1	0.000	1
22	2	10	1	0.000	1
23	3	10	1	0.000	1
24	3	9	1	0.000	1

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年3月21日 (木)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	11	1	0.000	0
2	6	8	1	0.000	0
3	6	10	1	0.000	1
4	6	11	1	0.000	0
5	6	10	1	0.000	1
6	6	10	1	0.000	0
7	6	12	1	0.000	1
8	6	10	1	0.000	1
9	6	12	1	0.000	1
10	6	10	1	0.000	1
11	6	11	1	0.000	1
12	6	12	1	0.000	1
13	6	10	1	0.000	1
14	6	13	1	0.000	1
15	6	14	1	0.000	1
16	6	15	1	0.000	1
17	6	7	1	0.000	0
18	6	12	1	0.000	0
19	6	12	1	0.000	0
20	6	13	1	0.000	0
21	6	12	1	0.000	0
22	6	12	1	0.000	0
23	6	13	1	0.000	0
24	6	11	1	0.000	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	3	11	1	0.000	1
2	3	10	1	0.000	1
3	3	11	1	0.000	1
4	3	12	1	0.000	1
5	3	10	1	0.000	1
6	3	10	1	0.000	1
7	3	9	1	0.000	1
8	3	10	1	0.000	1
9	3	11	1	0.000	1
10	3	9	1	0.000	1
11	3	11	1	0.000	1
12	3	10	1	0.000	1
13	3	10	1	0.000	1
14	3	10	1	0.000	1
15	3	10	1	0.000	1
16	3	11	1	0.000	1
17	3	11	1	0.000	1
18	4	12	1	0.000	1
19	4	11	1	0.000	1
20	4	11	1	0.000	1
21	4	13	1	0.000	1
22	4	12	1	0.000	1
23	4	11	1	0.000	0
24	4	12	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年3月22日 (金)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	14	1	0.000	0
2	6	14	1	0.000	0
3	6	11	1	0.000	0
4	6	14	1	0.000	0
5	6	10	1	0.000	0
6	6	10	1	0.000	0
7	6	15	1	0.000	0
8	6	12	1	0.000	0
9	6	12	1	0.000	0
10	6	13	1	0.000	0
11	6	12	1	0.000	0
12	6	13	1	0.000	0
13	6	11	1	0.000	0
14	6	13	1	0.000	0
15	6	11	1	0.000	0
16	6	12	1	0.000	0
17	6	11	1	0.000	0
18	6	10	1	0.000	0
19	6	12	1	0.000	0
20	6	12	1	0.000	0
21	6	13	1	0.000	0
22	6	12	1	0.000	0
23	6	11	1	0.000	0
24	6	15	1	0.000	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	4	11	1	0.000	1
2	4	11	1	0.000	0
3	4	10	1	0.000	1
4	4	11	1	0.000	0
5	4	9	1	0.000	0
6	5	11	1	0.000	1
7	5	14	1	0.000	1
8	5	12	1	0.000	0
9	4	11	1	0.000	0
10	4	12	1	0.000	0
11	4	11	1	0.000	1
12	4	11	1	0.000	1
13	4	11	1	0.000	0
14	4	11	1	0.000	0
15	4	11	1	0.000	1
16	4	11	1	0.000	0
17	3	10	1	0.000	0
18	3	12	1	0.000	0
19	4	11	1	0.000	0
20	4	12	1	0.000	0
21	5	12	1	0.000	0
22	4	11	1	0.000	0
23	5	11	1	0.000	0
24	4	14	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年3月23日 (土)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	13	1	0.000	0
2	6	12	1	0.000	0
3	6	13	1	0.000	0
4	6	13	1	0.000	0
5	6	12	1	0.000	0
6	6	11	1	0.000	0
7	6	14	1	0.000	0
8	6	13	1	0.000	0
9	5	10	1	0.000	0
10	6	12	1	0.000	0
11	6	12	1	0.000	0
12	6	12	1	0.000	0
13	6	11	1	0.000	0
14	6	11	1	0.000	0
15	6	12	1	0.000	0
16	6	11	1	0.000	0
17	6	12	1	0.000	0
18	6	11	1	0.000	0
19	6	11	1	0.000	0
20	6	13	1	0.000	0
21	6	13	1	0.000	0
22	6	14	1	0.000	0
23	6	11	1	0.000	0
24	6	12	1	0.000	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	4	13	1	0.000	0
2	4	12	1	0.000	0
3	5	12	1	0.000	0
4	5	12	1	0.000	0
5	5	11	1	0.000	0
6	5	10	1	0.000	0
7	5	11	1	0.000	0
8	5	11	1	0.000	0
9	4	12	1	0.000	0
10	4	10	1	0.000	0
11	4	11	1	0.000	0
12	4	10	1	0.000	0
13	4	10	1	0.000	0
14	4	10	1	0.000	0
15	4	12	1	0.000	0
16	3	12	1	0.000	0
17	3	10	1	0.000	0
18	3	10	1	0.000	0
19	4	11	1	0.000	0
20	4	12	1	0.000	0
21	3	10	1	0.000	0
22	3	11	1	0.000	0
23	3	10	1	0.000	0
24	3	12	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年3月24日 (日)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	12	1	0.000	0
2	6	11	1	0.000	0
3	6	10	1	0.000	0
4	6	12	1	0.000	0
5	6	11	1	0.000	0
6	6	11	1	0.000	0
7	6	12	1	0.000	2
8	6	13	1	0.000	1
9	6	10	1	0.000	1
10	6	12	1	0.000	0
11	6	13	1	0.000	0
12	6	11	1	0.000	0
13	6	11	1	0.000	1
14	6	12	1	0.000	0
15	6	9	1	0.000	0
16	6	10	1	0.000	0
17	6	12	1	0.000	0
18	6	12	1	0.000	0
19	6	10	1	0.000	0
20	6	11	1	0.000	0
21	6	11	1	0.000	0
22	5	10	1	0.000	0
23	6	11	1	0.000	0
24	6	10	1	0.000	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	3	11	1	0.000	0
2	3	11	1	0.000	0
3	3	11	1	0.000	0
4	4	10	1	0.000	0
5	3	10	1	0.000	0
6	4	10	1	0.000	0
7	3	12	1	0.000	0
8	3	12	1	0.000	0
9	3	11	1	0.000	0
10	3	12	1	0.000	0
11	3	11	1	0.000	0
12	3	11	1	0.000	0
13	3	11	1	0.000	0
14	3	10	1	0.000	0
15	3	10	1	0.000	0
16	3	11	1	0.000	0
17	3	10	1	0.000	0
18	3	11	1	0.000	0
19	3	12	1	0.000	0
20	3	11	1	0.000	0
21	2	11	1	0.000	0
22	2	11	1	0.000	0
23	2	11	1	0.000	0
24	2	10	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年3月25日 (月)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	10	1	0.000	0
2	5	11	1	0.000	0
3	6	11	1	0.000	0
4	5	9	1	0.000	0
5	5	10	0	0.000	0
6	5	11	1	0.000	0
7	6	10	1	0.000	0
8	6	8	1	0.000	0
9	5	10	1	0.000	0
10	5	10	0	0.000	0
11	5	11	1	0.000	0
12	6	10	1	0.000	0
13	6	10	1	0.000	0
14	6	11	1	0.000	0
15	6	11	1	0.000	0
16	6	12	1	0.000	0
17	6	11	1	0.000	0
18	5	10	1	0.000	0
19	5	11	1	0.000	0
20	6	10	1	0.000	0
21	6	11	1	0.000	0
22	6	10	1	0.000	0
23	6	10	1	0.000	0
24	6	11	1	0.000	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	2	10	1	0.000	0
2	2	10	1	0.000	0
3	2	10	1	0.000	0
4	2	11	1	0.000	0
5	2	11	1	0.000	0
6	2	11	1	0.000	0
7	2	10	1	0.000	0
8	2	8	1	0.000	0
9	2	10	1	0.000	0
10	2	10	1	0.000	0
11	2	11	1	0.000	0
12	2	10	1	0.000	0
13	2	10	1	0.000	0
14	2	10	1	0.000	0
15	2	10	1	0.000	0
16	2	10	1	0.000	0
17	2	10	1	0.000	0
18	2	9	1	0.000	0
19	2	10	1	0.000	0
20	2	10	1	0.000	0
21	2	9	1	0.000	0
22	2	11	1	0.000	0
23	2	10	1	0.000	0
24	2	9	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年3月26日 (火)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	10	1	0.000	0
2	6	11	1	0.000	0
3	6	10	1	0.000	0
4	6	10	1	0.000	0
5	6	12	1	0.000	0
6	6	11	1	0.000	0
7	6	11	1	0.000	0
8	6	11	1	0.000	0
9	6	13	1	0.000	0
10	6	12	1	0.000	0
11	6	12	1	0.000	0
12	6	12	1	0.000	0
13	6	12	1	0.000	0
14	6	11	1	0.000	0
15	6	12	1	0.000	0
16	6	11	1	0.000	0
17	6	13	1	0.000	0
18	6	13	1	0.000	0
19	6	12	1	0.000	0
20	6	11	1	0.000	0
21	6	12	1	0.000	0
22	6	11	1	0.000	0
23	6	11	1	0.000	0
24	6	10	1	0.000	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	2	11	1	0.000	0
2	2	10	1	0.000	0
3	2	10	1	0.000	0
4	2	9	1	0.000	0
5	2	10	1	0.000	0
6	2	11	1	0.000	0
7	2	10	1	0.000	0
8	2	11	1	0.000	0
9	3	12	1	0.000	0
10	3	11	1	0.000	0
11	3	10	1	0.000	0
12	3	12	1	0.000	0
13	3	12	1	0.000	0
14	2	12	1	0.000	0
15	2	12	1	0.000	0
16	2	11	1	0.000	0
17	2	11	1	0.000	0
18	2	10	1	0.000	0
19	2	10	1	0.000	0
20	2	10	1	0.000	0
21	2	10	1	0.000	0
22	2	10	1	0.000	0
23	2	10	1	0.000	0
24	2	14	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年3月27日 (水)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	10	1	0.000	0
2	6	9	1	0.000	0
3	6	13	1	0.000	0
4	6	13	1	0.000	0
5	6	13	1	0.000	0
6	5	12	1	0.000	0
7	6	10	1	0.000	0
8	6	10	1	0.000	0
9	6	13	1	0.000	0
10	6	10	1	0.000	0
11	6	12	1	0.000	0
12	6	10	1	0.000	0
13	6	10	1	0.000	0
14	6	12	1	0.000	0
15	6	10	1	0.000	0
16	6	11	1	0.000	0
17	6	13	1	0.000	0
18	6	12	1	0.000	0
19	6	12	1	0.000	0
20	6	10	1	0.000	0
21	6	10	1	0.000	0
22	6	11	1	0.000	0
23	6	10	1	0.000	0
24	6	11	1	0.000	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	2	10	1	0.000	0
2	2	11	1	0.000	0
3	2	12	1	0.000	0
4	3	12	1	0.000	0
5	3	11	1	0.000	0
6	3	11	1	0.000	0
7	2	10	1	0.000	0
8	2	11	1	0.000	0
9	2	10	1	0.000	0
10	2	10	1	0.000	0
11	2	10	1	0.000	0
12	2	10	1	0.000	0
13	2	11	1	0.000	0
14	3	11	1	0.000	0
15	3	11	1	0.000	0
16	2	11	1	0.000	0
17	3	11	1	0.000	0
18	2	10	1	0.000	0
19	2	11	1	0.000	0
20	2	11	1	0.000	0
21	3	11	1	0.000	0
22	3	10	1	0.000	0
23	2	11	1	0.000	0
24	2	11	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年3月28日 (木)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	10	1	0.000	0
2	6	11	1	0.000	0
3	6	14	1	0.000	0
4	6	12	1	0.000	0
5	6	11	1	0.000	0
6	6	10	1	0.000	2
7	6	11	1	0.000	1
8	6	11	1	0.000	1
9	6	12	1	0.000	1
10	5	12	1	0.000	1
11	6	12	1	0.000	1
12	5	10	1	0.000	1
13	5	12	1	0.000	1
14	5	11	1	0.000	1
15	6	11	1	0.000	0
16	6	10	1	0.000	0
17	6	11	1	0.000	0
18	6	9	1	0.000	0
19	6	10	1	0.000	0
20	5	11	1	0.000	0
21	6	10	1	0.000	0
22	6	12	1	0.000	0
23	6	11	1	0.000	0
24	6	11	1	0.000	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	2	11	1	0.000	0
2	2	10	1	0.000	0
3	3	11	1	0.000	0
4	3	11	1	0.000	0
5	3	11	1	0.000	0
6	3	11	1	0.000	0
7	3	11	1	0.000	0
8	3	11	1	0.000	0
9	3	11	1	0.000	0
10	2	11	1	0.000	0
11	2	11	1	0.000	0
12	2	10	1	0.000	0
13	2	11	1	0.000	0
14	2	11	1	0.000	0
15	3	10	1	0.000	0
16	3	10	1	0.000	0
17	3	11	1	0.000	0
18	3	13	1	0.000	0
19	3	11	1	0.000	0
20	3	13	1	0.000	0
21	3	12	1	0.000	0
22	3	12	1	0.000	0
23	3	12	1	0.000	0
24	3	11	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年3月29日 (金)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	12	1	0.000	0
2	6	13	1	0.000	0
3	6	10	1	0.000	0
4	6	12	1	0.000	0
5	6	11	1	0.000	0
6	6	11	1	0.000	0
7	6	10	1	0.000	0
8	6	12	1	0.000	0
9	6	13	1	0.000	0
10	6	12	1	0.000	0
11	6	12	1	0.000	0
12	6	11	1	0.000	0
13	6	12	1	0.000	0
14	6	10	1	0.000	0
15	6	14	1	0.000	0
16	5	10	1	0.000	0
17	6	10	1	0.000	0
18	5	9	1	0.000	0
19	6	12	1	0.000	0
20	6	13	1	0.000	0
21	5	10	1	0.000	0
22	4	12	1	0.000	0
23	4	11	1	0.000	0
24	5	14	1	0.000	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	3	11	1	0.000	0
2	3	11	1	0.000	0
3	3	11	1	0.000	0
4	3	10	1	0.000	0
5	3	11	1	0.000	0
6	3	11	1	0.000	0
7	3	12	1	0.000	0
8	3	12	1	0.000	0
9	3	13	1	0.000	0
10	3	13	1	0.000	0
11	3	12	1	0.000	0
12	3	12	1	0.000	0
13	3	13	1	0.000	0
14	3	11	1	0.000	0
15	3	13	1	0.000	0
16	2	11	1	0.000	0
17	2	11	1	0.000	0
18	2	11	1	0.000	0
19	2	11	1	0.000	0
20	2	11	1	0.000	0
21	3	11	1	0.000	0
22	3	11	1	0.000	0
23	3	12	1	0.000	0
24	3	12	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年3月30日 (土)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	4	12	1	0.000	0
2	4	10	0	0.000	0
3	4	10	0	0.000	0
4	4	10	1	0.000	0
5	4	11	0	0.000	0
6	4	10	0	0.000	0
7	4	14	0	0.000	0
8	3	13	0	0.000	0
9	3	12	0	0.000	0
10	3	10	0	0.000	0
11	3	11	0	0.000	0
12	3	10	0	0.000	0
13	3	14	0	0.000	0
14	3	11	0	0.000	0
15	3	11	0	0.000	0
16	3	10	0	0.000	0
17	3	10	0	0.000	0
18	3	12	0	0.000	0
19	3	10	0	0.000	0
20	3	10	0	0.000	0
21	3	13	0	0.000	0
22	3	11	0	0.000	0
23	3	11	0	0.000	0
24	3	12	0	0.000	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	3	11	1	0.000	0
2	3	12	1	0.000	0
3	3	12	1	0.000	0
4	3	10	1	0.000	0
5	3	11	1	0.000	0
6	3	14	1	0.000	0
7	3	12	1	0.000	0
8	2	10	1	0.000	0
9	2	10	1	0.000	0
10	3	12	1	0.000	0
11	2	11	1	0.000	0
12	2	11	1	0.000	0
13	2	10	1	0.000	0
14	2	10	1	0.000	0
15	2	10	1	0.000	0
16	2	13	1	0.000	0
17	2	11	1	0.000	0
18	2	10	1	0.000	0
19	2	10	1	0.000	0
20	2	11	1	0.000	0
21	2	10	1	0.000	0
22	2	10	1	0.000	0
23	2	10	1	0.000	0
24	2	10	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年3月31日 (日)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	3	8	0	0.000	0
2	3	11	0	0.000	0
3	3	9	0	0.000	0
4	3	9	0	0.000	0
5	3	14	0	0.000	0
6	3	11	0	0.000	0
7	3	10	0	0.000	0
8	3	10	0	0.000	0
9	3	8	0	0.000	0
10	3	11	0	0.000	0
11	3	11	0	0.000	0
12	3	10	0	0.000	0
13	3	11	0	0.000	0
14	3	10	0	0.000	0
15	3	9	0	0.000	0
16	3	10	0	0.000	0
17	3	11	0	0.000	0
18	3	10	0	0.000	0
19	3	10	0	0.000	0
20	3	13	0	0.000	0
21	3	12	0	0.000	0
22	3	11	0	0.000	0
23	3	10	0	0.000	0
24	3	11	0	0.000	0

自主規制値
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m ³ N	μg/m ³ N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	2	8	1	0.000	0
2	3	11	1	0.000	0
3	2	8	1	0.000	0
4	2	10	1	0.000	0
5	2	14	1	0.000	0
6	3	11	1	0.000	0
7	2	10	1	0.000	0
8	3	10	1	0.000	0
9	3	9	1	0.000	0
10	2	11	1	0.000	0
11	2	10	1	0.000	0
12	2	11	1	0.000	0
13	2	11	1	0.000	0
14	2	11	1	0.000	0
15	2	10	1	0.000	0
16	2	12	1	0.000	0
17	2	11	1	0.000	0
18	2	10	1	0.000	0
19	2	11	1	0.000	0
20	2	11	1	0.000	0
21	3	12	1	0.000	0
22	2	12	1	0.000	0
23	2	11	1	0.000	0
24	2	13	1	0.000	0