

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年11月1日 (金)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	11	1	0.000	0
2	5	9	1	0.000	0
3	5	9	1	0.000	0
4	6	11	1	0.000	0
5	6	10	1	0.000	0
6	5	11	1	0.000	0
7	5	11	1	0.000	0
8	5	10	0	0.000	0
9	5	10	1	0.000	0
10	5	9	1	0.000	0
11	6	9	1	0.000	0
12	6	10	1	0.000	0
13	5	10	0	0.000	0
14	4	10	0	0.000	0
15	5	11	0	0.000	0
16	5	8	1	0.000	0
17	5	9	1	0.000	0
18	5	9	1	0.000	0
19	5	11	0	0.000	0
20	5	10	0	0.000	0
21	4	9	0	0.000	0
22	5	10	0	0.000	0
23	5	8	0	0.000	0
24	5	10	0	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	10	2	0.000	0
2	6	9	2	0.000	0
3	6	12	2	0.000	0
4	6	11	2	0.000	0
5	6	11	2	0.000	0
6	6	11	2	0.000	0
7	6	12	2	0.000	0
8	6	11	2	0.000	0
9	5	11	1	0.000	0
10	6	11	1	0.000	0
11	6	10	2	0.000	0
12	6	10	1	0.000	0
13	6	10	2	0.000	0
14	6	10	1	0.000	0
15	6	10	2	0.000	0
16	6	10	1	0.000	0
17	6	10	2	0.000	0
18	6	11	2	0.000	0
19	6	9	1	0.000	0
20	6	11	1	0.000	0
21	6	12	2	0.000	0
22	6	11	2	0.000	0
23	6	11	2	0.000	0
24	6	11	2	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年11月2日 (土)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	11	1	0.000	0
2	6	9	1	0.000	0
3	6	11	1	0.000	0
4	6	10	1	0.000	0
5	6	11	1	0.000	0
6	6	11	1	0.000	0
7	6	11	1	0.000	0
8	6	10	1	0.000	0
9	6	11	1	0.000	0
10	6	11	1	0.000	0
11	6	12	0	0.000	0
12	6	10	1	0.000	0
13	6	10	1	0.000	0
14	5	11	0	0.000	0
15	5	11	0	0.000	0
16	6	10	1	0.000	0
17	6	11	1	0.000	0
18	6	10	1	0.000	0
19	6	10	1	0.000	0
20	6	10	1	0.000	0
21	5	12	0	0.000	0
22	6	12	1	0.000	0
23	5	11	0	0.000	0
24	5	10	0	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	11	2	0.000	0
2	6	13	1	0.000	0
3	6	10	2	0.000	0
4	6	11	2	0.000	0
5	6	11	1	0.000	0
6	6	11	2	0.000	0
7	6	9	2	0.000	0
8	6	11	2	0.000	0
9	6	9	2	0.000	0
10	6	10	2	0.000	0
11	6	11	1	0.000	0
12	6	10	1	0.000	0
13	6	11	2	0.000	0
14	6	11	2	0.000	0
15	6	10	2	0.000	0
16	6	10	2	0.000	0
17	5	11	2	0.000	0
18	6	10	1	0.000	0
19	6	13	1	0.000	0
20	6	12	1	0.000	0
21	6	11	2	0.000	0
22	6	10	2	0.000	0
23	6	11	1	0.000	0
24	6	10	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年11月3日 (日)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	4	10	0	0.000	0
2	4	12	0	0.000	0
3	5	11	0	0.000	0
4	6	9	1	0.000	0
5	6	14	1	0.000	0
6	6	10	1	0.000	0
7	5	11	0	0.000	0
8	5	10	0	0.000	0
9	6	12	1	0.000	0
10	6	12	0	0.000	0
11	5	11	1	0.000	0
12	5	13	0	0.000	0
13	5	12	0	0.000	0
14	4	12	0	0.000	0
15	5	11	1	0.000	0
16	5	10	1	0.000	0
17	5	10	1	0.000	0
18	4	11	0	0.000	0
19	5	10	0	0.000	0
20	6	10	1	0.000	0
21	5	10	0	0.000	0
22	6	11	0	0.000	0
23	6	10	1	0.000	0
24	5	10	0	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	10	2	0.000	0
2	6	10	2	0.000	0
3	6	9	2	0.000	0
4	6	11	1	0.000	0
5	6	10	1	0.000	0
6	6	10	1	0.000	0
7	6	11	1	0.000	0
8	6	12	1	0.000	0
9	6	11	2	0.000	0
10	6	11	2	0.000	0
11	6	12	1	0.000	0
12	6	12	2	0.000	0
13	6	10	1	0.000	0
14	6	13	1	0.000	0
15	6	9	2	0.000	0
16	6	13	2	0.000	0
17	6	9	2	0.000	0
18	6	12	1	0.000	0
19	6	11	2	0.000	0
20	6	11	2	0.000	0
21	6	13	2	0.000	0
22	6	10	2	0.000	0
23	6	10	2	0.000	0
24	6	12	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年11月4日 (月)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	10	1	0.000	0
2	5	11	1	0.000	0
3	6	11	1	0.000	0
4	5	10	1	0.000	0
5	5	12	1	0.000	0
6	5	10	1	0.000	0
7	5	11	0	0.000	0
8	6	10	1	0.000	0
9	6	11	1	0.000	0
10	5	11	0	0.000	0
11	6	11	1	0.000	0
12	6	11	1	0.000	0
13	5	10	0	0.000	0
14	6	11	1	0.000	0
15	6	11	1	0.000	0
16	5	11	0	0.000	0
17	5	11	0	0.000	0
18	4	10	0	0.000	0
19	6	12	0	0.000	0
20	6	11	0	0.000	0
21	5	9	0	0.000	0
22	4	10	0	0.000	0
23	5	12	0	0.000	0
24	4	10	0	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	11	1	0.000	0
2	6	10	1	0.000	0
3	6	11	1	0.000	0
4	6	12	2	0.000	0
5	6	11	2	0.000	0
6	6	11	2	0.000	0
7	6	12	2	0.000	0
8	6	10	1	0.000	0
9	6	12	1	0.000	0
10	6	10	2	0.000	0
11	6	10	1	0.000	0
12	6	10	1	0.000	0
13	6	12	2	0.000	0
14	6	10	2	0.000	0
15	6	9	1	0.000	0
16	6	10	1	0.000	0
17	6	11	2	0.000	0
18	6	9	2	0.000	0
19	6	11	2	0.000	0
20	6	10	1	0.000	0
21	6	10	1	0.000	0
22	6	10	2	0.000	0
23	6	10	1	0.000	0
24	6	11	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年11月5日 (火)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	4	9	0	0.000	0
2	5	11	0	0.000	0
3	5	9	1	0.000	0
4	5	11	0	0.000	0
5	5	10	1	0.000	0
6	4	11	0	0.000	0
7	4	11	0	0.000	0
8	5	10	0	0.000	0
9	5	10	0	0.000	0
10	5	11	0	0.000	0
11	4	9	0	0.000	0
12	4	10	0	0.000	0
13	5	10	0	0.000	0
14	5	10	0	0.000	0
15	5	10	1	0.000	0
16	4	10	0	0.000	0
17	5	10	0	0.000	0
18	5	10	0	0.000	0
19	4	10	0	0.000	0
20	4	12	0	0.000	0
21	4	10	0	0.000	0
22	4	11	0	0.000	0
23	4	10	0	0.000	0
24	4	11	0	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	11	1	0.000	0
2	6	11	2	0.000	0
3	6	10	2	0.000	0
4	6	11	2	0.000	0
5	6	11	1	0.000	0
6	6	11	1	0.000	0
7	6	11	1	0.000	0
8	6	11	1	0.000	0
9	6	10	1	0.000	0
10	6	10	2	0.000	0
11	6	10	1	0.000	0
12	6	10	2	0.000	0
13	6	12	2	0.000	0
14	6	11	2	0.000	0
15	6	10	2	0.000	0
16	6	11	2	0.000	0
17	6	13	2	0.000	0
18	6	11	1	0.000	0
19	6	10	1	0.000	0
20	6	12	1	0.000	0
21	6	9	1	0.000	0
22	6	11	1	0.000	0
23	6	12	1	0.000	0
24	6	10	2	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年11月6日 (水)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	4	10	0	0.000	0
2	4	12	0	0.000	0
3	4	10	0	0.000	0
4	3	10	0	0.000	0
5	4	10	0	0.000	0
6	4	10	0	0.000	0
7	3	11	0	0.000	0
8	3	10	0	0.000	0
9	4	10	0	0.000	0
10	4	11	0	0.000	0
11	4	11	0	0.000	0
12	3	10	0	0.000	0
13	3	11	0	0.000	0
14	4	10	0	0.000	0
15	3	10	0	0.000	0
16	4	9	0	0.000	0
17	4	10	0	0.000	0
18	4	11	0	0.000	0
19	4	10	0	0.000	0
20	3	11	0	0.000	0
21	4	11	0	0.000	0
22	5	13	0	0.000	0
23	5	14	0	0.000	0
24	5	11	1	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	12	2	0.000	0
2	6	13	2	0.000	0
3	6	9	2	0.000	0
4	6	11	2	0.000	0
5	6	11	2	0.000	0
6	6	10	1	0.000	0
7	6	10	1	0.000	0
8	6	11	1	0.000	0
9	6	12	1	0.000	0
10	6	10	1	0.000	0
11	6	12	2	0.000	0
12	6	12	1	0.000	0
13	6	11	1	0.000	0
14	6	11	2	0.000	0
15	6	12	2	0.000	0
16	6	11	2	0.000	0
17	6	11	1	0.000	0
18	6	12	2	0.000	0
19	6	12	1	0.000	0
20	6	12	1	0.000	0
21	6	11	2	0.000	0
22	6	10	2	0.000	0
23	6	12	1	0.000	0
24	6	12	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年11月7日 (木)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	4	10	0	0.000	0
2	4	12	0	0.000	0
3	4	11	0	0.000	0
4	3	10	0	0.000	0
5	3	10	0	0.000	0
6	3	10	0	0.000	0
7	3	10	0	0.000	0
8	3	10	0	0.000	0
9	3	10	0	0.000	0
10	3	10	0	0.000	0
11	3	10	0	0.000	0
12	3	10	0	0.000	0
13	3	12	0	0.000	0
14	3	9	0	0.000	0
15	3	11	0	0.000	0
16	3	10	0	0.000	0
17	2	9	0	0.000	0
18	2	10	0	0.000	0
19	2	9	0	0.000	0
20	2	11	0	0.000	0
21	3	10	0	0.000	0
22	3	11	0	0.000	0
23	3	10	0	0.000	0
24	2	10	0	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	10	1	0.000	0
2	6	11	1	0.000	0
3	6	11	1	0.000	0
4	6	11	1	0.000	0
5	6	10	1	0.000	0
6	6	10	1	0.000	0
7	6	11	1	0.000	0
8	6	11	1	0.000	0
9	5	10	1	0.000	0
10	6	12	1	0.000	0
11	6	11	1	0.000	0
12	6	11	1	0.000	0
13	6	11	1	0.000	0
14	6	10	1	0.000	0
15	6	9	1	0.000	0
16	6	11	1	0.000	0
17	6	10	1	0.000	0
18	6	9	1	0.000	0
19	6	9	1	0.000	0
20	6	10	2	0.000	0
21	6	12	1	0.000	0
22	6	9	2	0.000	0
23	6	10	1	0.000	0
24	6	10	2	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年11月8日 (金)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	3	9	0	0.000	0
2	3	11	0	0.000	0
3	2	11	1	0.000	0
4	3	10	0	0.000	0
5	3	11	0	0.000	0
6	2	10	0	0.000	0
7	2	10	0	0.000	0
8	2	10	0	0.000	0
9	2	10	0	0.000	0
10	3	10	0	0.000	0
11	2	10	0	0.000	0
12	3	10	0	0.000	0
13	3	10	0	0.000	0
14	3	9	0	0.000	0
15	3	12	0	0.000	0
16	3	10	0	0.000	0
17	3	9	0	0.000	0
18	3	10	0	0.000	0
19	3	12	0	0.000	0
20	3	10	0	0.000	0
21	3	10	0	0.000	0
22	2	10	0	0.000	0
23	3	9	0	0.000	0
24	3	11	0	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	10	1	0.000	0
2	6	10	2	0.000	0
3	6	11	2	0.000	0
4	6	11	2	0.000	0
5	6	11	1	0.000	0
6	6	11	1	0.000	0
7	6	11	2	0.000	0
8	6	11	1	0.000	0
9	6	11	2	0.000	0
10	6	10	2	0.000	0
11	6	10	1	0.000	0
12	6	9	2	0.000	0
13	6	10	1	0.000	0
14	6	11	1	0.000	0
15	6	10	1	0.000	0
16	6	10	1	0.000	0
17	6	11	1	0.000	0
18	6	10	2	0.000	0
19	6	9	2	0.000	0
20	6	8	1	0.000	0
21	6	10	1	0.000	0
22	6	12	1	0.000	0
23	6	10	1	0.000	0
24	6	11	1	0.000	0



浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年11月9日 (土)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	3	9	0	0.000	0
2	3	11	0	0.000	0
3	3	10	0	0.000	0
4	3	11	0	0.000	0
5	3	10	0	0.000	0
6	3	10	0	0.000	0
7	3	10	0	0.000	0
8	3	12	0	0.000	0
9	3	12	0	0.000	0
10	3	10	0	0.000	0
11	3	10	0	0.000	0
12	3	10	0	0.000	0
13	3	11	0	0.000	0
14	3	11	0	0.000	0
15	3	11	0	0.000	0
16	3	12	0	0.000	0
17	3	10	0	0.000	0
18	3	11	0	0.000	0
19	3	11	0	0.000	0
20	3	10	0	0.000	0
21	3	10	0	0.000	0
22	3	11	0	0.000	0
23	3	10	0	0.000	0
24	3	9	0	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	10	2	0.000	0
2	6	11	2	0.000	0
3	6	12	2	0.000	0
4	6	13	2	0.000	0
5	6	12	2	0.000	0
6	6	11	1	0.000	0
7	6	12	2	0.000	0
8	6	11	2	0.000	0
9	6	11	1	0.000	0
10	6	12	1	0.000	0
11	6	11	1	0.000	0
12	6	11	1	0.000	0
13	6	12	1	0.000	0
14	6	10	1	0.000	0
15	6	10	1	0.000	0
16	6	10	1	0.000	0
17	6	11	1	0.000	0
18	6	13	2	0.000	0
19	6	11	2	0.000	0
20	6	11	2	0.000	0
21	6	13	2	0.000	0
22	6	10	1	0.000	0
23	6	10	1	0.000	0
24	6	9	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年11月10日 (日)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	3	10	0	0.000	0
2	3	13	0	0.000	0
3	3	9	0	0.000	0
4	3	11	0	0.000	0
5	2	10	0	0.000	0
6	3	12	0	0.000	0
7	3	10	0	0.000	0
8	3	12	0	0.000	0
9	3	11	0	0.000	0
10	3	10	0	0.000	0
11	2	10	0	0.000	0
12	3	11	0	0.000	0
13	3	11	0	0.000	0
14	3	12	0	0.000	0
15	3	10	0	0.000	0
16	3	11	0	0.000	0
17	3	10	0	0.000	0
18	3	8	0	0.000	0
19	3	11	0	0.000	0
20	3	11	0	0.000	0
21	3	10	0	0.000	0
22	2	10	0	0.000	0
23	3	10	0	0.000	0
24	3	11	0	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	11	1	0.000	0
2	6	10	1	0.000	0
3	6	11	1	0.000	0
4	6	10	2	0.000	0
5	6	11	2	0.000	0
6	6	12	1	0.000	0
7	6	9	1	0.000	0
8	6	10	1	0.000	0
9	6	11	1	0.000	0
10	6	10	1	0.000	0
11	6	11	1	0.000	0
12	6	10	1	0.000	0
13	5	9	1	0.000	0
14	6	10	1	0.000	0
15	6	10	1	0.000	0
16	6	10	1	0.000	0
17	6	10	1	0.000	0
18	6	10	1	0.000	0
19	6	10	1	0.000	0
20	6	10	1	0.000	0
21	6	11	1	0.000	0
22	6	10	1	0.000	0
23	6	11	1	0.000	0
24	6	10	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年11月11日 (月)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	3	9	0	0.000	0
2	3	10	0	0.000	0
3	3	11	0	0.000	0
4	3	10	0	0.000	0
5	3	11	0	0.000	0
6	3	10	0	0.000	0
7	3	10	0	0.000	0
8	3	10	0	0.000	0
9	3	11	0	0.000	0
10	3	11	0	0.000	0
11	3	13	0	0.000	0
12	3	11	0	0.000	0
13	3	11	0	0.000	0
14	3	12	0	0.000	0
15	3	10	0	0.000	0
16	3	11	0	0.000	0
17	3	9	0	0.000	0
18	3	11	0	0.000	0
19	3	10	0	0.000	0
20	3	11	0	0.000	0
21	3	9	0	0.000	0
22	3	10	0	0.000	0
23	3	11	0	0.000	0
24	3	11	0	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	10	1	0.000	0
2	6	11	2	0.000	0
3	6	10	2	0.000	0
4	6	11	1	0.000	0
5	5	10	1	0.000	0
6	6	11	1	0.000	0
7	6	11	1	0.000	0
8	6	10	1	0.000	0
9	6	12	1	0.000	0
10	6	11	1	0.000	0
11	5	11	1	0.000	0
12	6	11	1	0.000	0
13	4	9	1	0.000	0
14	4	10	1	0.000	0
15	4	10	1	0.000	0
16	5	11	1	0.000	0
17	6	11	1	0.000	0
18	4	9	1	0.000	0
19	4	11	1	0.000	0
20	5	10	1	0.000	0
21	5	11	1	0.000	0
22	4	11	1	0.000	0
23	4	10	1	0.000	0
24	4	10	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年11月12日 (火)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	3	9	0	0.000	0
2	3	10	0	0.000	0
3	3	12	0	0.000	0
4	2	9	0	0.000	0
5	2	10	0	0.000	0
6	2	10	0	0.000	0
7	2	11	0	0.000	0
8	2	10	0	0.000	0
9	3	10	0	0.000	0
10	3	10	0	0.000	0
11	4	10	0	0.000	0
12	4	10	0	0.000	0
13	4	11	0	0.000	0
14	4	8	0	0.000	0
15	4	10	0	0.000	0
16	4	12	0	0.000	0
17	3	10	0	0.000	0
18	3	11	0	0.000	0
19	3	12	0	0.000	0
20	3	8	0	0.000	0
21	3	9	0	0.000	0
22	3	9	0	0.000	0
23	3	10	0	0.000	0
24	3	10	0	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	4	11	1	0.000	0
2	4	10	1	0.000	0
3	3	10	1	0.000	0
4	4	11	1	0.000	0
5	4	10	1	0.000	0
6	4	9	1	0.000	0
7	4	11	1	0.000	0
8	4	11	1	0.000	0
9	5	11	1	0.000	0
10	7	12	1	0.000	0
11	6	10	1	0.000	0
12	6	10	1	0.000	0
13	6	10	1	0.000	0
14	6	12	1	0.000	0
15	6	10	2	0.000	0
16	6	10	2	0.000	0
17	6	11	1	0.000	0
18	6	11	1	0.000	0
19	6	10	1	0.000	0
20	6	10	1	0.000	0
21	6	9	1	0.000	0
22	6	10	1	0.000	0
23	6	10	1	0.000	0
24	6	11	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年11月13日 (水)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	3	11	0	0.000	0
2	4	10	0	0.000	0
3	3	11	0	0.000	0
4	4	10	0	0.000	0
5	4	11	0	0.000	0
6	4	11	0	0.000	0
7	4	11	0	0.000	0
8	4	11	0	0.000	0
9	5	10	0	0.000	0
10	5	10	0	0.000	0
11	4	10	0	0.000	0
12	4	11	0	0.000	0
13	4	10	0	0.000	0
14	5	11	1	0.000	0
15	5	9	1	0.000	0
16	4	11	0	0.000	0
17	4	12	0	0.000	0
18	4	11	0	0.000	0
19	3	10	0	0.000	0
20	3	11	0	0.000	0
21	4	9	0	0.000	0
22	3	9	0	0.000	0
23	4	10	0	0.000	0
24	3	11	0	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	12	1	0.000	0
2	6	12	1	0.000	0
3	6	11	1	0.000	0
4	6	11	1	0.000	0
5	6	11	1	0.000	0
6	6	11	1	0.000	0
7	6	12	1	0.000	0
8	6	11	1	0.000	0
9	6	11	1	0.000	0
10	6	12	1	0.000	0
11	6	12	2	0.000	0
12	6	10	1	0.000	0
13	6	10	2	0.000	0
14	6	11	1	0.000	0
15	6	12	2	0.000	0
16	6	13	1	0.000	0
17	6	11	1	0.000	0
18	6	10	1	0.000	0
19	6	11	2	0.000	0
20	6	11	2	0.000	0
21	6	10	2	0.000	0
22	6	9	2	0.000	0
23	6	10	1	0.000	0
24	5	10	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年11月14日 (木)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	4	10	0	0.000	0
2	5	10	0	0.000	0
3	4	13	0	0.000	0
4	4	10	0	0.000	0
5	3	9	0	0.000	0
6	3	10	0	0.000	0
7	3	12	0	0.000	0
8	4	11	0	0.000	0
9	3	11	0	0.000	0
10	4	11	1	0.000	0
11	3	8	0	0.000	0
12	3	11	0	0.000	0
13	4	10	0	0.000	0
14	4	10	0	0.000	0
15	3	10	0	0.000	0
16	3	11	0	0.000	0
17	4	11	0	0.000	0
18	4	10	0	0.000	0
19	4	10	0	0.000	0
20	4	10	0	0.000	0
21	4	11	0	0.000	0
22	4	12	0	0.000	0
23	4	9	0	0.000	0
24	4	11	0	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	9	2	0.000	0
2	6	12	2	0.000	0
3	6	10	1	0.000	0
4	6	10	1	0.000	0
5	6	10	1	0.000	0
6	6	9	2	0.000	0
7	6	10	2	0.000	0
8	6	9	2	0.000	0
9	6	11	1	0.000	0
10	6	10	2	0.000	0
11	6	11	2	0.000	0
12	6	10	1	0.000	0
13	6	10	1	0.000	0
14	6	8	1	0.000	0
15	6	10	1	0.000	0
16	6	10	2	0.000	0
17	6	10	2	0.000	0
18	6	10	2	0.000	0
19	6	9	2	0.000	0
20	6	10	2	0.000	0
21	6	11	1	0.000	0
22	6	10	2	0.000	0
23	6	10	2	0.000	0
24	6	11	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年11月15日 (金)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	4	11	0	0.000	0
2	4	11	0	0.000	0
3	4	10	0	0.000	0
4	4	11	0	0.000	0
5	4	9	0	0.000	0
6	4	11	0	0.000	0
7	3	11	0	0.000	0
8	4	10	0	0.000	0
9	4	10	0	0.000	0
10	4	10	0	0.000	0
11	3	10	0	0.000	0
12	4	10	0	0.000	0
13	3	10	0	0.000	0
14	4	10	0	0.000	0
15	3	11	0	0.000	0
16	3	12	0	0.000	0
17	4	11	0	0.000	0
18	3	9	0	0.000	0
19	3	10	0	0.000	0
20	3	10	0	0.000	0
21	3	9	0	0.000	0
22	4	10	0	0.000	0
23	4	10	0	0.000	0
24	3	10	0	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	10	1	0.000	0
2	6	12	2	0.000	0
3	6	10	2	0.000	0
4	6	10	1	0.000	0
5	6	11	1	0.000	0
6	6	11	2	0.000	0
7	6	11	1	0.000	0
8	6	10	1	0.000	0
9	6	10	1	0.000	0
10	6	11	1	0.000	0
11	6	10	1	0.000	0
12	6	11	1	0.000	0
13	6	9	1	0.000	0
14	6	11	1	0.000	0
15	6	10	2	0.000	0
16	6	10	1	0.000	0
17	6	11	1	0.000	0
18	6	11	1	0.000	0
19	6	12	2	0.000	0
20	6	9	2	0.000	0
21	6	9	2	0.000	0
22	6	10	1	0.000	0
23	6	11	1	0.000	0
24	6	9	2	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年11月16日 (土)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	4	11	0	0.000	0
2	3	11	0	0.000	0
3	3	10	0	0.000	0
4	3	10	0	0.000	0
5	4	9	0	0.000	0
6	3	10	0	0.000	0
7	3	10	0	0.000	0
8	3	10	0	0.000	0
9	3	10	0	0.000	0
10	4	10	0	0.000	0
11	4	9	0	0.000	0
12	4	10	0	0.000	0
13	3	11	0	0.000	0
14	4	11	0	0.000	0
15	3	10	0	0.000	0
16	3	8	0	0.000	0
17	3	11	0	0.000	0
18	4	10	0	0.000	0
19	4	10	0	0.000	0
20	4	9	0	0.000	0
21	4	10	0	0.000	0
22	3	9	0	0.000	0
23	4	10	0	0.000	0
24	4	9	0	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	10	1	0.000	0
2	6	12	1	0.000	0
3	6	12	2	0.000	0
4	6	10	2	0.000	0
5	6	12	1	0.000	0
6	6	10	2	0.000	0
7	6	10	2	0.000	0
8	6	11	2	0.000	0
9	6	11	2	0.000	0
10	6	10	2	0.000	0
11	6	11	1	0.000	0
12	6	10	1	0.000	0
13	6	11	1	0.000	0
14	6	10	1	0.000	0
15	6	11	1	0.000	0
16	6	11	2	0.000	0
17	6	11	2	0.000	0
18	6	11	1	0.000	0
19	6	11	1	0.000	0
20	6	12	1	0.000	0
21	6	11	1	0.000	0
22	6	11	1	0.000	0
23	6	10	1	0.000	0
24	6	11	1	0.000	0



浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年11月17日 (日)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	3	11	0	0.000	0
2	4	10	0	0.000	0
3	4	11	0	0.000	0
4	4	11	0	0.000	0
5	4	10	0	0.000	0
6	4	9	0	0.000	0
7	4	10	0	0.000	0
8	4	10	0	0.000	0
9	4	9	0	0.000	0
10	4	11	0	0.000	0
11	4	11	0	0.000	0
12	4	10	0	0.000	0
13	4	10	0	0.000	0
14	4	10	0	0.000	0
15	3	10	0	0.000	0
16	4	10	0	0.000	0
17	4	11	0	0.000	0
18	3	11	0	0.000	0
19	3	10	0	0.000	0
20	3	10	0	0.000	0
21	3	10	0	0.000	0
22	4	10	0	0.000	0
23	3	11	0	0.000	0
24	4	11	0	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	11	1	0.000	0
2	6	11	1	0.000	0
3	6	11	2	0.000	0
4	6	11	1	0.000	0
5	6	10	1	0.000	0
6	6	10	2	0.000	0
7	6	10	2	0.000	0
8	6	10	2	0.000	0
9	6	10	2	0.000	0
10	6	12	2	0.000	0
11	6	11	2	0.000	0
12	6	11	2	0.000	0
13	6	10	2	0.000	0
14	6	11	2	0.000	0
15	6	10	2	0.000	0
16	6	10	2	0.000	0
17	6	13	2	0.000	0
18	6	10	2	0.000	0
19	6	10	2	0.000	0
20	6	10	1	0.000	0
21	6	10	2	0.000	0
22	6	10	2	0.000	0
23	6	10	2	0.000	0
24	6	10	2	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年11月18日 (月)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	3	9	0	0.000	0
2	4	8	0	0.000	0
3	3	10	0	0.000	0
4	4	13	0	0.000	0
5	4	12	0	0.000	0
6	4	11	0	0.000	0
7	3	11	0	0.000	0
8	3	11	0	0.000	0
9	3	10	0	0.000	0
10	3	10	0	0.000	0
11	3	12	0	0.000	0
12	3	10	0	0.000	0
13	3	12	0	0.000	0
14	3	12	0	0.000	0
15	3	11	0	0.000	0
16	3	11	0	0.000	0
17	3	10	0	0.000	0
18	3	13	0	0.000	0
19	3	12	1	0.000	0
20	2	9	0	0.000	0
21	2	10	0	0.000	0
22	2	11	0	0.000	0
23	2	10	0	0.000	0
24	3	10	0	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	9	1	0.000	0
2	6	10	3	0.000	0
3	6	11	1	0.000	0
4	6	11	1	0.000	0
5	6	12	1	0.000	0
6	6	12	1	0.000	0
7	6	10	2	0.000	0
8	6	10	2	0.000	0
9	6	11	2	0.000	0
10	6	11	1	0.000	0
11	6	12	2	0.000	0
12	6	11	1	0.000	0
13	6	10	1	0.000	0
14	6	13	1	0.000	0
15	6	10	1	0.000	0
16	5	12	1	0.000	0
17	4	9	1	0.000	0
18	5	11	1	0.000	0
19	5	11	1	0.000	0
20	5	10	1	0.000	0
21	5	10	1	0.000	0
22	6	11	1	0.000	0
23	6	12	2	0.000	0
24	6	12	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年11月19日 (火)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	3	11	0	0.000	0
2	2	13	0	0.000	0
3	2	11	0	0.000	0
4	2	10	0	0.000	0
5	2	13	0	0.000	0
6	3	11	0	0.000	0
7	2	11	0	0.000	0
8	2	9	0	0.000	0
9	2	10	0	0.000	0
10	2	10	0	0.000	0
11	3	9	0	0.000	0
12	2	10	0	0.000	0
13	3	10	0	0.000	0
14	3	10	0	0.000	0
15	2	11	0	0.000	0
16	2	11	0	0.000	0
17	2	10	0	0.000	0
18	2	10	0	0.000	0
19	3	10	0	0.000	0
20	3	11	0	0.000	0
21	3	9	0	0.000	0
22	3	11	0	0.000	0
23	2	10	0	0.000	0
24	2	10	0	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	10	2	0.000	0
2	6	11	1	0.000	0
3	6	11	1	0.000	0
4	6	12	1	0.000	0
5	6	12	1	0.000	0
6	6	11	1	0.000	0
7	5	10	1	0.000	0
8	6	11	1	0.000	0
9	5	11	1	0.000	0
10	6	12	1	0.000	0
11	6	10	1	0.000	0
12	6	10	2	0.000	0
13	6	12	2	0.000	0
14	6	11	2	0.000	0
15	5	12	1	0.000	0
16	6	10	2	0.000	0
17	6	13	2	0.000	0
18	6	11	2	0.000	0
19	6	11	1	0.000	0
20	6	11	1	0.000	0
21	6	10	1	0.000	0
22	6	13	1	0.000	0
23	6	13	1	0.000	0
24	6	12	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

**環境監視日報**

2024年11月20日 (水)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	3	10	0	0.000	0
2	2	11	0	0.000	0
3	2	11	0	0.000	0
4	3	11	0	0.000	0
5	3	10	0	0.000	0
6	2	10	0	0.000	0
7	2	10	0	0.000	0
8	2	10	0	0.000	0
9	2	10	0	0.000	0
10	2	10	0	0.000	0
11	2	10	0	0.000	0
12	2	10	0	0.000	0
13	2	10	0	0.000	0
14	2	10	0	0.000	0
15	3	11	0	0.000	0
16	2	10	0	0.000	0
17	3	11	0	0.000	0
18	3	11	0	0.000	0
19	3	11	0	0.000	0
20	2	11	0	0.000	0
21	2	10	0	0.000	0
22	2	10	0	0.000	0
23	2	11	0	0.000	0
24	2	11	0	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	10	1	0.000	0
2	5	11	1	0.000	0
3	4	12	1	0.000	0
4	4	12	1	0.000	0
5	4	11	1	0.000	0
6	4	11	1	0.000	0
7	4	10	1	0.000	0
8	5	12	1	0.000	0
9	4	12	1	0.000	0
10	4	13	1	0.000	0
11	4	12	1	0.000	0
12	4	11	1	0.000	0
13	4	11	1	0.000	0
14	5	11	1	0.000	0
15	5	10	1	0.000	0
16	5	12	1	0.000	0
17	5	12	1	0.000	0
18	6	11	2	0.000	0
19	6	10	2	0.000	0
20	6	12	2	0.000	0
21	6	12	2	0.000	0
22	6	12	2	0.000	0
23	6	11	2	0.000	0
24	6	12	2	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年11月21日 (木)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	2	10	0	0.000	0
2	2	9	0	0.000	0
3	3	10	0	0.000	0
4	3	11	0	0.000	0
5	3	10	0	0.000	0
6	3	11	0	0.000	0
7	3	11	0	0.000	0
8	2	12	0	0.000	0
9	2	11	0	0.000	0
10	4	11	0	0.000	0
11	5	11	2	0.000	0
12	6	12	2	0.000	0
13	5	10	2	0.000	0
14	5	11	1	0.000	0
15	5	10	1	0.000	0
16	5	12	1	0.000	0
17	5	11	0	0.000	0
18	4	11	0	0.000	0
19	4	14	0	0.000	0
20	5	12	0	0.000	0
21	4	11	0	0.000	0
22	4	9	0	0.000	0
23	5	12	1	0.000	0
24	5	12	1	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	10	2	0.000	0
2	6	11	2	0.000	0
3	6	12	2	0.000	0
4	6	12	2	0.000	0
5	6	10	2	0.000	0
6	6	12	2	0.000	0
7	6	11	2	0.000	0
8	6	11	2	0.000	0
9	6	12	2	0.000	0
10	6	14	1	0.000	0
11	6	10	2	0.000	0
12	6	10	2	0.000	0
13	6	11	2	0.000	0
14	6	11	2	0.000	0
15	6	10	1	0.000	0
16	6	11	1	0.000	0
17	6	12	2	0.000	0
18	6	11	2	0.000	0
19	6	13	1	0.000	0
20	6	12	2	0.000	0
21	6	11	2	0.000	0
22	6	10	2	0.000	0
23	6	10	2	0.000	0
24	6	11	2	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年11月22日 (金)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	4	12	0	0.000	0
2	5	12	1	0.000	0
3	5	11	1	0.000	0
4	5	10	1	0.000	0
5	4	9	0	0.000	0
6	5	10	1	0.000	0
7	4	10	0	0.000	0
8	5	9	1	0.000	0
9	4	8	0	0.000	0
10	5	12	0	0.000	0
11	4	11	0	0.000	0
12	4	10	0	0.000	0
13	4	11	0	0.000	0
14	4	11	0	0.000	0
15	5	9	1	0.000	0
16	5	11	0	0.000	0
17	5	11	0	0.000	0
18	5	11	0	0.000	0
19	5	11	0	0.000	0
20	5	11	0	0.000	0
21	6	11	1	0.000	0
22	5	11	1	0.000	0
23	5	11	1	0.000	0
24	4	11	0	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	11	2	0.000	0
2	6	12	2	0.000	0
3	6	12	2	0.000	0
4	6	10	2	0.000	0
5	6	9	2	0.000	0
6	6	11	2	0.000	0
7	6	11	2	0.000	0
8	6	11	2	0.000	0
9	6	10	2	0.000	1
10	6	11	2	0.000	2
11	6	11	2	0.000	2
12	6	12	1	0.000	2
13	6	12	2	0.000	1
14	6	10	2	0.000	1
15	6	12	2	0.000	2
16	6	11	1	0.000	2
17	6	10	2	0.000	1
18	6	11	2	0.000	1
19	6	11	2	0.000	1
20	6	11	2	0.000	1
21	6	12	2	0.000	1
22	6	13	2	0.000	1
23	6	10	2	0.000	1
24	6	10	2	0.000	1

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年11月23日 (土)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	4	10	0	0.000	0
2	5	12	1	0.000	0
3	5	10	1	0.000	0
4	4	13	0	0.000	0
5	4	10	0	0.000	0
6	3	11	0	0.000	0
7	3	10	0	0.000	0
8	4	10	0	0.000	0
9	5	12	1	0.000	0
10	4	12	1	0.000	0
11	4	11	0	0.000	0
12	5	12	0	0.000	0
13	4	9	0	0.000	0
14	4	11	0	0.000	0
15	5	10	1	0.000	0
16	6	10	1	0.000	0
17	6	10	1	0.000	0
18	5	11	1	0.000	0
19	4	11	0	0.000	0
20	5	12	1	0.000	0
21	4	12	0	0.000	0
22	5	10	1	0.000	0
23	4	10	0	0.000	0
24	4	10	0	0.000	1

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	11	2	0.000	0
2	6	11	2	0.000	0
3	6	10	2	0.000	0
4	5	12	1	0.000	1
5	5	11	1	0.000	1
6	5	11	1	0.000	1
7	5	10	1	0.000	0
8	6	10	2	0.000	1
9	6	10	2	0.000	0
10	6	12	2	0.000	0
11	6	10	1	0.000	1
12	6	10	2	0.000	1
13	6	11	2	0.000	1
14	5	10	1	0.000	1
15	6	11	2	0.000	1
16	6	10	1	0.000	0
17	6	11	1	0.000	0
18	6	12	1	0.000	1
19	6	10	1	0.000	1
20	6	12	1	0.000	0
21	6	13	1	0.000	0
22	6	13	1	0.000	0
23	6	8	1	0.000	0
24	6	11	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年11月24日 (日)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	4	10	0	0.000	1
2	4	11	0	0.000	0
3	4	10	0	0.000	0
4	4	10	0	0.000	1
5	3	9	0	0.000	0
6	4	10	0	0.000	1
7	4	10	0	0.000	1
8	3	10	0	0.000	0
9	3	10	0	0.000	0
10	4	10	0	0.000	0
11	4	11	0	0.000	0
12	4	10	0	0.000	0
13	4	10	0	0.000	0
14	4	11	0	0.000	0
15	4	11	0	0.000	0
16	4	10	0	0.000	0
17	4	10	0	0.000	0
18	3	11	0	0.000	0
19	4	12	0	0.000	0
20	3	13	0	0.000	0
21	3	10	0	0.000	0
22	3	12	0	0.000	0
23	3	10	0	0.000	0
24	3	11	0	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	10	1	0.000	1
2	6	11	1	0.000	0
3	6	10	1	0.000	0
4	6	12	1	0.000	0
5	6	11	1	0.000	0
6	6	12	1	0.000	1
7	6	10	1	0.000	0
8	6	11	2	0.000	0
9	6	10	2	0.000	0
10	6	11	2	0.000	0
11	6	12	2	0.000	0
12	6	11	1	0.000	0
13	6	12	1	0.000	0
14	6	11	1	0.000	0
15	6	12	1	0.000	0
16	6	11	1	0.000	0
17	6	12	1	0.000	0
18	6	11	1	0.000	0
19	6	13	1	0.000	0
20	6	11	1	0.000	0
21	6	12	1	0.000	0
22	6	11	2	0.000	0
23	6	11	2	0.000	0
24	6	11	2	0.000	0



浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年11月25日 (月)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	3	12	0	0.000	0
2	3	12	0	0.000	0
3	3	11	0	0.000	0
4	3	11	0	0.000	0
5	2	14	0	0.000	0
6	3	11	0	0.000	0
7	3	9	0	0.000	0
8	2	11	0	0.000	0
9	3	11	0	0.000	0
10	2	11	0	0.000	0
11	2	9	0	0.000	0
12	2	11	0	0.000	0
13	2	10	0	0.000	0
14	3	12	0	0.000	0
15	3	11	0	0.000	0
16	3	10	0	0.000	0
17	3	11	0	0.000	0
18	3	11	0	0.000	0
19	3	10	0	0.000	0
20	3	11	0	0.000	0
21	3	10	0	0.000	0
22	3	10	0	0.000	0
23	3	13	0	0.000	0
24	3	9	0	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	12	1	0.000	0
2	6	12	1	0.000	0
3	6	12	1	0.000	0
4	6	10	2	0.000	0
5	5	12	1	0.000	0
6	6	14	1	0.000	0
7	6	10	1	0.000	0
8	6	10	1	0.000	0
9	6	11	1	0.000	0
10	6	10	1	0.000	0
11	6	11	1	0.000	0
12	5	13	1	0.000	0
13	6	9	1	0.000	0
14	6	9	1	0.000	0
15	6	13	1	0.000	0
16	6	12	2	0.000	0
17	6	12	1	0.000	0
18	6	12	2	0.000	0
19	6	13	2	0.000	0
20	6	11	2	0.000	0
21	6	11	2	0.000	0
22	6	11	2	0.000	0
23	6	12	2	0.000	0
24	6	10	2	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年11月26日 (火)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	3	13	0	0.000	1
2	3	11	0	0.000	1
3	3	10	0	0.000	1
4	3	11	0	0.000	0
5	3	14	0	0.000	0
6	3	10	0	0.000	1
7	3	6	0	0.000	1
8	3	12	0	0.000	1
9	3	11	0	0.000	0
10	2	10	0	0.000	0
11	3	10	0	0.000	0
12	3	12	0	0.000	0
13	3	8	0	0.000	0
14	3	10	0	0.000	0
15	3	9	0	0.000	0
16	3	10	0	0.000	0
17	3	10	0	0.000	0
18	4	13	0	0.000	0
19	3	11	0	0.000	0
20	3	10	0	0.000	0
21	3	12	0	0.000	0
22	4	11	0	0.000	0
23	3	10	0	0.000	0
24	3	11	0	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	11	2	0.000	0
2	6	11	2	0.000	0
3	6	14	2	0.000	0
4	6	9	1	0.000	0
5	6	11	2	0.000	0
6	6	14	1	0.000	0
7	6	13	1	0.000	0
8	6	14	1	0.000	0
9	6	8	1	0.000	0
10	6	9	1	0.000	0
11	6	11	2	0.000	0
12	6	10	2	0.000	0
13	6	11	1	0.000	0
14	6	11	1	0.000	0
15	6	11	2	0.000	0
16	6	12	2	0.000	0
17	6	12	2	0.000	0
18	6	8	1	0.000	0
19	6	9	2	0.000	0
20	6	13	2	0.000	0
21	6	13	2	0.000	0
22	6	12	2	0.000	0
23	6	12	1	0.000	0
24	6	12	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年11月27日 (水)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	3	10	0	0.000	0
2	3	10	0	0.000	0
3	3	11	0	0.000	0
4	3	11	0	0.000	0
5	3	11	0	0.000	0
6	3	10	0	0.000	0
7	4	11	0	0.000	0
8	4	12	0	0.000	0
9	4	11	0	0.000	0
10	3	11	0	0.000	0
11	3	11	0	0.000	0
12	3	10	0	0.000	0
13	4	10	0	0.000	0
14	4	9	0	0.000	0
15	4	10	0	0.000	0
16	4	10	0	0.000	0
17	4	10	0	0.000	0
18	4	10	0	0.000	63
19	5	10	0	0.000	39
20	5	10	0	0.000	18
21	4	10	0	0.000	12
22	4	11	0	0.000	8
23	5	11	0	0.000	7
24	5	11	1	0.000	6

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	12	2	0.000	0
2	6	11	2	0.000	0
3	6	11	2	0.000	0
4	6	15	1	0.000	0
5	6	11	1	0.000	0
6	6	12	1	0.000	0
7	6	10	1	0.000	0
8	6	10	1	0.000	0
9	6	11	1	0.000	0
10	6	10	2	0.000	0
11	5	12	1	0.000	0
12	6	10	2	0.000	0
13	6	9	2	0.000	0
14	6	10	2	0.000	0
15	6	11	2	0.000	0
16	6	11	1	0.000	0
17	6	11	2	0.000	0
18	6	10	2	0.000	0
19	6	10	1	0.000	1
20	6	12	1	0.000	1
21	6	11	1	0.000	1
22	6	12	1	0.000	1
23	6	13	1	0.000	1
24	6	13	2	0.000	1

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年11月28日 (木)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	4	12	0	0.000	5
2	3	11	0	0.000	3
3	4	10	0	0.000	2
4	3	11	0	0.000	1
5	3	10	0	0.000	1
6	3	12	0	0.000	1
7	3	10	0	0.000	1
8	3	10	0	0.000	1
9	3	11	0	0.000	1
10	4	9	0	0.000	1
11	4	10	0	0.000	1
12	4	11	0	0.000	1
13	4	11	0	0.000	1
14	4	11	0	0.000	1
15	4	11	0	0.000	1
16	4	12	0	0.000	0
17	4	13	0	0.000	0
18	4	11	0	0.000	1
19	4	11	0	0.000	0
20	4	13	0	0.000	0
21	4	11	0	0.000	0
22	3	11	0	0.000	1
23	3	11	0	0.000	1
24	3	11	0	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	11	2	0.000	1
2	6	12	2	0.000	1
3	6	11	2	0.000	1
4	6	11	2	0.000	1
5	6	10	2	0.000	1
6	6	11	2	0.000	1
7	6	12	1	0.000	1
8	6	13	1	0.000	1
9	6	11	1	0.000	1
10	6	11	1	0.000	1
11	6	13	2	0.000	1
12	6	14	2	0.000	1
13	6	10	2	0.000	1
14	6	10	2	0.000	1
15	6	12	2	0.000	1
16	6	10	2	0.000	1
17	6	12	2	0.000	1
18	6	12	2	0.000	1
19	6	12	2	0.000	0
20	6	10	2	0.000	1
21	6	13	2	0.000	1
22	6	12	1	0.000	1
23	6	12	2	0.000	0
24	6	11	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年11月29日 (金)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	3	11	0	0.000	0
2	3	10	0	0.000	0
3	3	10	0	0.000	0
4	3	10	0	0.000	0
5	3	10	0	0.000	1
6	3	10	0	0.000	1
7	3	10	0	0.000	0
8	3	10	0	0.000	0
9	3	9	0	0.000	0
10	3	9	0	0.000	0
11	3	11	0	0.000	0
12	3	10	0	0.000	0
13	3	9	0	0.000	0
14	3	10	0	0.000	0
15	3	11	0	0.000	0
16	3	10	0	0.000	0
17	3	10	0	0.000	0
18	3	10	0	0.000	0
19	3	9	0	0.000	0
20	3	11	0	0.000	0
21	3	10	0	0.000	0
22	3	11	0	0.000	0
23	3	10	0	0.000	0
24	3	10	0	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	11	1	0.000	0
2	6	11	2	0.000	0
3	6	10	2	0.000	0
4	6	11	2	0.000	0
5	6	11	2	0.000	1
6	6	11	1	0.000	1
7	6	11	1	0.000	0
8	6	12	1	0.000	0
9	6	10	1	0.000	0
10	6	11	1	0.000	0
11	6	11	1	0.000	0
12	6	10	1	0.000	0
13	6	12	1	0.000	0
14	6	11	2	0.000	0
15	6	11	2	0.000	0
16	6	10	2	0.000	0
17	6	11	1	0.000	0
18	6	13	2	0.000	0
19	6	10	2	0.000	0
20	6	13	2	0.000	0
21	6	11	2	0.000	0
22	6	11	2	0.000	0
23	6	12	1	0.000	0
24	6	13	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2024年11月30日 (土)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	3	10	0	0.000	0
2	3	12	0	0.000	0
3	2	11	0	0.000	0
4	2	12	0	0.000	0
5	3	10	0	0.000	0
6	3	9	0	0.000	0
7	3	10	0	0.000	0
8	3	11	0	0.000	0
9	3	10	0	0.000	0
10	3	11	0	0.000	0
11	3	10	0	0.000	0
12	3	11	0	0.000	0
13	3	12	0	0.000	0
14	4	11	0	0.000	0
15	4	10	0	0.000	0
16	4	10	0	0.000	0
17	3	11	0	0.000	0
18	4	10	0	0.000	0
19	3	10	0	0.000	0
20	3	11	0	0.000	0
21	3	11	0	0.000	0
22	3	11	0	0.000	0
23	3	10	0	0.000	0
24	3	12	0	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	6	12	1	0.000	0
2	6	10	1	0.000	0
3	6	13	1	0.000	0
4	6	11	2	0.000	0
5	6	12	2	0.000	0
6	6	11	2	0.000	0
7	6	10	2	0.000	0
8	6	12	1	0.000	0
9	6	12	1	0.000	0
10	6	11	1	0.000	0
11	6	10	2	0.000	0
12	6	13	2	0.000	0
13	6	11	1	0.000	0
14	6	11	1	0.000	0
15	6	12	1	0.000	0
16	6	12	1	0.000	0
17	6	11	1	0.000	0
18	6	11	1	0.000	0
19	6	10	2	0.000	0
20	6	10	1	0.000	0
21	6	11	1	0.000	0
22	6	10	2	0.000	0
23	6	12	2	0.000	0
24	5	14	1	0.000	0