

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2025年11月1日 (土)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	5	15	0	0.000	0
2	5	14	0	0.000	0
3	5	12	0	0.000	0
4	5	11	1	0.000	0
5	5	14	1	0.000	0
6	5	11	0	0.000	0
7	5	12	1	0.000	0
8	5	11	1	0.000	0
9	5	13	1	0.000	0
10	5	12	1	0.000	0
11	5	12	1	0.000	0
12	5	11	1	0.000	0
13	5	12	0	0.000	0
14	5	12	1	0.000	0
15	5	12	1	0.000	0
16	5	13	1	0.000	0
17	5	12	1	0.000	0
18	5	11	1	0.000	0
19	5	14	1	0.000	0
20	5	13	1	0.000	0
21	5	13	0	0.000	0
22	5	12	0	0.000	0
23	5	12	0	0.000	0
24	5	14	1	0.000	0

自主規制値
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	5	12	1	0.000	0
2	5	11	1	0.000	0
3	5	12	1	0.000	0
4	5	11	1	0.000	0
5	5	12	0	0.000	0
6	5	11	1	0.000	0
7	5	11	1	0.000	0
8	5	12	1	0.000	0
9	5	12	1	0.000	0
10	5	12	1	0.000	0
11	5	11	1	0.000	0
12	5	12	0	0.000	0
13	5	12	1	0.000	0
14	5	13	1	0.000	0
15	5	11	1	0.000	0
16	5	13	1	0.000	0
17	5	15	0	0.000	0
18	5	11	0	0.000	0
19	5	13	1	0.000	0
20	5	10	1	0.000	0
21	5	12	0	0.000	0
22	5	12	1	0.000	0
23	5	13	0	0.000	0
24	5	11	0	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2025年11月2日 (日)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
	430	250	約2700		0.040
1	5	11	1	0.000	0
2	5	13	1	0.000	0
3	5	12	1	0.000	0
4	5	12	1	0.000	0
5	5	13	1	0.000	0
6	5	11	0	0.000	0
7	5	13	1	0.000	0
8	5	12	1	0.000	0
9	5	10	0	0.000	0
10	5	14	1	0.000	0
11	4	6	0	0.000	0
12	5	12	1	0.000	0
13	5	12	0	0.000	0
14	5	12	0	0.000	0
15	5	12	0	0.000	0
16	5	10	0	0.000	0
17	5	12	0	0.000	0
18	5	12	0	0.000	0
19	5	12	0	0.000	0
20	5	11	0	0.000	0
21	5	12	0	0.000	0
22	5	13	0	0.000	0
23	5	11	0	0.000	0
24	5	14	0	0.000	0

自主規制値
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
	430	250	約2700		0.040
1	5	11	1	0.000	0
2	5	12	1	0.000	0
3	5	11	0	0.000	0
4	5	12	1	0.000	0
5	5	11	1	0.000	0
6	5	12	1	0.000	0
7	5	13	0	0.000	0
8	5	10	1	0.000	0
9	5	10	1	0.000	0
10	5	11	0	0.000	0
11	5	11	1	0.000	0
12	5	12	1	0.000	0
13	5	13	1	0.000	0
14	5	9	1	0.000	0
15	5	12	0	0.000	0
16	5	11	1	0.000	0
17	5	12	1	0.000	0
18	5	11	1	0.000	0
19	5	11	1	0.000	0
20	5	11	1	0.000	0
21	5	11	0	0.000	0
22	5	11	0	0.000	0
23	5	11	0	0.000	0
24	5	11	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2025年11月3日 (月)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
	430	250	約2700		50
1	5	11	0	0.000	0
2	5	11	1	0.000	0
3	5	12	0	0.000	0
4	5	13	1	0.000	0
5	5	12	1	0.000	0
6	5	13	1	0.000	0
7	5	13	1	0.000	0
8	5	12	1	0.000	0
9	5	13	1	0.000	0
10	5	12	1	0.000	0
11	5	13	0	0.000	0
12	5	11	1	0.000	0
13	5	16	0	0.000	0
14	5	10	0	0.000	0
15	5	10	1	0.000	0
16	5	13	1	0.000	0
17	5	11	1	0.000	0
18	5	14	1	0.000	0
19	5	7	1	0.000	0
20	5	13	1	0.000	0
21	5	13	0	0.000	0
22	5	11	0	0.000	0
23	5	13	0	0.000	0
24	5	10	0	0.000	0

自主規制値
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
	430	250	約2700		50
1	5	11	0	0.000	0
2	5	11	1	0.000	0
3	5	11	1	0.000	0
4	5	12	1	0.000	0
5	5	13	1	0.000	0
6	5	11	1	0.000	0
7	5	11	1	0.000	0
8	5	11	1	0.000	0
9	5	10	1	0.000	0
10	5	10	1	0.000	0
11	5	11	1	0.000	0
12	5	11	0	0.000	0
13	5	12	0	0.000	0
14	5	9	0	0.000	0
15	5	15	0	0.000	0
16	5	8	0	0.000	0
17	5	12	0	0.000	0
18	5	12	1	0.000	0
19	5	11	1	0.000	0
20	5	11	1	0.000	0
21	5	12	1	0.000	0
22	5	10	1	0.000	0
23	5	10	1	0.000	0
24	5	13	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2025年11月4日 (火)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
	430	250	約2700		50
1	5	11	1	0.000	0
2	5	12	0	0.000	0
3	5	11	1	0.000	0
4	5	12	1	0.000	0
5	5	11	1	0.000	0
6	5	11	1	0.000	0
7	5	13	1	0.000	0
8	5	10	0	0.000	0
9	5	11	1	0.000	0
10	5	13	1	0.000	0
11	5	14	1	0.000	0
12	5	10	1	0.000	0
13	5	12	1	0.000	0
14	5	12	1	0.000	0
15	5	12	0	0.000	0
16	5	10	1	0.000	0
17	5	11	1	0.000	0
18	5	12	1	0.000	0
19	5	12	1	0.000	0
20	5	12	1	0.000	0
21	5	11	1	0.000	0
22	5	11	1	0.000	0
23	5	12	1	0.000	0
24	5	12	1	0.000	0

自主規制値
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
	430	250	約2700		50
1	5	8	1	0.000	0
2	5	12	1	0.000	0
3	5	12	1	0.000	0
4	5	11	1	0.000	0
5	5	11	1	0.000	0
6	5	11	1	0.000	0
7	5	11	1	0.000	0
8	5	11	1	0.000	0
9	5	12	1	0.000	0
10	5	10	1	0.000	0
11	5	12	1	0.000	0
12	5	11	0	0.000	0
13	5	12	0	0.000	0
14	5	11	0	0.000	0
15	5	11	0	0.000	0
16	5	10	1	0.000	0
17	5	13	0	0.000	0
18	5	10	0	0.000	0
19	5	12	0	0.000	0
20	5	11	1	0.000	0
21	5	11	1	0.000	0
22	5	13	1	0.000	0
23	5	12	1	0.000	0
24	5	11	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2025年11月5日 (水)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
	430	250	約2700		50
1	5	10	1	0.000	0
2	5	14	1	0.000	0
3	5	10	1	0.000	0
4	5	13	1	0.000	0
5	5	13	1	0.000	0
6	5	14	1	0.000	0
7	5	11	1	0.000	0
8	5	11	1	0.000	0
9	5	13	1	0.000	0
10	5	11	1	0.000	0
11	5	12	1	0.000	0
12	5	12	1	0.000	0
13	5	12	1	0.000	0
14	5	12	1	0.000	0
15	5	12	1	0.000	0
16	5	16	0	0.000	0
17	5	4	0	0.000	0
18	5	14	0	0.000	0
19	5	7	0	0.000	0
20	5	13	0	0.000	0
21	5	11	0	0.000	0
22	5	11	1	0.000	0
23	5	12	1	0.000	0
24	5	11	1	0.000	0

自主規制値
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
	430	250	約2700		50
1	5	12	1	0.000	0
2	5	11	1	0.000	0
3	5	13	1	0.000	0
4	5	12	1	0.000	0
5	5	11	1	0.000	0
6	5	12	1	0.000	0
7	5	11	1	0.000	0
8	5	11	1	0.000	0
9	5	12	1	0.000	0
10	5	12	1	0.000	0
11	5	12	1	0.000	0
12	5	12	1	0.000	0
13	5	11	0	0.000	0
14	5	11	1	0.000	0
15	5	11	0	0.000	0
16	5	11	0	0.000	0
17	5	10	0	0.000	0
18	5	11	0	0.000	0
19	5	10	0	0.000	0
20	5	13	0	0.000	0
21	5	11	1	0.000	0
22	5	11	1	0.000	0
23	5	12	1	0.000	0
24	5	13	0	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2025年11月6日 (木)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
	430	250	約2700		50
1	5	14	0	0.000	0
2	5	7	0	0.000	0
3	5	14	0	0.000	0
4	5	12	0	0.000	0
5	5	12	1	0.000	0
6	5	11	1	0.000	0
7	5	11	1	0.000	0
8	5	12	1	0.000	0
9	5	12	1	0.000	0
10	5	12	0	0.000	0
11	5	12	0	0.000	0
12	5	12	1	0.000	0
13	5	13	1	0.000	0
14	5	11	1	0.000	0
15	5	12	0	0.000	0
16	5	13	1	0.000	0
17	5	12	0	0.000	0
18	5	12	1	0.000	0
19	5	13	1	0.000	0
20	5	12	0	0.000	0
21	5	11	1	0.000	0
22	5	10	0	0.000	0
23	5	10	0	0.000	0
24	5	11	0	0.000	0

自主規制値
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
	430	250	約2700		50
1	5	13	0	0.000	0
2	5	9	0	0.000	0
3	5	10	0	0.000	0
4	5	13	1	0.000	0
5	5	12	1	0.000	0
6	5	12	1	0.000	0
7	5	13	0	0.000	0
8	5	12	1	0.000	0
9	5	12	0	0.000	0
10	5	13	0	0.000	0
11	5	13	0	0.000	0
12	5	12	1	0.000	0
13	5	12	1	0.000	0
14	5	11	1	0.000	0
15	5	12	1	0.000	0
16	5	13	1	0.000	0
17	5	12	1	0.000	0
18	5	13	0	0.000	0
19	5	13	1	0.000	0
20	5	13	1	0.000	0
21	5	12	1	0.000	0
22	5	11	1	0.000	0
23	5	13	1	0.000	0
24	5	11	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2025年11月7日 (金)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
	430	250	約2700		50
1	5	11	0	0.000	0
2	5	14	1	0.000	0
3	5	11	1	0.000	0
4	5	11	1	0.000	0
5	5	12	1	0.000	0
6	5	11	1	0.000	0
7	5	12	1	0.000	0
8	5	14	1	0.000	0
9	5	12	1	0.000	0
10	5	13	1	0.000	0
11	5	11	0	0.000	0
12	5	12	0	0.000	0
13	5	12	1	0.000	0
14	5	12	1	0.000	0
15	5	11	0	0.000	0
16	5	14	0	0.000	0
17	5	11	1	0.000	0
18	5	9	1	0.000	0
19	5	13	1	0.000	0
20	4	8	1	0.000	0
21	5	11	1	0.000	0
22	5	12	1	0.000	0
23	5	13	1	0.000	0
24	5	11	1	0.000	0

自主規制値
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
	430	250	約2700		50
1	5	12	1	0.000	0
2	5	11	0	0.000	0
3	5	11	0	0.000	0
4	5	11	1	0.000	0
5	5	12	1	0.000	0
6	5	12	1	0.000	0
7	5	12	1	0.000	0
8	5	12	1	0.000	0
9	5	12	1	0.000	0
10	5	11	1	0.000	0
11	5	11	1	0.000	0
12	5	14	1	0.000	0
13	5	10	1	0.000	0
14	5	11	1	0.000	0
15	5	12	1	0.000	0
16	5	11	1	0.000	0
17	5	12	1	0.000	0
18	5	11	0	0.000	0
19	5	12	1	0.000	0
20	5	11	1	0.000	0
21	5	10	1	0.000	0
22	5	11	2	0.000	0
23	5	13	1	0.000	0
24	5	11	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2025年11月8日 (土)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
	430	250	約2700		50
1	5	12	1	0.000	0
2	5	13	1	0.000	0
3	5	13	1	0.000	0
4	5	13	1	0.000	0
5	5	10	1	0.000	0
6	5	13	1	0.000	0
7	5	12	1	0.000	0
8	5	13	1	0.000	0
9	5	10	1	0.000	0
10	5	13	1	0.000	0
11	5	13	1	0.000	0
12	5	11	1	0.000	0
13	5	11	1	0.000	0
14	5	12	1	0.000	0
15	5	12	1	0.000	0
16	5	12	1	0.000	0
17	5	14	1	0.000	0
18	5	12	1	0.000	0
19	5	12	1	0.000	0
20	5	13	1	0.000	0
21	5	14	1	0.000	0
22	5	10	1	0.000	0
23	5	11	1	0.000	0
24	5	10	1	0.000	0

自主規制値
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
	430	250	約2700		50
1	5	11	1	0.000	0
2	5	11	1	0.000	0
3	5	13	1	0.000	0
4	5	12	1	0.000	0
5	5	12	1	0.000	0
6	5	12	1	0.000	0
7	5	12	1	0.000	0
8	5	12	1	0.000	0
9	5	11	1	0.000	0
10	5	13	1	0.000	0
11	5	12	1	0.000	0
12	5	12	1	0.000	0
13	5	13	1	0.000	0
14	5	13	1	0.000	0
15	5	12	1	0.000	0
16	5	12	1	0.000	0
17	5	12	2	0.000	0
18	5	13	1	0.000	0
19	5	13	1	0.000	0
20	5	12	1	0.000	0
21	5	10	1	0.000	0
22	5	13	1	0.000	0
23	5	11	1	0.000	0
24	5	12	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2025年11月9日 (日)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
	430	250	約2700		50
1	5	14	1	0.000	0
2	5	12	1	0.000	0
3	5	11	1	0.000	0
4	5	11	1	0.000	0
5	5	12	1	0.000	0
6	5	12	1	0.000	0
7	5	11	1	0.000	0
8	5	11	1	0.000	0
9	5	12	1	0.000	0
10	5	11	1	0.000	0
11	5	12	0	0.000	0
12	5	12	1	0.000	0
13	5	12	0	0.000	0
14	5	13	0	0.000	0
15	5	10	0	0.000	0
16	5	12	0	0.000	0
17	5	13	0	0.000	0
18	5	12	0	0.000	0
19	5	11	0	0.000	0
20	5	11	1	0.000	0
21	5	11	0	0.000	0
22	5	13	0	0.000	0
23	5	11	0	0.000	0
24	5	10	1	0.000	0

自主規制値
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
	430	250	約2700		50
1	5	11	1	0.000	0
2	5	12	1	0.000	0
3	5	12	1	0.000	0
4	5	11	1	0.000	0
5	5	11	1	0.000	0
6	5	12	1	0.000	0
7	5	13	1	0.000	0
8	5	11	1	0.000	0
9	5	12	1	0.000	0
10	5	11	1	0.000	0
11	5	12	1	0.000	0
12	5	12	1	0.000	0
13	5	11	1	0.000	0
14	5	10	1	0.000	0
15	5	11	1	0.000	0
16	5	11	0	0.000	0
17	5	11	1	0.000	0
18	5	11	1	0.000	0
19	5	11	1	0.000	0
20	5	9	1	0.000	0
21	5	11	1	0.000	0
22	5	10	1	0.000	0
23	5	10	1	0.000	0
24	5	14	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2025年11月10日 (月)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
	430	250	約2700		50
1	5	14	0	0.000	0
2	5	9	1	0.000	0
3	5	11	1	0.000	0
4	5	11	1	0.000	0
5	5	11	1	0.000	0
6	5	10	1	0.000	0
7	5	12	1	0.000	0
8	5	12	1	0.000	0
9	5	10	1	0.000	0
10	5	12	1	0.000	0
11	5	12	1	0.000	0
12	5	11	0	0.000	0
13	5	13	0	0.000	0
14	5	14	0	0.000	0
15	5	10	0	0.000	0
16	4	13	0	0.000	0
17	5	10	0	0.000	0
18	5	11	1	0.000	0
19	5	10	0	0.000	0
20	5	10	0	0.000	0
21	5	12	0	0.000	0
22	5	10	0	0.000	0
23	5	11	0	0.000	0
24	5	10	0	0.000	0

自主規制値
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
	430	250	約2700		50
1	5	11	1	0.000	0
2	5	12	1	0.000	0
3	5	11	1	0.000	0
4	5	11	1	0.000	0
5	5	11	1	0.000	0
6	5	13	1	0.000	0
7	5	10	1	0.000	0
8	5	13	0	0.000	0
9	5	10	1	0.000	0
10	5	11	1	0.000	0
11	5	11	1	0.000	0
12	5	11	1	0.000	0
13	5	11	1	0.000	0
14	5	12	1	0.000	0
15	5	10	1	0.000	0
16	5	11	1	0.000	0
17	5	11	1	0.000	0
18	5	11	1	0.000	0
19	5	10	1	0.000	0
20	5	11	0	0.000	0
21	5	12	0	0.000	0
22	5	9	1	0.000	0
23	5	10	1	0.000	0
24	5	11	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2025年11月11日 (火)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
	430	250	約2700		50
1	5	10	1	0.000	0
2	5	11	1	0.000	0
3	5	12	1	0.000	0
4	5	10	0	0.000	0
5	5	11	0	0.000	0
6	5	10	1	0.000	0
7	5	10	1	0.000	0
8	5	11	1	0.000	0
9	5	12	1	0.000	0
10	5	11	1	0.000	0
11	5	9	1	0.000	0
12	5	12	1	0.000	0
13	5	11	1	0.000	0
14	5	12	1	0.000	0
15	5	12	1	0.000	0
16	5	11	1	0.000	0
17	5	13	1	0.000	0
18	5	11	1	0.000	0
19	5	12	1	0.000	0
20	5	11	1	0.000	0
21	5	12	0	0.000	0
22	5	11	1	0.000	0
23	5	13	0	0.000	0
24	5	12	0	0.000	0

自主規制値
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
	430	250	約2700		50
1	5	10	1	0.000	0
2	5	11	1	0.000	0
3	5	11	1	0.000	0
4	5	10	1	0.000	0
5	5	11	1	0.000	0
6	5	11	1	0.000	0
7	5	13	1	0.000	0
8	5	12	1	0.000	0
9	5	12	1	0.000	0
10	5	11	1	0.000	0
11	5	10	1	0.000	0
12	5	11	1	0.000	0
13	5	12	1	0.000	0
14	5	11	1	0.000	0
15	5	10	1	0.000	0
16	5	11	1	0.000	0
17	5	11	1	0.000	0
18	5	11	1	0.000	0
19	5	11	1	0.000	0
20	5	10	1	0.000	0
21	5	11	1	0.000	0
22	5	11	1	0.000	0
23	5	13	1	0.000	0
24	5	12	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2025年11月12日 (水)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
	430	250	約2700		50
1	5	12	0	0.000	0
2	5	12	0	0.000	0
3	5	10	1	0.000	0
4	5	11	1	0.000	0
5	5	11	1	0.000	0
6	5	11	1	0.000	0
7	5	11	1	0.000	0
8	5	11	1	0.000	0
9	5	14	1	0.000	0
10	5	11	1	0.000	0
11	5	11	1	0.000	0
12	5	11	1	0.000	0
13	5	12	1	0.000	0
14	5	13	1	0.000	0
15	5	12	1	0.000	0
16	5	14	1	0.000	0
17	5	9	1	0.000	0
18	5	10	1	0.000	0
19	5	11	1	0.000	0
20	5	10	1	0.000	0
21	5	12	1	0.000	0
22	5	11	1	0.000	0
23	5	13	1	0.000	0
24	5	11	1	0.000	0

自主規制値
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
	430	250	約2700		50
1	5	11	1	0.000	0
2	5	11	1	0.000	0
3	5	11	1	0.000	0
4	5	11	1	0.000	0
5	5	10	1	0.000	0
6	5	11	1	0.000	0
7	5	11	1	0.000	0
8	5	11	1	0.000	0
9	5	11	1	0.000	0
10	5	10	1	0.000	0
11	5	11	1	0.000	0
12	5	10	1	0.000	0
13	5	11	1	0.000	0
14	5	13	1	0.000	0
15	5	13	0	0.000	0
16	5	11	1	0.000	0
17	5	12	0	0.000	0
18	5	12	1	0.000	0
19	5	11	0	0.000	0
20	5	12	0	0.000	0
21	5	13	1	0.000	0
22	5	11	1	0.000	0
23	5	10	1	0.000	0
24	5	11	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2025年11月13日 (木)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	5	11	1	0.000	0
2	5	13	1	0.000	0
3	5	11	1	0.000	0
4	5	10	1	0.000	0
5	5	11	1	0.000	0
6	5	13	1	0.000	0
7	5	11	1	0.000	0
8	5	11	1	0.000	0
9	5	12	1	0.000	0
10	5	11	1	0.000	0
11	5	12	1	0.000	0
12	5	10	1	0.000	0
13	5	12	0	0.000	0
14	5	10	1	0.000	0
15	5	11	1	0.000	0
16	5	12	1	0.000	0
17	5	11	1	0.000	0
18	5	11	0	0.000	0
19	5	12	1	0.000	0
20	5	11	1	0.000	0
21	5	11	1	0.000	0
22	5	12	1	0.000	0
23	5	10	1	0.000	0
24	5	13	0	0.000	0

自主規制値
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
430	250	約2700	0.040	50	
1	5	11	1	0.000	0
2	5	11	1	0.000	0
3	5	12	1	0.000	0
4	5	11	1	0.000	0
5	5	12	1	0.000	0
6	5	12	1	0.000	0
7	5	10	1	0.000	0
8	5	12	1	0.000	0
9	5	12	1	0.000	0
10	5	11	1	0.000	0
11	5	10	0	0.000	0
12	5	10	0	0.000	0
13	5	11	1	0.000	0
14	5	10	1	0.000	0
15	5	10	1	0.000	0
16	5	11	1	0.000	0
17	5	11	0	0.000	0
18	5	12	0	0.000	0
19	5	11	0	0.000	0
20	5	10	0	0.000	0
21	5	11	0	0.000	0
22	5	11	0	0.000	0
23	5	12	0	0.000	0
24	5	11	0	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2025年11月14日 (金)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
	430	250	約2700		50
1	5	11	1	0.000	0
2	5	11	0	0.000	0
3	5	11	1	0.000	0
4	5	11	1	0.000	0
5	5	12	1	0.000	0
6	5	11	1	0.000	0
7	5	12	1	0.000	0
8	5	12	1	0.000	0
9	5	10	1	0.000	0
10	5	11	1	0.000	0
11	5	10	1	0.000	0
12	5	10	1	0.000	0
13	5	10	1	0.000	0
14	5	12	1	0.000	0
15	5	11	1	0.000	0
16	5	13	1	0.000	0
17	5	10	1	0.000	0
18	5	14	1	0.000	0
19	5	11	1	0.000	0
20	5	13	1	0.000	0
21	5	10	1	0.000	0
22	5	11	1	0.000	0
23	5	13	1	0.000	0
24	5	11	0	0.000	0

自主規制値
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
	430	250	約2700		50
1	5	11	1	0.000	0
2	5	12	0	0.000	0
3	5	11	0	0.000	0
4	5	12	0	0.000	0
5	5	13	0	0.000	0
6	5	10	1	0.000	0
7	5	11	1	0.000	0
8	5	10	1	0.000	0
9	5	12	1	0.000	0
10	5	13	1	0.000	0
11	5	11	1	0.000	0
12	5	10	1	0.000	0
13	5	12	1	0.000	0
14	5	10	1	0.000	0
15	5	11	1	0.000	0
16	5	11	1	0.000	0
17	5	12	1	0.000	0
18	5	11	1	0.000	0
19	5	13	1	0.000	0
20	5	12	1	0.000	0
21	5	12	1	0.000	0
22	5	11	1	0.000	0
23	5	13	1	0.000	0
24	5	11	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2025年11月15日 (土)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	µg/m³N
	10	20	10	0.005	50
	430	250	約2700		50
1	5	12	1	0.000	0
2	5	12	1	0.000	0
3	5	10	1	0.000	0
4	5	11	1	0.000	0
5	5	13	0	0.000	0
6	5	11	1	0.000	0
7	5	12	1	0.000	0
8	5	13	1	0.000	0
9	5	11	0	0.000	0
10	5	12	1	0.000	0
11	5	12	1	0.000	0
12	5	11	1	0.000	0
13	5	11	1	0.000	0
14	5	12	1	0.000	0
15	5	11	1	0.000	0
16	5	12	0	0.000	0
17	5	12	1	0.000	0
18	5	11	1	0.000	0
19	5	11	0	0.000	0
20	5	12	0	0.000	0
21	5	12	0	0.000	0
22	5	11	1	0.000	0
23	5	11	1	0.000	0
24	5	11	1	0.000	0

自主規制値
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	µg/m³N
	10	20	10	0.005	50
	430	250	約2700		50
1	5	11	1	0.000	0
2	5	12	1	0.000	0
3	5	12	1	0.000	0
4	5	11	1	0.000	0
5	5	11	1	0.000	0
6	5	11	1	0.000	0
7	5	11	1	0.000	0
8	5	10	1	0.000	0
9	5	11	1	0.000	0
10	5	11	1	0.000	0
11	5	11	1	0.000	0
12	5	12	1	0.000	0
13	5	10	1	0.000	0
14	5	12	1	0.000	0
15	5	12	1	0.000	0
16	5	9	1	0.000	0
17	5	10	1	0.000	0
18	5	12	1	0.000	0
19	5	11	1	0.000	0
20	5	12	1	0.000	0
21	5	11	0	0.000	0
22	5	10	1	0.000	0
23	5	12	1	0.000	0
24	5	10	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2025年11月16日 (日)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
	430	250	約2700		50
1	5	10	1	0.000	0
2	5	12	1	0.000	0
3	5	13	0	0.000	0
4	5	12	1	0.000	0
5	5	6	0	0.000	0
6	5	11	0	0.000	0
7	5	10	1	0.000	0
8	5	15	1	0.000	0
9	5	9	0	0.000	0
10	5	14	0	0.000	0
11	5	11	1	0.000	0
12	5	13	0	0.000	0
13	5	10	0	0.000	0
14	5	13	1	0.000	0
15	5	10	1	0.000	0
16	5	14	0	0.000	0
17	5	11	1	0.000	0
18	5	12	1	0.000	0
19	5	12	1	0.000	0
20	5	12	1	0.000	0
21	5	10	1	0.000	0
22	5	11	0	0.000	0
23	5	13	0	0.000	0
24	5	10	0	0.000	0

自主規制値
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
	430	250	約2700		50
1	5	12	1	0.000	0
2	5	9	1	0.000	0
3	5	12	1	0.000	0
4	5	11	1	0.000	0
5	5	11	1	0.000	0
6	5	12	1	0.000	0
7	5	10	1	0.000	0
8	5	12	0	0.000	0
9	5	13	0	0.000	0
10	5	12	0	0.000	0
11	5	11	1	0.000	0
12	5	9	0	0.000	0
13	5	10	1	0.000	0
14	5	10	1	0.000	0
15	5	10	1	0.000	0
16	5	11	1	0.000	0
17	5	10	1	0.000	0
18	5	11	1	0.000	0
19	5	12	1	0.000	0
20	5	12	1	0.000	0
21	5	10	1	0.000	0
22	5	10	1	0.000	0
23	5	11	0	0.000	0
24	5	11	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2025年11月17日 (月)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	13	0	0.000	0
2	5	11	1	0.000	0
3	5	11	0	0.000	0
4	5	11	1	0.000	0
5	5	12	1	0.000	0
6	5	12	1	0.000	0
7	5	9	1	0.000	0
8	5	13	0	0.000	0
9	5	11	1	0.000	0
10	5	12	1	0.000	0
11	5	13	0	0.000	0
12	5	10	0	0.000	0
13	5	11	1	0.000	0
14	5	11	0	0.000	0
15	5	14	0	0.000	0
16	5	11	1	0.000	0
17	5	10	1	0.000	0
18	5	14	0	0.000	0
19	5	11	1	0.000	0
20	5	13	1	0.000	0
21	5	11	1	0.000	0
22	5	11	1	0.000	0
23	5	13	0	0.000	0
24	5	13	0	0.000	0

自主規制値
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	11	0	0.000	0
2	5	10	0	0.000	0
3	5	11	1	0.000	0
4	5	11	0	0.000	0
5	5	12	0	0.000	0
6	5	10	1	0.000	0
7	5	11	1	0.000	0
8	5	11	1	0.000	0
9	5	11	0	0.000	0
10	5	11	0	0.000	0
11	5	11	1	0.000	0
12	5	11	1	0.000	0
13	5	10	1	0.000	0
14	5	11	1	0.000	0
15	5	11	1	0.000	0
16	5	10	1	0.000	0
17	5	12	1	0.000	0
18	5	14	1	0.000	0
19	5	13	1	0.000	0
20	5	11	1	0.000	0
21	5	10	1	0.000	0
22	5	12	1	0.000	0
23	5	10	1	0.000	0
24	5	11	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2025年11月18日 (火)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
	430	250	約2700		50
1	5	13	0	0.000	0
2	5	12	0	0.000	0
3	5	13	0	0.000	0
4	5	12	1	0.000	0
5	5	12	0	0.000	0
6	5	10	1	0.000	0
7	5	11	1	0.000	0
8	5	12	1	0.000	0
9	5	12	1	0.000	0
10	5	11	1	0.000	0
11	5	10	0	0.000	0
12	5	14	0	0.000	0
13	5	10	1	0.000	0
14	5	11	1	0.000	0
15	5	13	0	0.000	0
16	5	9	1	0.000	0
17	5	11	1	0.000	0
18	5	12	1	0.000	0
19	5	12	1	0.000	0
20	5	11	1	0.000	0
21	5	11	1	0.000	0
22	5	10	1	0.000	0
23	5	11	1	0.000	0
24	5	11	1	0.000	0

自主規制値
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
	430	250	約2700		50
1	5	10	1	0.000	0
2	5	12	1	0.000	0
3	5	11	1	0.000	0
4	5	14	1	0.000	0
5	5	11	1	0.000	0
6	5	12	1	0.000	0
7	5	10	1	0.000	0
8	5	10	1	0.000	0
9	5	11	1	0.000	0
10	5	11	1	0.000	0
11	5	13	1	0.000	0
12	5	6	0	0.000	0
13	5	10	1	0.000	0
14	5	13	0	0.000	0
15	5	7	1	0.000	0
16	5	10	1	0.000	0
17	5	11	1	0.000	0
18	5	10	1	0.000	0
19	5	11	1	0.000	0
20	5	11	1	0.000	0
21	5	11	1	0.000	0
22	5	11	0	0.000	0
23	5	11	1	0.000	0
24	5	12	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2025年11月19日 (水)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
	430	250	約2700		50
1	5	13	0	0.000	0
2	5	14	0	0.000	0
3	5	11	1	0.000	0
4	5	11	1	0.000	0
5	5	13	1	0.000	0
6	5	13	1	0.000	0
7	5	11	1	0.000	0
8	5	11	1	0.000	0
9	5	13	1	0.000	0
10	5	12	0	0.000	0
11	5	12	0	0.000	0
12	5	11	0	0.000	0
13	5	13	0	0.000	0
14	5	12	0	0.000	0
15	5	12	0	0.000	0
16	5	12	1	0.000	0
17	5	11	1	0.000	0
18	5	12	0	0.000	0
19	5	11	1	0.000	0
20	5	11	1	0.000	0
21	5	13	1	0.000	0
22	5	9	1	0.000	0
23	5	13	0	0.000	0
24	5	12	0	0.000	0

自主規制値
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
	430	250	約2700		50
1	5	12	1	0.000	0
2	5	12	1	0.000	0
3	5	11	1	0.000	0
4	5	12	0	0.000	0
5	5	12	1	0.000	0
6	5	12	1	0.000	0
7	5	12	1	0.000	0
8	5	13	1	0.000	0
9	5	11	1	0.000	0
10	5	10	1	0.000	0
11	5	11	0	0.000	0
12	5	11	0	0.000	0
13	5	10	0	0.000	0
14	5	11	0	0.000	0
15	5	10	0	0.000	0
16	5	11	0	0.000	0
17	5	10	1	0.000	0
18	5	11	0	0.000	0
19	5	14	0	0.000	0
20	5	8	0	0.000	0
21	5	11	1	0.000	0
22	5	12	0	0.000	0
23	5	11	0	0.000	0
24	5	12	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2025年11月20日 (木)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
	430	250	約2700		50
1	5	14	0	0.000	0
2	5	10	0	0.000	0
3	5	11	0	0.000	0
4	5	11	0	0.000	0
5	5	11	0	0.000	0
6	5	13	0	0.000	0
7	5	10	1	0.000	0
8	5	11	1	0.000	0
9	5	11	0	0.000	0
10	5	12	0	0.000	0
11	5	13	1	0.000	0
12	5	12	1	0.000	0
13	5	10	1	0.000	0
14	5	13	1	0.000	0
15	5	13	1	0.000	0
16	5	11	0	0.000	0
17	5	11	1	0.000	0
18	5	13	1	0.000	0
19	5	13	1	0.000	0
20	5	13	1	0.000	0
21	5	11	1	0.000	0
22	5	12	1	0.000	0
23	5	12	1	0.000	0
24	5	11	1	0.000	0

自主規制値
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
	430	250	約2700		50
1	5	11	1	0.000	0
2	5	13	1	0.000	0
3	5	11	1	0.000	0
4	5	10	1	0.000	0
5	5	11	1	0.000	0
6	5	10	1	0.000	0
7	5	12	1	0.000	0
8	5	10	1	0.000	0
9	5	11	1	0.000	0
10	5	14	1	0.000	0
11	5	12	1	0.000	0
12	5	11	1	0.000	0
13	5	11	1	0.000	0
14	5	10	1	0.000	0
15	5	11	1	0.000	0
16	5	9	1	0.000	0
17	5	12	1	0.000	0
18	5	12	0	0.000	0
19	5	12	0	0.000	0
20	5	12	0	0.000	0
21	5	9	1	0.000	0
22	5	11	1	0.000	0
23	5	11	1	0.000	0
24	5	12	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2025年11月21日 (金)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
	430	250	約2700		50
1	5	12	1	0.000	0
2	5	11	1	0.000	0
3	5	11	1	0.000	0
4	5	13	1	0.000	0
5	5	11	1	0.000	0
6	5	13	1	0.000	0
7	5	11	1	0.000	0
8	5	13	1	0.000	0
9	5	13	0	0.000	0
10	5	12	1	0.000	0
11	5	11	1	0.000	0
12	5	13	1	0.000	0
13	5	12	1	0.000	0
14	5	11	1	0.000	0
15	5	12	1	0.000	0
16	5	12	0	0.000	0
17	5	11	1	0.000	0
18	5	12	0	0.000	0
19	5	14	0	0.000	0
20	5	11	0	0.000	0
21	5	11	0	0.000	0
22	5	11	1	0.000	0
23	5	12	0	0.000	0
24	5	14	1	0.000	0

自主規制値
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
	430	250	約2700		50
1	5	12	1	0.000	0
2	5	12	1	0.000	0
3	5	11	1	0.000	0
4	5	12	1	0.000	0
5	5	13	1	0.000	0
6	5	10	1	0.000	0
7	5	12	1	0.000	0
8	5	11	1	0.000	0
9	5	11	1	0.000	0
10	5	12	1	0.000	0
11	5	11	1	0.000	0
12	5	11	1	0.000	0
13	5	10	1	0.000	0
14	5	11	1	0.000	0
15	5	11	1	0.000	0
16	5	11	1	0.000	0
17	5	10	1	0.000	0
18	5	10	1	0.000	0
19	5	11	1	0.000	0
20	5	12	0	0.000	0
21	5	12	1	0.000	0
22	5	12	1	0.000	0
23	5	11	1	0.000	0
24	5	11	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2025年11月22日 (土)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
	430	250	約2700		50
1	5	11	0	0.000	0
2	5	12	1	0.000	0
3	5	13	1	0.000	0
4	5	11	1	0.000	0
5	5	14	1	0.000	0
6	5	12	0	0.000	0
7	5	11	1	0.000	0
8	5	10	1	0.000	0
9	5	11	0	0.000	0
10	5	13	0	0.000	0
11	5	11	1	0.000	0
12	5	11	1	0.000	0
13	5	12	0	0.000	0
14	5	13	0	0.000	0
15	5	11	0	0.000	0
16	5	14	1	0.000	0
17	5	10	0	0.000	0
18	5	13	0	0.000	0
19	5	12	0	0.000	0
20	5	11	0	0.000	0
21	5	12	1	0.000	0
22	5	11	0	0.000	0
23	5	11	1	0.000	0
24	5	10	0	0.000	0

自主規制値
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
	430	250	約2700		50
1	5	10	1	0.000	0
2	5	11	1	0.000	0
3	5	12	1	0.000	0
4	5	11	1	0.000	0
5	5	12	1	0.000	0
6	5	12	1	0.000	0
7	5	11	1	0.000	0
8	5	11	1	0.000	0
9	5	13	1	0.000	0
10	5	12	1	0.000	0
11	5	11	1	0.000	0
12	5	10	1	0.000	0
13	5	12	1	0.000	0
14	5	13	1	0.000	0
15	5	11	1	0.000	0
16	5	13	1	0.000	0
17	5	12	1	0.000	0
18	5	12	1	0.000	0
19	5	11	0	0.000	0
20	5	10	0	0.000	0
21	5	12	0	0.000	0
22	5	11	0	0.000	0
23	5	13	1	0.000	0
24	5	12	0	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2025年11月23日 (日)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
	430	250	約2700		50
1	5	11	0	0.000	0
2	5	13	0	0.000	0
3	5	10	1	0.000	0
4	5	11	1	0.000	0
5	5	11	1	0.000	0
6	5	11	0	0.000	0
7	5	12	1	0.000	0
8	5	12	1	0.000	0
9	5	10	1	0.000	0
10	5	13	0	0.000	0
11	5	10	1	0.000	0
12	5	12	0	0.000	0
13	5	11	0	0.000	0
14	5	12	0	0.000	0
15	5	12	1	0.000	0
16	5	12	1	0.000	0
17	5	11	1	0.000	0
18	5	10	0	0.000	0
19	5	12	0	0.000	0
20	5	11	1	0.000	0
21	5	13	0	0.000	0
22	5	9	1	0.000	0
23	5	12	0	0.000	0
24	5	8	0	0.000	0

自主規制値
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
	430	250	約2700		50
1	5	10	0	0.000	0
2	5	11	0	0.000	0
3	5	13	1	0.000	0
4	5	11	1	0.000	0
5	5	13	0	0.000	0
6	5	13	1	0.000	0
7	5	11	1	0.000	0
8	5	12	1	0.000	0
9	5	12	1	0.000	0
10	5	11	1	0.000	0
11	5	11	1	0.000	0
12	5	11	0	0.000	0
13	5	9	1	0.000	0
14	5	11	1	0.000	0
15	5	11	1	0.000	0
16	5	11	1	0.000	0
17	5	12	1	0.000	0
18	5	12	0	0.000	0
19	5	10	1	0.000	0
20	5	12	1	0.000	0
21	5	10	1	0.000	0
22	5	10	1	0.000	0
23	5	11	1	0.000	0
24	5	10	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2025年11月24日 (月)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
	430	250	約2700		0.040
1	5	12	0	0.000	0
2	5	12	0	0.000	0
3	5	12	0	0.000	0
4	5	12	1	0.000	0
5	5	12	0	0.000	0
6	5	13	0	0.000	0
7	5	8	0	0.000	0
8	5	13	1	0.000	0
9	5	13	0	0.000	0
10	5	13	1	0.000	0
11	5	11	1	0.000	0
12	5	12	1	0.000	0
13	5	12	0	0.000	0
14	5	14	0	0.000	0
15	5	11	1	0.000	0
16	5	12	0	0.000	0
17	5	11	1	0.000	0
18	5	12	0	0.000	0
19	5	11	0	0.000	0
20	5	12	1	0.000	0
21	5	10	0	0.000	0
22	5	12	0	0.000	0
23	5	12	0	0.000	0
24	5	11	1	0.000	0

自主規制値
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
	430	250	約2700		0.040
1	5	11	1	0.000	0
2	5	12	1	0.000	0
3	5	11	1	0.000	0
4	5	11	1	0.000	0
5	5	11	1	0.000	0
6	5	12	1	0.000	0
7	5	12	1	0.000	0
8	5	11	1	0.000	0
9	5	13	1	0.000	0
10	5	11	1	0.000	0
11	5	13	0	0.000	0
12	5	9	1	0.000	0
13	5	12	0	0.000	0
14	5	12	1	0.000	0
15	5	11	1	0.000	0
16	5	11	1	0.000	0
17	5	13	1	0.000	0
18	5	9	1	0.000	0
19	5	11	1	0.000	0
20	5	11	1	0.000	0
21	5	11	1	0.000	0
22	5	11	1	0.000	0
23	5	10	1	0.000	0
24	5	10	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2025年11月25日 (火)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
	430	250	約2700		50
1	5	12	1	0.000	0
2	5	11	1	0.000	0
3	5	11	1	0.000	0
4	5	14	1	0.000	0
5	5	15	0	0.000	0
6	5	12	1	0.000	0
7	5	12	1	0.000	0
8	5	12	0	0.000	0
9	5	10	1	0.000	0
10	5	13	0	0.000	0
11	5	13	1	0.000	0
12	5	13	1	0.000	0
13	5	13	0	0.000	0
14	5	12	0	0.000	0
15	5	12	0	0.000	0
16	5	12	0	0.000	0
17	5	12	0	0.000	0
18	5	11	0	0.000	0
19	5	13	0	0.000	0
20	5	11	0	0.000	0
21	5	12	0	0.000	0
22	5	11	0	0.000	0
23	5	10	0	0.000	0
24	5	12	0	0.000	0

自主規制値
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
	430	250	約2700		50
1	5	11	1	0.000	0
2	5	11	1	0.000	0
3	5	11	1	0.000	0
4	5	10	1	0.000	0
5	5	11	1	0.000	0
6	5	12	1	0.000	0
7	5	12	1	0.000	0
8	5	10	1	0.000	0
9	5	11	1	0.000	0
10	5	11	1	0.000	0
11	5	13	1	0.000	0
12	5	14	1	0.000	0
13	5	11	1	0.000	0
14	5	11	1	0.000	0
15	5	11	0	0.000	0
16	5	12	0	0.000	0
17	5	12	0	0.000	0
18	5	10	0	0.000	0
19	5	11	0	0.000	0
20	5	12	0	0.000	0
21	5	11	0	0.000	0
22	5	10	0	0.000	0
23	5	11	0	0.000	0
24	5	11	0	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2025年11月26日 (水)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	12	0	0.000	0
2	5	11	0	0.000	0
3	5	10	0	0.000	0
4	5	11	0	0.000	0
5	5	10	0	0.000	0
6	5	10	0	0.000	0
7	5	13	0	0.000	0
8	5	12	1	0.000	0
9	5	11	0	0.000	0
10	5	11	1	0.000	0
11	5	10	1	0.000	0
12	5	10	1	0.000	0
13	5	9	0	0.000	0
14	5	11	0	0.000	0
15	5	11	0	0.000	0
16	5	12	0	0.000	0
17	5	11	0	0.000	0
18	5	12	0	0.000	0
19	5	11	0	0.000	0
20	5	12	0	0.000	0
21	5	11	1	0.000	0
22	5	12	0	0.000	0
23	5	11	0	0.000	0
24	5	12	0	0.000	0

自主規制値
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	11	1	0.000	0
2	5	10	0	0.000	0
3	5	11	1	0.000	0
4	5	11	0	0.000	0
5	5	11	0	0.000	0
6	5	10	0	0.000	0
7	5	11	1	0.000	0
8	5	12	1	0.000	0
9	5	12	1	0.000	0
10	5	11	0	0.000	0
11	5	12	0	0.000	0
12	5	11	0	0.000	0
13	5	10	1	0.000	0
14	5	11	1	0.000	0
15	5	13	1	0.000	0
16	5	10	1	0.000	0
17	5	12	0	0.000	0
18	5	11	1	0.000	0
19	5	12	1	0.000	0
20	5	11	1	0.000	0
21	5	12	1	0.000	0
22	5	10	1	0.000	0
23	5	11	1	0.000	0
24	5	13	0	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2025年11月27日 (木)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	µg/m³N
	10	20	10	0.005	50
	430	250	約2700		50
1	5	11	1	0.000	0
2	5	11	1	0.000	0
3	5	12	0	0.000	0
4	5	10	1	0.000	0
5	5	10	0	0.000	0
6	5	11	1	0.000	0
7	5	12	1	0.000	0
8	5	11	0	0.000	0
9	5	14	0	0.000	0
10	5	10	1	0.000	0
11	5	11	0	0.000	0
12	5	13	1	0.000	0
13	5	12	1	0.000	0
14	5	13	0	0.000	0
15	5	11	1	0.000	0
16	5	14	0	0.000	0
17	5	11	1	0.000	0
18	5	12	1	0.000	0
19	5	12	1	0.000	0
20	5	11	1	0.000	0
21	5	11	1	0.000	0
22	5	12	1	0.000	0
23	5	10	1	0.000	0
24	5	11	1	0.000	0

自主規制値
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	µg/m³N
	10	20	10	0.005	50
	430	250	約2700		50
1	5	12	0	0.000	0
2	5	13	1	0.000	0
3	5	10	1	0.000	0
4	5	12	0	0.000	0
5	5	11	0	0.000	0
6	5	11	1	0.000	0
7	5	11	1	0.000	0
8	3	11	0	0.000	0
9	----	----	----	----	----
10	----	----	----	----	----
11	----	----	----	----	----
12	----	----	----	----	----
13	----	----	----	----	----
14	----	----	----	----	----
15	----	----	----	----	----
16	----	----	----	----	----
17	----	----	----	----	----
18	----	----	----	----	----
19	----	----	----	----	----
20	----	----	----	----	----
21	----	----	----	----	----
22	----	----	----	----	----
23	----	----	----	----	----
24	----	----	----	----	----

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2025年11月28日 (金)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	µg/m³N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	11	1	0.000	0
2	5	12	1	0.000	0
3	5	11	1	0.000	0
4	5	12	1	0.000	0
5	5	11	1	0.000	0
6	5	12	1	0.000	0
7	5	12	1	0.000	0
8	5	13	1	0.000	0
9	5	13	1	0.000	0
10	5	12	1	0.000	0
11	5	13	1	0.000	0
12	5	13	1	0.000	0
13	5	13	1	0.000	0
14	5	14	1	0.000	0
15	5	13	1	0.000	0
16	5	13	1	0.000	0
17	5	12	1	0.000	0
18	5	13	1	0.000	0
19	5	12	1	0.000	0
20	5	13	1	0.000	0
21	5	13	1	0.000	0
22	5	12	1	0.000	0
23	5	15	1	0.000	0
24	5	11	1	0.000	0

自主規制値
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	µg/m³N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	----	----	----	----	----
2	----	----	----	----	----
3	----	----	----	----	----
4	----	----	----	----	----
5	----	----	----	----	----
6	----	----	----	----	----
7	----	----	----	----	----
8	----	----	----	----	----
9	----	----	----	----	----
10	----	----	----	----	----
11	----	----	----	----	----
12	----	----	----	----	----
13	----	----	----	----	----
14	----	----	----	----	----
15	----	----	----	----	----
16	----	----	----	----	----
17	----	----	----	----	----
18	----	----	----	----	----
19	----	----	----	----	----
20	----	----	----	----	----
21	----	----	----	----	----
22	----	----	----	----	----
23	----	----	----	----	----
24	----	----	----	----	----

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2025年11月29日 (土)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	10	1	0.000	0
2	5	13	1	0.000	0
3	5	11	1	0.000	0
4	5	11	1	0.000	0
5	5	14	1	0.000	0
6	5	13	1	0.000	0
7	5	11	1	0.000	0
8	5	12	1	0.000	0
9	5	13	1	0.000	0
10	5	9	1	0.000	0
11	5	13	0	0.000	0
12	5	10	1	0.000	0
13	5	11	1	0.000	0
14	5	12	1	0.000	0
15	5	12	1	0.000	0
16	5	11	1	0.000	0
17	5	11	1	0.000	0
18	5	13	1	0.000	0
19	5	12	1	0.000	0
20	5	13	1	0.000	0
21	5	14	1	0.000	0
22	5	11	1	0.000	0
23	5	14	1	0.000	0
24	5	12	1	0.000	0

自主規制値
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	μg/m³N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	----	----	----	----	----
2	----	----	----	----	----
3	----	----	----	----	----
4	----	----	----	----	----
5	----	----	----	----	----
6	----	----	----	----	----
7	----	----	----	----	----
8	----	----	----	----	----
9	----	----	----	----	----
10	----	----	----	----	----
11	----	----	----	----	----
12	----	----	----	----	----
13	----	----	----	----	----
14	----	----	----	----	----
15	----	----	----	----	----
16	----	----	----	----	----
17	----	----	----	----	----
18	----	----	----	----	----
19	----	----	----	----	----
20	----	----	----	----	----
21	----	----	----	----	----
22	----	----	----	----	----
23	----	----	----	----	----
24	----	----	----	----	----

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2025年11月30日 (日)

項目 時 刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	µg/m³N
	10	20	10	0.005	50
	430	250	約2700		50
1	5	13	1	0.000	0
2	5	13	1	0.000	0
3	5	9	1	0.000	0
4	5	8	1	0.000	0
5	5	11	1	0.000	0
6	5	11	1	0.000	0
7	5	11	1	0.000	0
8	5	13	1	0.000	0
9	5	12	1	0.000	0
10	5	14	1	0.000	0
11	5	11	1	0.000	0
12	5	12	1	0.000	0
13	5	13	1	0.000	0
14	5	11	1	0.000	0
15	5	12	0	0.000	0
16	5	11	1	0.000	0
17	5	13	1	0.000	0
18	5	14	0	0.000	0
19	5	12	0	0.000	0
20	5	12	0	0.000	0
21	5	12	1	0.000	0
22	5	13	1	0.000	0
23	5	14	1	0.000	0
24	5	12	1	0.000	0

自主規制値
法規制値

項目 時 刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m³N	µg/m³N
	10	20	10	0.005	50
	430	250	約2700		50
1	---	---	---	---	---
2	---	---	---	---	---
3	---	---	---	---	---
4	---	---	---	---	---
5	---	---	---	---	---
6	---	---	---	---	---
7	---	---	---	---	---
8	---	---	---	---	---
9	---	---	---	---	---
10	---	---	---	---	---
11	---	---	---	---	---
12	---	---	---	---	---
13	---	---	---	---	---
14	---	---	---	---	---
15	---	---	---	---	---
16	---	---	---	---	---
17	---	---	---	---	---
18	---	---	---	---	---
19	---	---	---	---	---
20	---	---	---	---	---
21	---	---	---	---	---
22	---	---	---	---	---
23	---	---	---	---	---
24	---	---	---	---	---