

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2026年3月1日 (日)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	12	0	0.000	0
2	5	14	1	0.000	0
3	5	13	0	0.000	0
4	5	14	1	0.000	0
5	5	13	1	0.000	0
6	5	13	1	0.000	0
7	5	14	1	0.000	0
8	5	14	1	0.000	0
9	5	13	1	0.000	0
10	5	12	1	0.000	0
11	5	13	1	0.000	0
12	5	13	1	0.000	0
13	5	12	1	0.000	0
14	5	13	1	0.000	0
15	5	14	1	0.000	0
16	5	13	1	0.000	0
17	5	12	1	0.000	0
18	5	14	0	0.000	0
19	5	14	0	0.000	0
20	5	12	0	0.000	0
21	5	13	0	0.000	0
22	5	11	0	0.000	0
23	5	14	0	0.000	0
24	5	10	1	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	12	0	0.000	0
2	5	12	1	0.000	0
3	5	12	1	0.000	0
4	5	12	1	0.000	0
5	5	11	1	0.000	0
6	5	12	1	0.000	0
7	5	13	1	0.000	0
8	5	11	1	0.000	0
9	5	11	1	0.000	0
10	5	12	1	0.000	0
11	5	13	1	0.000	0
12	5	13	1	0.000	0
13	5	12	1	0.000	0
14	5	12	1	0.000	0
15	5	13	1	0.000	0
16	5	11	1	0.000	0
17	5	13	1	0.000	0
18	5	11	1	0.000	0
19	5	14	1	0.000	0
20	5	12	1	0.000	0
21	5	12	1	0.000	0
22	5	14	2	0.000	0
23	5	13	1	0.000	0
24	5	12	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2026年3月2日 (月)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	12	0	0.000	0
2	5	12	0	0.000	0
3	5	11	1	0.000	0
4	5	12	1	0.000	0
5	5	13	1	0.000	0
6	5	11	1	0.000	0
7	5	14	1	0.000	0
8	5	12	1	0.000	0
9	5	9	1	0.000	0
10	5	14	0	0.000	0
11	5	14	0	0.000	0
12	5	5	0	0.000	0
13	5	15	1	0.000	0
14	5	10	1	0.000	0
15	5	13	0	0.000	0
16	5	10	0	0.000	0
17	5	12	0	0.000	0
18	5	14	0	0.000	0
19	5	12	0	0.000	0
20	5	11	0	0.000	0
21	5	13	0	0.000	0
22	5	12	0	0.000	0
23	5	11	0	0.000	0
24	5	12	0	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	14	1	0.000	0
2	5	12	1	0.000	0
3	5	13	1	0.000	0
4	5	14	1	0.000	0
5	5	12	1	0.000	0
6	5	13	1	0.000	0
7	5	14	1	0.000	0
8	5	12	1	0.000	0
9	5	10	1	0.000	0
10	5	13	1	0.000	0
11	5	14	1	0.000	0
12	5	11	1	0.000	0
13	5	11	0	0.000	0
14	5	12	2	0.000	0
15	5	9	2	0.000	0
16	5	10	1	0.000	0
17	5	14	1	0.000	0
18	5	11	1	0.000	0
19	5	10	1	0.000	0
20	5	13	1	0.000	0
21	5	13	1	0.000	0
22	5	12	1	0.000	0
23	5	13	1	0.000	0
24	5	13	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2026年3月3日 (火)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	12	0	0.000	0
2	5	13	0	0.000	0
3	5	12	0	0.000	0
4	5	10	0	0.000	0
5	5	13	0	0.000	0
6	5	11	1	0.000	0
7	5	11	1	0.000	0
8	5	10	1	0.000	0
9	5	12	1	0.000	0
10	5	12	1	0.000	0
11	5	12	0	0.000	0
12	5	12	0	0.000	0
13	5	13	0	0.000	0
14	5	10	1	0.000	0
15	5	10	1	0.000	0
16	5	11	1	0.000	0
17	5	12	1	0.000	0
18	5	11	0	0.000	0
19	5	11	0	0.000	0
20	5	12	0	0.000	0
21	5	11	0	0.000	0
22	5	12	0	0.000	0
23	5	11	0	0.000	0
24	5	13	0	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	12	2	0.000	0
2	5	14	1	0.000	0
3	5	13	1	0.000	0
4	5	13	2	0.000	0
5	5	13	1	0.000	0
6	5	14	1	0.000	0
7	5	13	1	0.000	0
8	5	12	1	0.000	0
9	5	13	1	0.000	0
10	5	13	1	0.000	0
11	5	14	1	0.000	0
12	5	14	1	0.000	0
13	5	12	2	0.000	0
14	5	13	1	0.000	0
15	5	11	1	0.000	0
16	5	13	1	0.000	0
17	5	12	1	0.000	0
18	5	13	1	0.000	0
19	5	10	1	0.000	0
20	5	12	1	0.000	0
21	5	14	1	0.000	0
22	5	11	1	0.000	0
23	5	13	1	0.000	0
24	5	13	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2026年3月4日 (水)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	12	0	0.000	0
2	5	12	0	0.000	0
3	5	11	0	0.000	0
4	5	12	0	0.000	0
5	5	10	0	0.000	0
6	5	11	1	0.000	0
7	5	12	0	0.000	0
8	5	11	1	0.000	0
9	5	14	0	0.000	0
10	5	12	0	0.000	0
11	5	13	0	0.000	0
12	5	10	0	0.000	0
13	5	14	0	0.000	0
14	5	11	0	0.000	0
15	5	13	0	0.000	0
16	5	12	0	0.000	0
17	5	11	0	0.000	0
18	5	11	0	0.000	0
19	5	12	0	0.000	0
20	5	11	0	0.000	0
21	5	11	0	0.000	0
22	5	12	0	0.000	0
23	5	11	0	0.000	0
24	5	12	1	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	13	1	0.000	0
2	5	12	1	0.000	0
3	5	12	1	0.000	0
4	5	12	1	0.000	0
5	5	12	1	0.000	0
6	5	12	1	0.000	0
7	5	13	1	0.000	0
8	5	12	1	0.000	0
9	5	14	1	0.000	0
10	5	13	1	0.000	0
11	5	13	1	0.000	0
12	5	13	1	0.000	0
13	5	14	1	0.000	0
14	5	14	1	0.000	0
15	5	11	1	0.000	0
16	5	15	1	0.000	0
17	5	12	1	0.000	0
18	5	14	1	0.000	0
19	5	12	1	0.000	0
20	5	13	1	0.000	0
21	5	14	1	0.000	0
22	5	13	0	0.000	0
23	5	12	1	0.000	0
24	5	14	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

**環境監視日報**

2026年3月5日 (木)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	11	1	0.000	0
2	5	12	0	0.000	0
3	5	12	0	0.000	0
4	5	10	0	0.000	0
5	5	10	1	0.000	0
6	5	13	0	0.000	0
7	5	11	0	0.000	0
8	5	12	1	0.000	0
9	5	12	1	0.000	0
10	5	11	0	0.000	0
11	5	12	0	0.000	0
12	5	12	0	0.000	0
13	5	12	0	0.000	0
14	5	11	0	0.000	0
15	5	11	0	0.000	0
16	5	10	0	0.000	0
17	5	13	0	0.000	0
18	5	13	1	0.000	0
19	5	12	0	0.000	0
20	5	13	1	0.000	0
21	5	14	1	0.000	0
22	5	9	1	0.000	0
23	5	13	0	0.000	0
24	5	13	0	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	12	1	0.000	0
2	5	13	1	0.000	0
3	5	13	1	0.000	0
4	5	14	1	0.000	0
5	5	12	1	0.000	0
6	5	14	1	0.000	0
7	5	14	1	0.000	0
8	5	13	1	0.000	0
9	5	13	1	0.000	0
10	5	13	1	0.000	0
11	5	11	1	0.000	0
12	5	14	0	0.000	0
13	5	12	1	0.000	0
14	5	12	1	0.000	0
15	5	14	1	0.000	0
16	5	14	1	0.000	0
17	5	14	1	0.000	0
18	5	13	1	0.000	0
19	5	13	1	0.000	0
20	5	13	1	0.000	0
21	5	13	1	0.000	0
22	5	13	1	0.000	0
23	5	13	1	0.000	0
24	5	13	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2026年3月6日 (金)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	12	0	0.000	0
2	5	11	0	0.000	0
3	5	12	0	0.000	0
4	5	11	1	0.000	0
5	5	13	0	0.000	0
6	5	13	0	0.000	0
7	5	13	1	0.000	0
8	5	13	1	0.000	0
9	5	12	0	0.000	0
10	5	11	0	0.000	0
11	5	12	1	0.000	0
12	5	12	0	0.000	0
13	5	10	0	0.000	0
14	5	11	0	0.000	0
15	5	12	0	0.000	0
16	5	10	0	0.000	0
17	5	12	0	0.000	0
18	5	12	0	0.000	0
19	5	12	0	0.000	0
20	5	11	0	0.000	0
21	5	11	0	0.000	0
22	5	13	0	0.000	0
23	5	11	0	0.000	0
24	5	11	0	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	14	1	0.000	0
2	5	12	1	0.000	0
3	5	13	1	0.000	0
4	5	14	1	0.000	0
5	5	13	1	0.000	0
6	5	13	1	0.000	0
7	5	12	1	0.000	0
8	5	14	1	0.000	0
9	5	10	1	0.000	0
10	5	14	1	0.000	0
11	5	12	1	0.000	0
12	5	13	1	0.000	0
13	5	12	1	0.000	0
14	5	13	1	0.000	0
15	5	13	1	0.000	0
16	5	11	1	0.000	0
17	5	13	0	0.000	0
18	5	11	1	0.000	0
19	5	13	0	0.000	0
20	5	13	1	0.000	0
21	5	14	1	0.000	0
22	5	12	1	0.000	0
23	5	13	0	0.000	0
24	5	12	0	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2026年3月7日 (土)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	12	0	0.000	0
2	5	11	0	0.000	0
3	5	10	1	0.000	0
4	5	13	0	0.000	0
5	5	12	1	0.000	0
6	5	11	1	0.000	0
7	5	12	1	0.000	0
8	5	11	1	0.000	0
9	5	12	1	0.000	0
10	5	13	0	0.000	0
11	5	12	0	0.000	0
12	5	12	0	0.000	0
13	5	12	0	0.000	0
14	5	11	0	0.000	0
15	5	13	1	0.000	0
16	5	11	0	0.000	0
17	5	12	0	0.000	0
18	5	12	0	0.000	0
19	5	13	0	0.000	0
20	5	13	0	0.000	0
21	5	13	0	0.000	0
22	5	10	0	0.000	0
23	5	12	0	0.000	0
24	5	12	0	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	14	1	0.000	0
2	5	13	1	0.000	0
3	5	13	1	0.000	0
4	5	13	1	0.000	0
5	5	13	1	0.000	0
6	5	13	1	0.000	0
7	5	12	1	0.000	0
8	5	14	1	0.000	0
9	5	13	1	0.000	0
10	5	14	1	0.000	0
11	5	11	1	0.000	0
12	5	13	1	0.000	0
13	5	12	1	0.000	0
14	5	13	1	0.000	0
15	5	14	1	0.000	0
16	5	14	1	0.000	0
17	5	12	1	0.000	0
18	5	13	1	0.000	0
19	5	13	0	0.000	0
20	5	13	1	0.000	0
21	5	13	1	0.000	0
22	5	12	1	0.000	0
23	5	13	1	0.000	0
24	5	13	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2026年3月8日 (日)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	11	0	0.000	0
2	5	14	0	0.000	0
3	5	11	1	0.000	0
4	5	11	0	0.000	0
5	5	12	0	0.000	0
6	5	13	0	0.000	0
7	5	11	0	0.000	0
8	5	11	0	0.000	0
9	5	11	0	0.000	0
10	5	11	0	0.000	0
11	5	12	0	0.000	0
12	5	11	0	0.000	0
13	5	11	0	0.000	0
14	5	12	0	0.000	0
15	5	10	0	0.000	0
16	5	11	0	0.000	0
17	5	12	0	0.000	0
18	5	12	0	0.000	0
19	5	12	0	0.000	0
20	5	11	0	0.000	0
21	5	12	1	0.000	0
22	5	13	1	0.000	0
23	5	12	0	0.000	0
24	5	11	0	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	11	1	0.000	0
2	5	13	1	0.000	0
3	5	12	1	0.000	0
4	5	11	1	0.000	0
5	5	14	1	0.000	0
6	5	13	1	0.000	0
7	5	13	1	0.000	0
8	5	13	1	0.000	0
9	5	13	1	0.000	0
10	5	14	1	0.000	0
11	5	14	1	0.000	0
12	5	11	1	0.000	0
13	5	15	1	0.000	0
14	5	14	0	0.000	0
15	5	12	0	0.000	0
16	5	15	1	0.000	0
17	5	12	1	0.000	0
18	5	14	1	0.000	0
19	5	13	1	0.000	0
20	5	13	2	0.000	0
21	5	14	1	0.000	0
22	5	13	2	0.000	0
23	5	11	1	0.000	0
24	5	9	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

**環境監視日報**

2026年3月9日 (月)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	14	0	0.000	0
2	5	13	0	0.000	0
3	5	10	1	0.000	0
4	5	11	0	0.000	0
5	5	12	0	0.000	0
6	5	12	1	0.000	0
7	5	13	1	0.000	0
8	5	13	0	0.000	0
9	5	11	1	0.000	0
10	5	13	1	0.000	0
11	5	9	1	0.000	0
12	5	13	0	0.000	0
13	5	12	0	0.000	0
14	5	12	0	0.000	0
15	5	14	0	0.000	0
16	5	12	0	0.000	0
17	5	10	1	0.000	0
18	5	11	1	0.000	0
19	5	12	1	0.000	0
20	5	12	0	0.000	0
21	5	13	0	0.000	0
22	5	13	0	0.000	0
23	5	12	0	0.000	0
24	5	12	0	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	14	1	0.000	0
2	5	14	1	0.000	0
3	5	9	1	0.000	0
4	5	14	1	0.000	0
5	5	11	1	0.000	0
6	5	12	1	0.000	0
7	5	14	1	0.000	0
8	5	13	1	0.000	0
9	5	13	1	0.000	0
10	5	12	1	0.000	0
11	5	13	1	0.000	0
12	5	12	1	0.000	0
13	5	14	1	0.000	0
14	5	12	1	0.000	0
15	5	13	1	0.000	0
16	5	12	1	0.000	0
17	5	14	1	0.000	0
18	5	11	1	0.000	0
19	5	13	1	0.000	0
20	5	14	1	0.000	0
21	5	12	1	0.000	0
22	5	14	1	0.000	0
23	5	13	1	0.000	0
24	5	13	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2026年3月10日 (火)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	13	0	0.000	0
2	5	14	0	0.000	0
3	5	11	1	0.000	0
4	5	11	1	0.000	0
5	5	13	1	0.000	0
6	5	12	0	0.000	0
7	5	11	1	0.000	0
8	5	12	1	0.000	0
9	5	13	0	0.000	0
10	5	11	0	0.000	0
11	5	15	0	0.000	0
12	4	10	0	0.000	0
13	5	13	0	0.000	0
14	5	11	0	0.000	0
15	5	14	0	0.000	0
16	5	9	0	0.000	0
17	5	12	0	0.000	0
18	5	12	0	0.000	0
19	5	11	0	0.000	0
20	5	11	1	0.000	0
21	5	14	0	0.000	0
22	5	12	0	0.000	0
23	5	10	0	0.000	0
24	5	10	0	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	14	1	0.000	0
2	5	13	1	0.000	0
3	5	12	2	0.000	0
4	5	13	1	0.000	0
5	5	12	1	0.000	0
6	5	14	1	0.000	0
7	5	12	1	0.000	0
8	5	12	1	0.000	0
9	5	14	1	0.000	0
10	5	14	1	0.000	0
11	5	12	1	0.000	0
12	5	14	1	0.000	0
13	5	13	1	0.000	0
14	5	10	1	0.000	0
15	5	14	1	0.000	0
16	5	11	0	0.000	0
17	5	14	1	0.000	0
18	5	11	0	0.000	0
19	5	12	1	0.000	0
20	5	13	1	0.000	0
21	5	13	1	0.000	0
22	5	13	0	0.000	0
23	5	12	0	0.000	0
24	5	13	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2026年3月11日 (水)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	11	0	0.000	0
2	5	10	0	0.000	0
3	5	12	1	0.000	0
4	5	13	1	0.000	0
5	5	11	0	0.000	0
6	5	13	0	0.000	0
7	5	11	1	0.000	0
8	5	11	0	0.000	0
9	5	11	1	0.000	0
10	5	13	1	0.000	0
11	5	11	1	0.000	0
12	5	13	1	0.000	0
13	5	12	1	0.000	0
14	5	10	1	0.000	0
15	5	12	1	0.000	0
16	5	12	1	0.000	0
17	5	12	0	0.000	0
18	5	12	1	0.000	0
19	5	10	1	0.000	0
20	5	11	1	0.000	0
21	5	11	1	0.000	0
22	5	11	1	0.000	0
23	5	11	1	0.000	0
24	5	12	1	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	12	0	0.000	0
2	5	13	0	0.000	0
3	5	13	0	0.000	0
4	5	13	1	0.000	0
5	5	12	1	0.000	0
6	5	12	0	0.000	0
7	5	12	0	0.000	0
8	5	13	1	0.000	0
9	5	11	1	0.000	0
10	5	12	1	0.000	0
11	5	11	1	0.000	0
12	5	13	1	0.000	0
13	5	13	1	0.000	0
14	5	13	1	0.000	0
15	5	13	1	0.000	0
16	5	12	1	0.000	0
17	5	14	1	0.000	0
18	5	12	1	0.000	0
19	5	12	1	0.000	0
20	5	11	1	0.000	0
21	5	12	1	0.000	0
22	5	14	1	0.000	0
23	5	10	1	0.000	0
24	5	12	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2026年3月12日 (木)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	13	0	0.000	0
2	5	12	0	0.000	0
3	5	11	0	0.000	0
4	5	11	0	0.000	0
5	5	12	1	0.000	0
6	5	12	1	0.000	0
7	5	13	0	0.000	0
8	5	11	1	0.000	0
9	5	13	1	0.000	0
10	5	13	1	0.000	0
11	5	13	1	0.000	0
12	5	13	1	0.000	0
13	5	10	1	0.000	0
14	5	15	1	0.000	0
15	5	8	0	0.000	0
16	5	12	0	0.000	0
17	5	12	0	0.000	0
18	5	12	0	0.000	0
19	5	13	0	0.000	0
20	5	12	0	0.000	0
21	5	11	0	0.000	0
22	5	11	0	0.000	0
23	5	12	0	0.000	0
24	5	11	1	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	12	1	0.000	0
2	5	11	1	0.000	0
3	5	11	1	0.000	0
4	5	13	1	0.000	0
5	5	11	1	0.000	0
6	5	13	1	0.000	0
7	5	13	1	0.000	0
8	5	13	1	0.000	0
9	5	13	1	0.000	0
10	5	14	1	0.000	0
11	5	12	1	0.000	0
12	5	13	1	0.000	0
13	5	14	1	0.000	0
14	5	11	1	0.000	0
15	5	12	1	0.000	0
16	5	14	0	0.000	0
17	5	12	0	0.000	0
18	5	13	0	0.000	0
19	5	13	0	0.000	0
20	5	13	0	0.000	0
21	5	12	0	0.000	0
22	5	11	1	0.000	0
23	5	13	0	0.000	0
24	5	13	0	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2026年3月13日 (金)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	12	0	0.000	0
2	5	11	0	0.000	0
3	5	12	1	0.000	0
4	5	13	1	0.000	0
5	5	11	1	0.000	0
6	5	12	1	0.000	0
7	5	12	1	0.000	0
8	5	13	0	0.000	0
9	5	12	1	0.000	0
10	5	13	1	0.000	0
11	5	12	1	0.000	0
12	5	11	1	0.000	0
13	5	13	1	0.000	0
14	5	10	1	0.000	0
15	5	11	1	0.000	0
16	5	10	1	0.000	0
17	5	12	1	0.000	0
18	5	11	0	0.000	0
19	5	12	0	0.000	0
20	5	12	1	0.000	0
21	5	13	1	0.000	0
22	5	12	1	0.000	0
23	5	11	1	0.000	0
24	5	11	1	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	11	1	0.000	0
2	5	12	1	0.000	0
3	5	13	1	0.000	0
4	5	14	1	0.000	0
5	5	11	1	0.000	0
6	5	14	1	0.000	0
7	5	11	0	0.000	0
8	5	14	1	0.000	0
9	5	13	1	0.000	0
10	5	12	1	0.000	0
11	5	12	1	0.000	0
12	5	13	1	0.000	0
13	5	12	1	0.000	0
14	5	13	0	0.000	0
15	5	12	0	0.000	0
16	5	13	0	0.000	0
17	5	14	0	0.000	0
18	5	14	0	0.000	0
19	5	12	0	0.000	0
20	5	13	0	0.000	0
21	5	13	1	0.000	0
22	5	14	1	0.000	0
23	5	14	1	0.000	0
24	5	12	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2026年3月14日 (土)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	11	1	0.000	0
2	5	12	1	0.000	0
3	5	13	1	0.000	0
4	5	12	1	0.000	0
5	5	13	1	0.000	0
6	5	12	1	0.000	0
7	5	11	1	0.000	0
8	5	13	1	0.000	0
9	5	12	0	0.000	0
10	5	11	1	0.000	0
11	5	11	1	0.000	0
12	5	11	0	0.000	0
13	5	12	1	0.000	0
14	5	12	1	0.000	0
15	5	12	1	0.000	0
16	5	11	0	0.000	0
17	5	12	0	0.000	0
18	5	13	0	0.000	0
19	5	10	0	0.000	0
20	5	10	1	0.000	0
21	5	11	0	0.000	0
22	5	12	1	0.000	0
23	5	11	0	0.000	0
24	5	11	0	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	14	1	0.000	0
2	5	13	1	0.000	0
3	5	12	1	0.000	0
4	5	14	1	0.000	0
5	5	14	1	0.000	0
6	5	13	1	0.000	0
7	5	13	1	0.000	0
8	5	14	1	0.000	0
9	5	11	1	0.000	0
10	5	12	1	0.000	0
11	5	12	1	0.000	0
12	5	13	1	0.000	0
13	5	11	1	0.000	0
14	5	13	1	0.000	0
15	5	12	1	0.000	0
16	5	13	0	0.000	0
17	5	13	1	0.000	0
18	5	11	1	0.000	0
19	5	13	1	0.000	0
20	5	13	1	0.000	0
21	5	12	1	0.000	0
22	5	13	1	0.000	0
23	5	13	1	0.000	0
24	5	12	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2026年3月15日 (日)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	11	0	0.000	0
2	5	12	1	0.000	0
3	5	11	0	0.000	0
4	5	11	0	0.000	0
5	5	11	0	0.000	0
6	5	11	0	0.000	0
7	5	11	0	0.000	0
8	5	13	1	0.000	0
9	5	10	1	0.000	0
10	5	11	1	0.000	0
11	5	12	1	0.000	0
12	5	12	1	0.000	0
13	5	12	1	0.000	0
14	5	10	1	0.000	0
15	5	13	1	0.000	0
16	5	12	1	0.000	0
17	5	10	0	0.000	0
18	5	11	0	0.000	0
19	5	11	1	0.000	0
20	5	12	0	0.000	0
21	5	11	1	0.000	0
22	5	12	1	0.000	0
23	5	12	0	0.000	0
24	5	12	1	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	12	0	0.000	0
2	5	13	0	0.000	0
3	5	13	1	0.000	0
4	5	11	1	0.000	0
5	5	13	1	0.000	0
6	5	11	1	0.000	0
7	5	14	1	0.000	0
8	5	12	1	0.000	0
9	5	14	1	0.000	0
10	5	13	1	0.000	0
11	5	14	1	0.000	0
12	5	14	1	0.000	0
13	5	11	1	0.000	0
14	5	15	1	0.000	0
15	5	13	1	0.000	0
16	5	11	1	0.000	0
17	5	13	1	0.000	0
18	5	11	1	0.000	0
19	5	14	1	0.000	0
20	5	10	1	0.000	0
21	5	12	1	0.000	0
22	5	13	1	0.000	0
23	5	13	1	0.000	0
24	5	12	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2026年3月16日 (月)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	13	1	0.000	0
2	5	11	1	0.000	0
3	5	12	1	0.000	0
4	5	12	1	0.000	0
5	5	13	1	0.000	0
6	5	12	1	0.000	0
7	5	13	1	0.000	0
8	5	11	1	0.000	0
9	5	14	1	0.000	0
10	5	12	1	0.000	0
11	5	14	1	0.000	0
12	5	11	1	0.000	0
13	5	11	1	0.000	0
14	5	14	0	0.000	0
15	5	12	0	0.000	0
16	5	15	0	0.000	0
17	5	8	1	0.000	0
18	5	12	0	0.000	0
19	5	15	0	0.000	0
20	5	9	0	0.000	0
21	5	12	0	0.000	0
22	5	9	1	0.000	0
23	5	12	1	0.000	0
24	5	11	1	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	13	1	0.000	0
2	5	13	1	0.000	0
3	5	12	1	0.000	0
4	5	13	1	0.000	0
5	5	12	1	0.000	0
6	5	12	1	0.000	0
7	5	12	1	0.000	0
8	5	13	1	0.000	0
9	5	13	1	0.000	0
10	5	12	0	0.000	0
11	5	14	1	0.000	0
12	5	13	1	0.000	0
13	5	13	1	0.000	0
14	5	13	1	0.000	0
15	5	13	1	0.000	0
16	5	12	1	0.000	0
17	5	14	0	0.000	0
18	5	12	0	0.000	0
19	5	14	1	0.000	0
20	5	6	0	0.000	0
21	5	6	1	0.000	0
22	5	14	1	0.000	0
23	5	13	1	0.000	0
24	5	11	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2026年3月17日 (火)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	11	1	0.000	0
2	5	11	1	0.000	0
3	5	10	0	0.000	0
4	5	10	1	0.000	0
5	5	15	0	0.000	0
6	5	10	1	0.000	0
7	5	11	1	0.000	0
8	5	11	1	0.000	0
9	5	11	1	0.000	0
10	5	11	1	0.000	0
11	5	12	1	0.000	0
12	5	13	0	0.000	0
13	5	12	1	0.000	0
14	5	14	1	0.000	0
15	5	10	1	0.000	0
16	5	12	0	0.000	0
17	5	11	0	0.000	0
18	5	11	0	0.000	0
19	5	11	0	0.000	0
20	5	11	0	0.000	0
21	5	11	0	0.000	0
22	5	11	0	0.000	0
23	5	12	1	0.000	0
24	5	12	1	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	14	0	0.000	0
2	5	11	0	0.000	0
3	5	13	1	0.000	0
4	5	13	1	0.000	0
5	5	13	1	0.000	0
6	5	13	1	0.000	0
7	5	13	1	0.000	0
8	5	14	1	0.000	0
9	5	13	1	0.000	0
10	5	12	1	0.000	0
11	5	13	1	0.000	0
12	5	13	1	0.000	0
13	5	11	1	0.000	0
14	5	14	1	0.000	0
15	5	11	1	0.000	0
16	5	13	1	0.000	0
17	5	12	1	0.000	0
18	5	13	1	0.000	0
19	5	12	1	0.000	0
20	5	13	1	0.000	0
21	5	14	0	0.000	0
22	5	12	0	0.000	0
23	5	13	0	0.000	0
24	5	13	0	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2026年3月18日 (水)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	11	0	0.000	0
2	5	11	0	0.000	0
3	5	11	0	0.000	0
4	5	12	0	0.000	0
5	5	11	0	0.000	0
6	5	12	1	0.000	0
7	5	13	0	0.000	0
8	5	11	0	0.000	0
9	5	11	0	0.000	0
10	5	11	0	0.000	0
11	5	12	0	0.000	0
12	5	11	0	0.000	0
13	5	13	0	0.000	0
14	5	12	0	0.000	0
15	5	11	0	0.000	0
16	5	11	0	0.000	0
17	5	11	0	0.000	0
18	5	12	0	0.000	0
19	5	10	0	0.000	0
20	5	11	0	0.000	0
21	5	11	0	0.000	0
22	5	11	0	0.000	0
23	5	12	0	0.000	0
24	5	11	0	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	13	1	0.000	0
2	5	13	1	0.000	0
3	5	12	0	0.000	0
4	5	14	1	0.000	0
5	5	13	1	0.000	0
6	5	13	1	0.000	0
7	5	13	1	0.000	0
8	5	14	0	0.000	0
9	5	7	1	0.000	0
10	5	13	0	0.000	0
11	5	11	0	0.000	0
12	5	11	1	0.000	0
13	5	13	0	0.000	0
14	5	10	1	0.000	0
15	5	13	1	0.000	0
16	5	12	1	0.000	0
17	5	12	1	0.000	0
18	5	12	1	0.000	0
19	5	13	1	0.000	0
20	5	12	1	0.000	0
21	5	14	1	0.000	0
22	5	12	1	0.000	0
23	5	13	1	0.000	0
24	5	12	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2026年3月19日 (木)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	13	0	0.000	0
2	5	10	0	0.000	0
3	5	11	1	0.000	0
4	5	11	1	0.000	0
5	5	13	0	0.000	0
6	5	11	1	0.000	0
7	5	12	1	0.000	0
8	5	12	1	0.000	0
9	5	12	1	0.000	0
10	5	12	0	0.000	0
11	5	12	0	0.000	0
12	5	13	1	0.000	0
13	5	11	0	0.000	0
14	5	12	1	0.000	0
15	5	10	1	0.000	0
16	5	11	1	0.000	0
17	5	11	1	0.000	0
18	5	11	1	0.000	0
19	5	11	0	0.000	0
20	5	10	0	0.000	0
21	5	11	0	0.000	0
22	5	12	1	0.000	0
23	5	12	0	0.000	0
24	5	12	0	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	14	1	0.000	0
2	5	11	1	0.000	0
3	5	12	1	0.000	0
4	5	13	1	0.000	0
5	5	12	1	0.000	0
6	5	11	1	0.000	0
7	5	14	1	0.000	0
8	5	13	1	0.000	0
9	5	12	1	0.000	0
10	5	15	1	0.000	0
11	5	12	1	0.000	0
12	5	14	1	0.000	0
13	5	12	1	0.000	0
14	5	13	1	0.000	0
15	5	12	1	0.000	0
16	5	13	2	0.000	0
17	5	13	1	0.000	0
18	5	10	2	0.000	0
19	5	12	1	0.000	0
20	5	11	1	0.000	0
21	5	13	1	0.000	0
22	5	11	1	0.000	0
23	5	12	1	0.000	0
24	5	12	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2026年3月20日 (金)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	9	0	0.000	0
2	5	13	1	0.000	0
3	5	12	0	0.000	0
4	5	10	1	0.000	0
5	5	12	1	0.000	0
6	5	12	0	0.000	0
7	5	12	0	0.000	0
8	5	11	0	0.000	0
9	5	12	0	0.000	0
10	5	11	0	0.000	0
11	5	12	0	0.000	0
12	5	13	1	0.000	0
13	5	12	1	0.000	0
14	5	11	1	0.000	0
15	5	14	0	0.000	0
16	5	10	1	0.000	0
17	5	11	1	0.000	0
18	5	10	1	0.000	0
19	5	13	1	0.000	0
20	5	10	1	0.000	0
21	5	10	1	0.000	0
22	5	12	1	0.000	0
23	5	10	1	0.000	0
24	5	13	1	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	13	1	0.000	0
2	5	12	1	0.000	0
3	5	14	1	0.000	0
4	5	9	1	0.000	0
5	5	12	1	0.000	0
6	5	13	1	0.000	0
7	5	12	1	0.000	0
8	5	13	1	0.000	0
9	5	13	1	0.000	0
10	5	12	1	0.000	0
11	5	13	1	0.000	0
12	5	14	1	0.000	0
13	5	13	1	0.000	0
14	5	14	1	0.000	0
15	5	13	1	0.000	0
16	5	13	1	0.000	0
17	5	13	1	0.000	0
18	5	11	1	0.000	0
19	5	13	1	0.000	0
20	5	13	1	0.000	0
21	5	13	1	0.000	0
22	5	12	1	0.000	0
23	5	13	1	0.000	0
24	5	12	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2026年3月21日 (土)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	11	1	0.000	0
2	5	12	1	0.000	0
3	5	11	1	0.000	0
4	5	11	1	0.000	0
5	5	12	1	0.000	0
6	5	13	1	0.000	0
7	5	11	1	0.000	0
8	5	13	1	0.000	0
9	5	11	1	0.000	0
10	5	12	1	0.000	0
11	5	12	1	0.000	0
12	5	11	1	0.000	0
13	5	12	1	0.000	0
14	5	13	1	0.000	0
15	5	11	1	0.000	0
16	5	12	1	0.000	0
17	5	13	1	0.000	0
18	5	13	1	0.000	0
19	5	12	1	0.000	0
20	5	13	1	0.000	0
21	5	13	1	0.000	0
22	5	12	0	0.000	0
23	5	13	1	0.000	0
24	5	12	1	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	13	2	0.000	0
2	5	14	1	0.000	0
3	5	12	1	0.000	0
4	5	13	1	0.000	0
5	5	13	1	0.000	0
6	5	11	1	0.000	0
7	5	14	1	0.000	0
8	5	13	1	0.000	0
9	5	13	1	0.000	0
10	5	13	1	0.000	0
11	5	13	1	0.000	0
12	5	12	1	0.000	0
13	5	13	1	0.000	0
14	5	12	1	0.000	0
15	5	13	1	0.000	0
16	5	13	1	0.000	0
17	5	13	1	0.000	0
18	5	11	1	0.000	0
19	5	13	1	0.000	0
20	5	12	1	0.000	0
21	5	14	1	0.000	0
22	5	12	1	0.000	0
23	5	13	1	0.000	0
24	5	15	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2026年3月22日 (日)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	13	1	0.000	0
2	5	14	0	0.000	0
3	5	11	1	0.000	0
4	5	11	1	0.000	0
5	5	13	1	0.000	0
6	5	11	1	0.000	0
7	5	12	0	0.000	0
8	5	11	1	0.000	0
9	5	12	1	0.000	0
10	5	11	1	0.000	0
11	5	13	1	0.000	0
12	5	12	1	0.000	0
13	5	12	0	0.000	0
14	5	12	1	0.000	0
15	5	12	0	0.000	0
16	5	5	0	0.000	0
17	5	8	0	0.000	0
18	5	12	0	0.000	0
19	5	13	0	0.000	0
20	5	11	1	0.000	0
21	5	13	1	0.000	0
22	5	12	1	0.000	0
23	5	13	1	0.000	0
24	5	11	1	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	10	1	0.000	0
2	5	15	1	0.000	0
3	5	11	1	0.000	0
4	5	13	1	0.000	0
5	5	13	1	0.000	0
6	5	13	1	0.000	0
7	5	12	1	0.000	0
8	5	13	1	0.000	0
9	5	10	1	0.000	0
10	5	12	1	0.000	0
11	5	12	1	0.000	0
12	5	12	1	0.000	0
13	5	12	1	0.000	0
14	5	12	1	0.000	0
15	5	11	1	0.000	0
16	5	12	1	0.000	0
17	5	13	1	0.000	0
18	5	10	1	0.000	0
19	5	12	1	0.000	0
20	5	12	1	0.000	0
21	5	13	1	0.000	0
22	5	12	1	0.000	0
23	5	12	1	0.000	0
24	5	12	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2026年3月23日 (月)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	12	1	0.000	0
2	5	12	0	0.000	0
3	5	12	1	0.000	0
4	5	13	0	0.000	0
5	5	12	1	0.000	0
6	5	13	0	0.000	0
7	5	13	0	0.000	0
8	5	12	0	0.000	0
9	5	13	0	0.000	0
10	5	12	1	0.000	0
11	5	13	0	0.000	0
12	5	12	1	0.000	0
13	5	12	0	0.000	0
14	5	11	0	0.000	0
15	5	13	0	0.000	0
16	5	12	0	0.000	0
17	5	13	0	0.000	0
18	5	12	0	0.000	0
19	5	11	0	0.000	0
20	5	11	1	0.000	0
21	5	10	1	0.000	0
22	5	11	1	0.000	0
23	5	11	1	0.000	0
24	5	13	1	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	13	1	0.000	0
2	5	13	1	0.000	0
3	5	13	1	0.000	0
4	5	12	1	0.000	0
5	5	14	1	0.000	0
6	5	12	1	0.000	0
7	5	12	1	0.000	0
8	5	13	1	0.000	0
9	5	14	1	0.000	0
10	5	12	1	0.000	0
11	5	14	1	0.000	0
12	5	11	1	0.000	0
13	5	12	1	0.000	0
14	5	14	1	0.000	0
15	5	12	1	0.000	0
16	5	12	1	0.000	0
17	5	12	1	0.000	0
18	4	10	0	0.000	0
19	5	14	1	0.000	0
20	5	10	1	0.000	0
21	5	12	1	0.000	0
22	5	12	1	0.000	0
23	5	12	1	0.000	0
24	5	13	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2026年3月24日 (火)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	12	1	0.000	0
2	5	12	1	0.000	0
3	5	12	1	0.000	0
4	5	12	1	0.000	0
5	5	12	1	0.000	0
6	5	12	1	0.000	0
7	5	11	1	0.000	0
8	5	12	1	0.000	0
9	5	13	1	0.000	0
10	5	12	1	0.000	0
11	5	13	1	0.000	0
12	5	12	0	0.000	0
13	5	11	0	0.000	0
14	5	12	0	0.000	0
15	5	11	0	0.000	0
16	5	12	0	0.000	0
17	5	13	0	0.000	0
18	5	12	1	0.000	0
19	5	12	0	0.000	0
20	5	11	0	0.000	0
21	5	12	0	0.000	0
22	5	11	0	0.000	0
23	5	13	1	0.000	0
24	5	12	1	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	12	1	0.000	0
2	5	12	1	0.000	0
3	5	12	1	0.000	0
4	5	10	1	0.000	0
5	5	13	1	0.000	0
6	5	13	1	0.000	0
7	5	11	1	0.000	0
8	5	12	1	0.000	0
9	5	11	1	0.000	0
10	5	13	1	0.000	0
11	5	13	1	0.000	0
12	5	12	1	0.000	0
13	5	15	1	0.000	0
14	5	10	1	0.000	0
15	5	13	1	0.000	0
16	5	13	1	0.000	0
17	5	14	1	0.000	0
18	5	10	1	0.000	0
19	5	13	1	0.000	0
20	5	12	1	0.000	0
21	5	13	1	0.000	0
22	5	13	1	0.000	0
23	5	13	1	0.000	0
24	5	12	0	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2026年3月25日 (水)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	10	0	0.000	0
2	5	10	0	0.000	0
3	5	12	1	0.000	0
4	5	13	1	0.000	0
5	5	10	1	0.000	0
6	5	10	1	0.000	0
7	5	13	1	0.000	0
8	5	12	0	0.000	0
9	5	11	1	0.000	0
10	5	11	1	0.000	0
11	5	11	1	0.000	0
12	5	11	0	0.000	0
13	5	11	1	0.000	0
14	5	13	0	0.000	0
15	5	12	0	0.000	0
16	5	14	0	0.000	0
17	5	11	0	0.000	0
18	5	11	1	0.000	0
19	5	13	1	0.000	0
20	5	11	1	0.000	0
21	5	12	1	0.000	0
22	5	12	0	0.000	0
23	5	10	0	0.000	0
24	5	12	0	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	12	1	0.000	0
2	5	14	1	0.000	0
3	5	13	1	0.000	0
4	5	13	1	0.000	0
5	5	13	1	0.000	0
6	5	14	1	0.000	0
7	5	14	0	0.000	0
8	5	12	0	0.000	0
9	5	14	0	0.000	0
10	5	11	1	0.000	0
11	5	12	1	0.000	0
12	5	14	1	0.000	0
13	5	13	0	0.000	0
14	5	12	1	0.000	0
15	5	13	1	0.000	0
16	5	13	1	0.000	0
17	5	13	1	0.000	0
18	5	14	1	0.000	0
19	5	12	1	0.000	0
20	5	13	1	0.000	0
21	5	13	1	0.000	0
22	5	13	1	0.000	0
23	5	13	1	0.000	0
24	5	14	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2026年3月26日 (木)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	13	1	0.000	0
2	5	11	1	0.000	0
3	5	13	1	0.000	0
4	5	11	1	0.000	0
5	5	12	1	0.000	0
6	5	12	0	0.000	0
7	5	11	1	0.000	0
8	5	11	1	0.000	0
9	5	11	1	0.000	0
10	5	11	1	0.000	0
11	5	13	1	0.000	0
12	5	10	1	0.000	0
13	5	12	1	0.000	0
14	5	13	0	0.000	0
15	5	11	1	0.000	0
16	5	11	1	0.000	0
17	5	13	1	0.000	0
18	5	12	0	0.000	0
19	5	12	0	0.000	0
20	5	11	0	0.000	0
21	5	13	0	0.000	0
22	5	11	1	0.000	0
23	5	11	1	0.000	0
24	5	12	0	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	12	1	0.000	0
2	5	13	1	0.000	0
3	5	12	1	0.000	0
4	5	13	1	0.000	0
5	5	14	1	0.000	0
6	5	13	1	0.000	0
7	5	13	1	0.000	0
8	5	14	1	0.000	0
9	5	10	1	0.000	0
10	5	14	1	0.000	0
11	5	10	1	0.000	0
12	5	13	1	0.000	0
13	5	12	1	0.000	0
14	5	13	1	0.000	0
15	5	12	1	0.000	0
16	5	12	1	0.000	0
17	5	12	1	0.000	0
18	5	12	1	0.000	0
19	5	13	1	0.000	0
20	5	13	1	0.000	0
21	5	13	1	0.000	0
22	5	13	1	0.000	0
23	5	11	1	0.000	0
24	5	13	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2026年3月27日 (金)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	10	0	0.000	0
2	5	10	0	0.000	0
3	5	10	0	0.000	0
4	5	11	0	0.000	0
5	5	12	0	0.000	0
6	5	11	1	0.000	0
7	5	14	0	0.000	0
8	5	11	1	0.000	0
9	5	11	1	0.000	0
10	5	11	1	0.000	0
11	5	12	1	0.000	0
12	5	11	1	0.000	0
13	5	11	1	0.000	0
14	5	10	1	0.000	0
15	5	11	1	0.000	0
16	5	12	0	0.000	0
17	5	11	1	0.000	0
18	5	13	0	0.000	0
19	5	12	0	0.000	0
20	5	11	0	0.000	0
21	5	12	0	0.000	0
22	5	12	0	0.000	0
23	5	11	1	0.000	0
24	5	12	0	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	13	0	0.000	0
2	5	13	1	0.000	0
3	5	13	1	0.000	0
4	5	14	1	0.000	0
5	5	13	1	0.000	0
6	5	13	1	0.000	0
7	5	13	1	0.000	0
8	5	13	1	0.000	0
9	5	13	1	0.000	0
10	5	14	1	0.000	0
11	5	13	1	0.000	0
12	5	13	1	0.000	0
13	5	12	1	0.000	0
14	5	13	1	0.000	0
15	5	14	1	0.000	0
16	5	12	1	0.000	0
17	5	12	1	0.000	0
18	5	13	1	0.000	0
19	5	12	1	0.000	0
20	5	13	1	0.000	0
21	5	12	1	0.000	0
22	5	12	1	0.000	0
23	5	13	1	0.000	0
24	5	12	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2026年3月28日 (土)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	11	0	0.000	0
2	5	13	1	0.000	0
3	5	11	1	0.000	0
4	5	13	1	0.000	0
5	5	12	0	0.000	0
6	5	12	0	0.000	0
7	5	7	0	0.000	0
8	5	12	0	0.000	0
9	5	12	0	0.000	0
10	5	12	0	0.000	0
11	5	12	0	0.000	0
12	5	12	0	0.000	0
13	5	13	0	0.000	0
14	5	12	0	0.000	0
15	5	12	0	0.000	0
16	5	12	0	0.000	0
17	5	13	0	0.000	0
18	5	13	0	0.000	0
19	5	11	1	0.000	0
20	5	11	0	0.000	0
21	5	11	1	0.000	0
22	5	11	0	0.000	0
23	5	13	1	0.000	0
24	5	11	1	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	12	1	0.000	0
2	5	12	1	0.000	0
3	5	13	1	0.000	0
4	5	12	1	0.000	0
5	5	13	0	0.000	0
6	5	13	1	0.000	0
7	5	12	1	0.000	0
8	5	12	1	0.000	0
9	5	14	1	0.000	0
10	5	12	0	0.000	0
11	5	13	1	0.000	0
12	5	13	1	0.000	0
13	5	12	1	0.000	0
14	5	12	1	0.000	0
15	5	14	1	0.000	0
16	5	13	1	0.000	0
17	5	13	1	0.000	0
18	5	13	1	0.000	0
19	5	14	1	0.000	0
20	5	10	1	0.000	0
21	5	15	1	0.000	0
22	5	12	1	0.000	0
23	5	11	1	0.000	0
24	5	14	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2026年3月29日 (日)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	13	1	0.000	0
2	5	13	1	0.000	0
3	5	13	1	0.000	0
4	5	11	1	0.000	0
5	5	12	1	0.000	0
6	5	9	1	0.000	0
7	5	11	1	0.000	0
8	5	11	1	0.000	0
9	5	13	1	0.000	0
10	5	12	1	0.000	0
11	5	10	1	0.000	0
12	5	14	0	0.000	0
13	5	12	0	0.000	0
14	5	13	0	0.000	0
15	5	13	0	0.000	0
16	5	11	0	0.000	0
17	5	8	0	0.000	0
18	5	12	0	0.000	0
19	5	12	0	0.000	0
20	5	12	1	0.000	0
21	5	14	0	0.000	0
22	5	11	0	0.000	0
23	5	12	0	0.000	0
24	5	12	1	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	12	1	0.000	0
2	5	10	1	0.000	0
3	5	13	0	0.000	0
4	5	8	0	0.000	0
5	5	14	1	0.000	0
6	5	13	1	0.000	0
7	5	12	1	0.000	0
8	5	13	1	0.000	0
9	5	13	1	0.000	0
10	5	12	1	0.000	0
11	5	13	1	0.000	0
12	5	13	1	0.000	0
13	5	12	1	0.000	0
14	5	14	1	0.000	0
15	5	13	1	0.000	0
16	5	12	1	0.000	0
17	5	13	1	0.000	0
18	5	13	1	0.000	0
19	5	13	1	0.000	0
20	5	13	1	0.000	0
21	5	13	1	0.000	0
22	5	13	1	0.000	0
23	5	14	0	0.000	0
24	5	12	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

**環境監視日報**

2026年3月30日 (月)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	13	1	0.000	0
2	5	13	0	0.000	0
3	5	11	1	0.000	0
4	5	13	0	0.000	0
5	5	12	1	0.000	0
6	5	12	0	0.000	0
7	5	14	0	0.000	0
8	5	10	0	0.000	0
9	5	13	0	0.000	0
10	5	12	0	0.000	0
11	5	11	1	0.000	0
12	5	12	0	0.000	0
13	5	12	0	0.000	0
14	5	13	0	0.000	0
15	5	11	0	0.000	0
16	5	12	0	0.000	0
17	5	12	0	0.000	0
18	5	13	0	0.000	0
19	5	9	0	0.000	0
20	5	14	0	0.000	0
21	5	12	0	0.000	0
22	5	13	0	0.000	0
23	5	13	0	0.000	0
24	5	11	0	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	13	1	0.000	0
2	5	13	1	0.000	0
3	5	13	1	0.000	0
4	5	13	1	0.000	0
5	5	13	1	0.000	0
6	5	14	1	0.000	0
7	5	13	1	0.000	0
8	5	12	1	0.000	0
9	5	12	1	0.000	0
10	5	13	1	0.000	0
11	5	13	1	0.000	0
12	5	9	1	0.000	0
13	5	13	1	0.000	0
14	5	13	1	0.000	0
15	5	13	1	0.000	0
16	5	13	1	0.000	0
17	5	13	1	0.000	0
18	5	13	1	0.000	0
19	5	11	1	0.000	0
20	5	14	1	0.000	0
21	5	12	0	0.000	0
22	5	13	0	0.000	0
23	5	13	0	0.000	0
24	5	12	1	0.000	0

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2026年3月31日 (火)

項目 時刻	1号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	11	0	0.000	0
2	5	12	0	0.000	0
3	5	12	0	0.000	0
4	5	12	0	0.000	0
5	5	12	0	0.000	0
6	5	10	0	0.000	0
7	5	11	1	0.000	0
8	5	11	0	0.000	0
9	5	13	0	0.000	0
10	5	12	0	0.000	0
11	5	10	0	0.000	0
12	5	12	0	0.000	0
13	5	11	0	0.000	0
14	5	13	0	0.000	0
15	5	13	0	0.000	0
16	5	12	2	0.000	0
17	5	12	1	0.000	0
18	5	12	0	0.000	0
19	5	11	1	0.000	0
20	5	12	1	0.000	0
21	5	12	0	0.000	0
22	5	13	0	0.000	0
23	5	11	0	0.000	0
24	5	12	0	0.000	0

自主規制値  
法規制値

項目 時刻	2号炉				
	塩化水素	窒素酸化物	硫黄酸化物	ばいじん	水銀
	ppm	ppm	ppm	g/m <sup>3</sup> N	μg/m <sup>3</sup> N
	10	20	10	0.005	50
	430	250	約2700	0.040	50
1	5	12	1	0.000	0
2	5	14	1	0.000	0
3	5	13	1	0.000	0
4	5	12	1	0.000	0
5	5	14	0	0.000	0
6	5	12	1	0.000	0
7	5	12	1	0.000	0
8	5	13	1	0.000	0
9	5	13	1	0.000	0
10	5	14	0	0.000	0
11	5	12	1	0.000	0
12	5	13	1	0.000	0
13	5	12	1	0.000	0
14	5	13	1	0.000	0
15	5	11	1	0.000	0
16	5	14	1	0.000	0
17	5	11	1	0.000	0
18	5	14	1	0.000	0
19	5	12	1	0.000	0
20	5	13	1	0.000	0
21	5	13	1	0.000	0
22	5	12	1	0.000	0
23	5	13	1	0.000	0
24	5	13	1	0.000	0